

TREVICO, Italy

WMO: 162630

Lat: 41.047N

Lon: 15.233E

Elev: 1093

StdP: 88.87

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-4.4	-12.7	1.4	2.8	-9.9	1.8	0.7	17.7	4.6	15.4	3.6	5.8	0	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	28.2	17.0	26.9	16.7	25.2	16.2	19.5	23.9	18.6	23.3	17.8	22.7	3.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	14.9	21.4	17.0	13.9	20.7	16.1	13.1	20.1	60.7	23.7	57.3	23.3	54.8	23.1	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.7	10.3	-8.1	30.0	1.9	2.1	-9.5	31.5	-10.6	32.7	-11.7	33.9	-13.1	35.4		
(5)			-8.9	21.6	1.9	1.3	-10.2	22.5	-11.3	23.2	-12.3	23.9	-13.7	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	2.2	2.5	5.1	8.6	12.8	17.3	20.2	20.3	15.3	11.7	7.5	3.7		
	DBStd	7.31	3.45	3.71	3.83	3.49	3.86	4.12	3.14	3.22	3.51	3.64	3.64	3.43		
	HDD10.0	1003	242	211	156	64	15	2	0	0	3	24	89	196		
	HDD18.3	3009	500	443	410	291	178	68	16	17	102	206	326	453		
	CDD10.0	1243	0	1	4	24	101	220	317	319	163	78	14	1		
	CDD18.3	207	0	0	0	0	6	37	74	77	12	1	0	0		
	CDH23.3	912	0	0	0	1	19	152	359	357	24	1	0	0		
	CDH26.7	149	0	0	0	0	2	22	61	63	1	0	0	0		
(14) Wind	WSAvg	5.1	5.9	5.8	6.0	5.4	5.0	4.6	4.5	4.5	4.4	4.7	5.2	5.7		
(15) Precipitation	PrecAvg	628	54	48	60	64	47	42	37	31	63	56	77	72		
	PrecMax	995	159	90	155	136	128	91	115	105	184	144	239	151		
	PrecMin	459	10	8	0	24	7	5	1	0	17	4	22	14		
	PrecStd	123	34	24	34	25	30	23	30	24	40	34	44	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	13.9	15.6	20.0	25.8	29.0	30.2	31.0	25.9	21.8	18.9	12.9		
		MCWB	4.9	6.1	8.8	12.5	15.2	17.3	16.5	17.8	15.0	13.3	9.6	8.8		
	2%	DB	9.2	10.9	13.5	17.4	22.8	27.0	28.2	28.2	23.8	19.1	15.1	10.9		
		MCWB	5.6	5.5	8.1	11.0	14.4	17.1	16.9	17.0	15.0	13.2	9.3	7.6		
	5%	DB	7.9	8.9	11.8	15.2	20.3	25.0	26.9	26.5	22.0	17.9	13.7	9.1		
		MCWB	5.5	5.9	7.7	9.5	13.5	16.6	16.9	16.3	14.8	12.8	9.5	6.4		
	10%	DB	6.8	7.1	10.1	13.9	18.8	23.2	25.1	25.1	20.2	16.4	12.0	8.0		
		MCWB	5.2	4.9	6.6	9.0	12.9	15.7	16.4	16.0	14.6	12.4	9.1	6.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.9	10.9	14.1	16.7	20.2	20.8	20.9	18.2	16.1	13.0	9.7		
		MCDB	9.3	9.9	13.2	18.1	22.2	24.9	24.5	25.0	21.0	18.3	14.9	11.7		
	2%	WB	6.9	7.6	9.2	11.9	15.5	18.8	19.5	19.3	17.3	14.8	11.7	8.4		
		MCDB	7.9	9.2	12.1	15.8	20.4	23.9	23.9	23.8	20.4	17.3	13.5	9.9		
	5%	WB	6.0	6.3	8.2	10.5	14.6	17.7	18.6	18.4	16.4	13.9	10.7	7.5		
		MCDB	7.1	7.6	10.8	13.9	19.4	23.0	23.3	23.3	19.7	16.3	12.6	8.7		
	10%	WB	5.1	5.2	7.2	9.6	13.5	16.7	17.8	17.7	15.5	13.1	9.8	6.4		
		MCDB	6.2	6.5	9.3	12.8	17.8	22.0	22.6	22.8	19.0	15.5	11.5	7.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	4.3	5.2	5.9	6.6	6.9	7.2	6.9	5.7	4.8	4.1	3.7		
		MCDBR	4.4	5.7	6.9	7.2	7.6	7.8	8.1	7.6	6.9	5.8	5.2	4.6		
		MCWBR	3.5	4.4	5.2	5.7	5.7	5.5	5.2	4.9	4.8	4.4	4.2	3.7		
	5% WB	MCDBR	3.8	4.9	6.2	6.5	7.3	7.5	7.3	6.9	6.0	5.1	4.9	4.2		
		MCWBR	3.7	4.5	5.0	5.6	5.8	5.7	5.5	5.2	4.9	4.4	4.4	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.287	0.305	0.332	0.371	0.370	0.367	0.365	0.365	0.357	0.327	0.310	0.290		
	taud		2.552	2.490	2.411	2.292	2.336	2.368	2.380	2.386	2.423	2.517	2.530	2.552		
	Ebn at Noon		884	914	919	899	906	905	904	895	880	875	844	849		
	Edh at Noon		70	87	105	127	124	121	118	114	103	83	72	65		
(44) All-Sky Solar Radiation	RadAvg		1.74	2.50	3.73	4.96	6.09	6.96	7.19	6.37	4.55	3.19	2.03	1.59		
	RadStd		0.21	0.27	0.41	0.43	0.44	0.36	0.41	0.43	0.26	0.30	0.20	0.21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-100	+144	+67

Nomenclature: See separate page