

BARI PALESE, ItalyWMO: **162700**Lat: **41.138N**Lon: **16.765E**Elev: **177**StdP: **14.60**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.7	35.7	20.9	15.8	41.5	24.4	18.6	42.2	25.3	48.3	22.3	46.2	8.3	220	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	93.5	71.9	90.2	71.4	87.8	71.0	77.2	85.6	75.4	84.1	73.9	83.3	9.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.9	131.8	81.9	73.0	123.1	80.9	70.9	114.8	80.0	40.7	85.3	39.0	83.8	37.5	83.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	18.0	15.9	29.2	101.4	2.2	4.6	27.7	104.7	26.4	107.4	25.2	110.0	23.6	113.4
			27.2	79.6	2.3	2.2	25.6	81.2	24.3	82.5	23.0	83.7	21.4	85.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	47.4	47.7	51.8	57.2	65.0	73.0	77.5	77.2	70.0	62.9	55.9	49.6
	DBStd	11.91	5.00	5.40	5.18	4.97	4.85	5.41	4.47	4.25	5.10	4.89	5.65	5.25
	HDD50	339	112	100	38	5	0	0	0	0	0	0	14	70
	HDD65	2612	547	485	409	239	62	5	0	0	12	98	277	478
	CDD50	4479	30	35	94	221	464	689	853	844	601	401	191	56
	CDD65	1278	0	0	1	5	61	243	388	379	163	34	4	0
	CDH74	11747	0	0	5	36	412	2194	4116	3798	1056	122	8	0
	CDH80	4129	0	0	0	7	75	727	1628	1420	262	10	0	0
(14) Wind	WSAvg	7.5	7.7	8.1	8.1	7.6	7.3	7.3	7.8	7.3	7.4	6.9	7.1	7.7
(15) Precipitation	PrecAvg	21.6	1.9	2.1	1.9	1.6	1.4	1.0	1.0	1.2	2.3	2.4	2.1	2.4
	PrecMax	33.4	4.6	5.4	5.0	5.2	4.4	3.8	3.9	5.0	8.5	6.6	5.7	4.9
	PrecMin	12.6	0.1	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.1	0.0	0.3	0.2
	PrecStd	5.5	1.1	1.5	1.4	1.3	1.0	0.9	1.1	1.1	1.9	1.7	1.3	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	66.5	72.0	78.7	87.6	95.1	98.9	98.4	91.5	81.0	74.5	66.6
		MCWB	54.9	55.1	57.9	61.7	67.4	72.2	71.8	73.2	70.6	67.2	63.3	57.9
	2%	DB	61.0	62.6	67.6	73.0	82.0	90.0	94.0	93.1	86.1	77.3	70.3	63.0
		MCWB	54.2	53.9	56.1	59.9	65.5	70.2	71.6	72.5	70.1	66.4	61.6	56.1
	5%	DB	58.8	59.5	64.2	69.5	78.6	87.2	90.5	89.7	82.5	74.5	67.9	60.8
		MCWB	52.7	52.4	54.2	58.2	64.5	69.7	71.2	72.7	69.4	64.9	60.8	54.8
	10%	DB	55.8	57.2	61.1	66.4	75.5	84.1	87.8	86.9	79.7	71.8	65.0	58.3
		MCWB	50.4	50.7	53.2	56.7	63.3	69.4	71.0	71.9	68.6	64.1	59.0	52.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	58.2	59.9	63.9	70.1	76.4	79.1	80.6	75.5	71.0	66.1	60.2
		MCDB	62.4	63.3	69.0	73.4	78.1	84.3	86.1	88.4	82.5	76.9	70.7	64.8
	2%	WB	55.4	55.3	57.4	61.6	68.1	74.3	76.8	77.9	73.0	68.6	63.5	57.5
		MCDB	59.7	60.6	64.2	69.5	77.7	83.5	85.5	86.5	80.6	73.9	68.5	62.1
	5%	WB	53.5	53.2	55.7	59.8	66.2	72.7	75.0	75.9	71.4	66.9	61.6	55.3
		MCDB	57.9	58.6	61.8	66.8	76.1	82.6	84.5	84.5	79.2	72.4	66.3	59.6
	10%	WB	51.1	51.3	54.3	58.2	64.5	70.9	73.4	74.3	69.8	65.3	59.9	53.4
		MCDB	55.3	56.3	60.2	64.6	73.7	81.0	84.0	83.2	77.8	70.8	64.5	57.6
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	14.0	15.2	15.8	16.9	17.0	16.7	16.5	15.5	14.8	13.9	13.2
		MCDBR	16.4	17.5	20.0	20.5	21.7	22.2	21.8	21.2	19.5	18.0	16.2	15.7
		MCWBR	10.7	11.0	11.9	11.5	11.3	11.6	12.7	12.6	10.6	10.3	10.1	10.3
	5% WB	MCDBR	14.4	15.6	17.7	17.9	19.2	18.4	17.7	17.4	17.2	16.2	13.9	14.1
		MCWBR	10.3	10.3	11.5	11.0	11.2	11.8	12.5	12.6	10.7	10.4	9.5	10.0
(40) Clear-Sky Solar Irradiance	taub		0.340	0.363	0.398	0.445	0.441	0.431	0.426	0.432	0.423	0.394	0.366	0.342
	taud		2.457	2.371	2.274	2.147	2.224	2.293	2.315	2.300	2.319	2.383	2.414	2.449
	Ebn at Noon		257	266	268	263	267	269	269	264	258	252	243	244
	Edh at Noon		25	31	38	47	44	41	40	40	36	30	26	23
(44) All-Sky Solar Radiation	RadAvg		572	810	1228	1617	1980	2228	2264	1987	1452	1014	651	507
	RadStd		61	74	123	123	122	111	97	113	84	79	51	62

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.88	N/A	N/A	N/A	-1.55	-2.43	N/A	-184	+288	N/A
Regional (11 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-121	+166	N/A