

PONZA, Italy

WMO: 162800

Lat: 40.912N

Lon: 12.957E

Elev: 185

StdP: 99.12

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.0	6.2	-3.5	2.9	7.3	-1.1	3.5	8.0	16.8	10.8	14.8	11.3	6.5	40	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	30.0	25.5	29.0	25.1	28.1	24.5	27.0	28.9	26.2	27.9	25.5	27.2	2.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.5	28.3	25.7	21.4	27.6	24.9	20.4	26.8	86.3	29.0	82.5	28.0	79.3	27.2	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.8	10.1	3.3	31.9	1.6	1.6	2.2	33.1	1.2	34.0	0.3	34.9	-0.8	36.1		
(5)			0.7	27.8	1.4	1.5	-0.3	28.9	-1.2	29.8	-2.0	30.6	-3.0	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	10.8	10.5	11.9	14.4	17.9	22.2	25.1	25.7	22.6	19.1	15.2	12.2		
	DBStd	5.73	1.95	2.12	1.94	1.99	2.07	2.35	1.85	1.72	2.00	2.11	2.46	2.16		
	HDD10.0	48	14	18	7	1	0	0	0	0	0	0	1	7		
	HDD18.3	1107	233	218	200	119	32	1	0	0	1	16	96	191		
	CDD10.0	2728	39	33	66	133	246	365	468	487	378	282	157	74		
	CDD18.3	746	0	0	0	1	20	116	210	228	129	40	2	0		
	CDH23.3	3858	0	0	0	1	15	414	1410	1640	366	12	0	0		
	CDH26.7	613	0	0	0	0	0	45	237	312	19	0	0	0		
(14) Wind	WSAvg	4.4	5.3	5.1	4.8	4.2	4.0	3.6	3.5	3.6	3.8	4.2	5.2	5.4		
(15) Precipitation	PrecAvg	631	81	58	55	38	21	9	5	24	47	101	91	95		
	PrecMax	992	170	143	132	87	83	30	32	107	152	352	154	265		
	PrecMin	263	2	7	11	6	0	0	0	0	0	12	0	22		
	PrecStd	177	52	41	38	25	18	9	9	25	43	84	47	65		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	15.1	17.1	21.6	25.0	29.7	31.0	32.0	28.4	24.7	21.1	17.0		
		MCWB	13.6	12.6	13.9	17.7	20.6	23.6	25.8	25.6	24.0	21.7	19.0	15.3		
	2%	DB	14.2	14.1	15.8	19.4	23.3	27.9	29.8	30.3	27.1	23.3	19.8	16.0		
		MCWB	12.8	12.4	13.2	16.0	19.6	23.3	25.2	26.1	23.6	20.7	18.1	14.7		
	5%	DB	13.8	13.5	15.0	18.1	22.1	26.7	28.9	29.2	26.2	22.3	18.9	15.3		
		MCWB	12.3	11.8	12.6	15.3	18.8	22.9	25.1	25.4	23.1	20.0	17.4	14.0		
	10%	DB	13.1	13.0	14.2	17.0	20.9	25.7	28.0	28.4	25.2	21.6	18.1	14.9		
		MCWB	11.7	11.4	12.2	14.6	18.0	22.3	24.6	24.9	22.6	19.5	16.5	13.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	13.7	14.9	18.6	22.2	26.1	27.9	28.6	25.6	22.7	19.7	15.8		
		MCDB	15.0	14.4	16.2	20.6	23.7	27.8	29.6	30.3	27.2	24.0	20.5	16.3		
	2%	WB	13.2	12.9	13.9	16.8	20.6	24.9	26.9	27.4	24.7	21.4	18.4	15.0		
		MCDB	14.0	13.8	15.0	18.5	22.5	26.7	28.6	29.3	26.2	22.6	19.5	15.7		
	5%	WB	12.6	12.2	13.2	15.8	19.4	23.9	26.2	26.4	24.0	20.6	17.5	14.3		
		MCDB	13.5	13.2	14.3	17.6	21.3	25.8	27.8	28.3	25.4	21.8	18.6	15.2		
	10%	WB	12.0	11.7	12.7	15.0	18.6	23.0	25.5	25.7	23.3	20.0	16.7	13.7		
		MCDB	13.0	12.7	13.8	16.5	20.3	24.9	27.1	27.4	24.8	21.1	17.8	14.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	2.9	3.4	3.8	4.2	4.7	4.8	4.5	3.9	3.3	2.8	2.5		
		MCDBR	2.8	3.3	4.1	5.2	5.3	5.7	5.4	5.5	4.5	4.0	3.1	2.7		
	5% WB	MCWBR	2.7	2.9	3.5	4.3	4.5	5.1	4.7	4.5	3.5	3.3	2.8	2.7		
		MCWBR	2.5	3.1	3.8	4.8	5.0	5.3	5.1	5.2	4.2	3.8	2.9	2.5		
(40) Clear-Sky Solar Irradiance	taub		0.336	0.357	0.390	0.425	0.425	0.418	0.416	0.417	0.409	0.389	0.368	0.339		
	taud		2.494	2.424	2.335	2.249	2.296	2.362	2.373	2.379	2.395	2.432	2.417	2.480		
	Ebn at Noon		818	850	857	849	855	859	857	847	828	803	766	780		
	Edh at Noon		76	94	114	133	130	122	119	115	107	92	82	72		
(44) All-Sky Solar Radiation	RadAvg		1.87	2.77	4.07	5.44	6.62	7.50	7.56	6.59	4.89	3.39	2.13	1.67		
	RadStd		0.17	0.26	0.43	0.33	0.46	0.28	0.32	0.36	0.20	0.28	0.17	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.41	N/A	N/A	+0.53	N/A	N/A	N/A	-79	+131	+68

Nomenclature: See separate page