

NAPOLI CAPODICHINO, Italy

WMO: 162890

Lat: 40.884N

Lon: 14.291E

Elev: 236

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.1	36.9	18.0	13.7	39.7	21.6	16.4	42.1	23.6	49.8	20.5	49.7	4.9	30	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	91.5	73.3	89.5	73.1	87.6	73.1	78.9	86.1	77.2	84.7	75.5	83.4	8.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.0	141.7	83.4	75.0	132.5	82.2	73.2	124.6	80.8	42.6	85.5	40.8	84.0	39.2	83.2	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	16.2	13.8	DB	29.1	96.5	2.8	2.7	27.1	98.4	25.5	100.0	23.9	101.5	21.9	103.5
			WB	26.1	81.6	2.7	2.7	24.1	83.5	22.5	85.1	20.9	86.6	19.0	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	49.0	49.6	53.7	58.9	66.2	73.7	78.4	79.1	71.8	65.3	57.5	50.8
	DBStd	11.65	5.07	4.97	4.82	4.77	4.53	4.95	3.38	3.61	4.35	4.56	5.59	5.47
	HDD50	230	78	62	22	3	0	0	0	0	0	0	9	56
	HDD65	2238	495	432	350	189	40	3	0	0	4	52	232	441
	CDD50	4940	48	49	137	270	501	712	879	902	655	474	233	80
	CDD65	1475	0	0	0	7	77	265	414	437	209	60	6	0
	CDH74	12419	0	0	1	41	405	2139	4023	4332	1264	207	7	0
	CDH80	4123	0	0	0	4	57	620	1465	1697	265	15	0	0
Wind	WSAvg	5.3	5.5	6.0	6.2	5.6	5.3	5.0	5.1	4.8	5.0	4.6	5.0	5.5
Precipitation	PrecAvg	40.1	4.0	3.5	3.4	3.2	2.0	1.5	1.0	1.5	3.1	5.2	6.5	4.6
	PrecMax	62.0	8.5	9.4	9.3	9.1	8.2	7.2	6.0	4.4	8.0	13.2	15.0	10.2
	PrecMin	23.3	0.2	0.5	0.3	0.8	0.0	0.0	0.0	0.0	0.0	0.2	0.8	0.2
	PrecStd	8.5	2.4	2.5	2.2	2.2	1.7	1.5	1.3	1.2	2.0	3.5	3.8	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	64.7	71.7	78.8	84.8	91.7	93.5	96.5	89.5	82.2	74.5	66.4
		MCWB	56.2	54.6	55.3	59.8	66.5	72.3	73.0	73.6	68.7	66.5	63.1	58.9
	2%	DB	61.2	62.1	67.6	73.7	80.9	88.2	91.1	92.0	85.6	78.6	71.5	63.0
		MCWB	55.0	53.4	55.9	59.2	65.4	71.9	73.5	73.6	70.2	66.1	62.5	56.8
	5%	DB	59.2	59.4	64.6	70.3	78.6	86.1	89.2	89.8	82.8	76.5	69.2	61.2
		MCWB	53.9	52.7	55.1	58.1	65.2	71.3	73.0	73.9	69.9	65.7	61.7	55.9
	10%	DB	57.3	57.7	62.4	67.9	75.6	83.8	87.2	87.9	80.6	73.8	66.5	59.4
		MCWB	52.4	51.8	54.6	57.2	64.3	70.8	73.1	73.8	69.2	64.5	59.7	54.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	57.7	60.6	63.8	71.1	78.5	80.8	81.8	77.0	71.5	66.7	61.1
		MCDB	61.8	61.9	65.4	71.4	78.5	85.0	87.9	87.4	81.3	76.9	70.8	64.2
	2%	WB	56.7	55.8	58.6	61.8	69.1	75.9	78.3	79.7	74.3	69.1	64.1	59.1
		MCDB	60.0	59.5	63.6	69.4	76.7	83.6	86.1	86.4	80.5	75.1	69.2	62.0
	5%	WB	54.9	54.4	57.1	60.1	67.4	74.3	76.7	78.0	72.5	67.4	62.3	56.9
		MCDB	58.5	58.5	62.2	67.0	75.0	82.4	84.7	85.3	79.3	73.4	67.8	60.8
	10%	WB	53.0	52.8	55.7	58.9	65.6	72.6	75.2	76.1	70.9	65.9	60.4	54.9
		MCDB	56.8	57.3	60.5	65.2	73.1	80.7	83.3	83.8	77.8	72.0	65.7	59.0
Mean Daily Temperature Range	5% DB	MDBR	13.4	13.9	14.5	15.2	15.6	16.1	16.4	16.7	15.8	15.6	14.3	13.7
		MCDBR	14.4	15.6	18.0	19.1	19.3	18.9	18.8	19.0	17.6	17.7	15.8	14.2
		MCWBR	10.2	10.3	10.6	9.6	9.5	9.5	10.1	9.9	8.9	9.5	9.8	9.9
	5% WB	MCDBR	12.2	13.4	14.8	15.8	16.9	16.6	16.4	17.2	15.7	15.5	13.7	12.4
		MCWBR	10.0	10.1	9.9	9.4	9.8	10.1	10.7	10.8	9.4	9.8	9.8	9.9
Clear-Sky Solar Irradiance	taub	0.342	0.366	0.404	0.450	0.446	0.442	0.440	0.439	0.430	0.395	0.374	0.345	
	taud	2.459	2.373	2.262	2.140	2.204	2.262	2.281	2.285	2.302	2.390	2.387	2.449	
	Ebn at Noon	256	266	267	261	265	266	265	262	256	252	240	244	
	Edh at Noon	25	31	39	47	45	43	42	40	37	30	27	23	
All-Sky Solar Radiation	RadAvg	574	832	1233	1647	2022	2308	2348	2070	1512	1053	661	521	
	RadStd	57	92	142	124	134	100	121	124	67	95	61	58	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.61	N/A	N/A	N/A	N/A	-1.53	N/A	N/A	+185	+126
(47)	Regional (16 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-142	+236	+122

Nomenclature: See separate page