

NAPOLI CAPODICHINO, Italy

WMO: 162890

Lat: 40.884N

Lon: 14.291E

Elev: 72

StdP: 100.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	2.7	-7.8	2.0	4.3	-5.8	2.3	5.6	10.6	9.9	9.2	9.8	2.2	30	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	33.1	22.9	32.0	22.8	30.9	22.8	26.1	30.0	25.1	29.3	24.2	28.6	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.2	28.5	23.9	18.9	27.9	22.9	17.8	27.1	81.1	29.7	76.9	28.9	73.2	28.5	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.2	6.2	-1.6	35.8	1.5	1.5	-2.7	36.9	-3.6	37.8	-4.5	38.6	-5.6	39.7		
(5)			-3.3	27.5	1.5	1.5	-4.4	28.6	-5.3	29.5	-6.1	30.3	-7.2	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	9.5	9.8	12.1	15.0	19.0	23.2	25.8	26.2	22.1	18.5	14.2	10.4		
	DBStd	6.47	2.82	2.76	2.68	2.65	2.52	2.75	1.88	2.01	2.42	2.53	3.10	3.04		
	HDD10.0	128	43	34	12	2	0	0	0	0	0	0	5	31		
	HDD18.3	1243	275	240	194	105	22	2	0	0	2	29	129	245		
	CDD10.0	2744	27	27	76	150	278	396	488	501	364	263	129	44		
	CDD18.3	819	0	0	0	4	43	147	230	243	116	33	3	0		
	CDH23.3	6899	0	0	1	23	225	1188	2235	2407	702	115	4	0		
	CDH26.7	2291	0	0	0	2	32	344	814	943	147	8	0	0		
(14) Wind	WSAvg	2.4	2.5	2.7	2.8	2.5	2.3	2.3	2.3	2.1	2.2	2.1	2.2	2.5		
(15) Precipitation	PrecAvg	1019	101	90	86	81	51	38	25	38	78	132	165	116		
	PrecMax	1576	217	239	235	230	208	182	152	112	202	336	380	260		
	PrecMin	592	4	13	7	21	0	0	0	0	0	4	20	5		
	PrecStd	215	61	64	55	56	42	37	34	31	50	90	97	66		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	18.2	22.0	26.0	29.3	33.2	34.2	35.8	31.9	27.9	23.6	19.1		
		MCWB	13.4	12.6	13.0	15.4	19.2	22.4	22.8	23.1	20.4	19.2	17.3	15.0		
	2%	DB	16.2	16.7	19.8	23.2	27.2	31.2	32.8	33.3	29.8	25.9	21.9	17.2		
		MCWB	12.8	11.9	13.3	15.1	18.6	22.2	23.0	23.1	21.2	19.0	16.9	13.8		
	5%	DB	15.1	15.2	18.1	21.3	25.9	30.0	31.8	32.1	28.2	24.7	20.7	16.2		
		MCWB	12.2	11.5	12.9	14.5	18.4	21.8	22.8	23.3	21.1	18.7	16.5	13.3		
	10%	DB	14.1	14.3	16.9	19.9	24.2	28.8	30.7	31.0	27.0	23.2	19.2	15.2		
		MCWB	11.3	11.0	12.5	14.0	17.9	21.5	22.8	23.2	20.6	18.0	15.4	12.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.0	14.3	15.9	17.6	21.7	25.9	27.1	27.6	25.0	22.0	19.3	16.2		
		MCDB	16.6	16.6	18.6	21.9	25.8	29.4	31.0	30.8	27.4	24.9	21.6	17.9		
	2%	WB	13.7	13.2	14.8	16.5	20.6	24.4	25.7	26.5	23.5	20.6	17.8	15.0		
		MCDB	15.6	15.3	17.6	20.8	24.8	28.7	30.0	30.2	27.0	23.9	20.7	16.7		
	5%	WB	12.7	12.4	14.0	15.6	19.7	23.5	24.8	25.5	22.5	19.7	16.9	13.8		
		MCDB	14.7	14.7	16.8	19.5	23.9	28.0	29.3	29.6	26.3	23.0	19.9	16.0		
	10%	WB	11.6	11.6	13.1	15.0	18.7	22.6	24.0	24.5	21.6	18.8	15.8	12.7		
		MCDB	13.8	14.0	15.8	18.5	22.8	27.0	28.5	28.8	25.4	22.2	18.7	15.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.7	8.0	8.4	8.6	9.0	9.1	9.3	8.8	8.7	7.9	7.6		
		MCDBR	8.0	8.7	10.0	10.6	10.7	10.5	10.5	10.5	9.8	9.9	8.8	7.9		
		MCWBR	5.7	5.7	5.9	5.3	5.3	5.3	5.6	5.5	4.9	5.3	5.5	5.5		
	5% WB	MCDBR	6.8	7.4	8.2	8.8	9.4	9.2	9.1	9.5	8.7	8.6	7.6	6.9		
		MCWBR	5.6	5.6	5.5	5.2	5.5	5.6	5.9	6.0	5.2	5.4	5.4	5.5		
(40) Clear-Sky Solar Irradiance	taub		0.342	0.366	0.404	0.450	0.446	0.442	0.440	0.439	0.430	0.395	0.374	0.345		
	taud		2.459	2.373	2.262	2.140	2.204	2.262	2.281	2.285	2.302	2.390	2.387	2.449		
	Ebn at Noon		808	838	841	824	836	838	836	825	806	795	757	770		
	Edh at Noon		79	99	123	148	142	134	131	127	117	96	84	74		
(44) All-Sky Solar Radiation	RadAvg		1.81	2.62	3.89	5.19	6.37	7.28	7.40	6.53	4.77	3.32	2.08	1.64		
	RadStd		0.18	0.29	0.45	0.39	0.42	0.32	0.38	0.39	0.21	0.30	0.19	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.34	N/A	N/A	N/A	N/A	-0.85	N/A	N/A	+103	+70
(47) Regional (16 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-79	+131	+68

Nomenclature: See separate page