

CAPRI, Italy

WMO: 162940

Lat: 40.559N

Lon: 14.201E

Elev: 161

StdP: 99.41

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	5.1	-8.1	1.9	6.7	-5.3	2.5	7.8	9.8	10.1	8.5	10.0	3.0	60	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	33.2	24.5	32.1	24.2	30.9	23.8	27.4	31.0	26.2	29.7	25.4	28.7	1.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	22.2	30.0	25.2	20.7	28.7	24.2	19.5	27.7	88.0	31.1	82.6	29.9	78.5	28.8	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.5	5.3	1.7	35.0	1.3	2.3	0.7	36.6	0.0	37.9	-0.8	39.2	-1.7	40.8		
(5)			-1.1	28.9	1.4	1.6	-2.2	30.0	-3.0	30.9	-3.8	31.8	-4.8	33.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	10.8	11.0	12.9	16.2	19.8	23.9	26.9	27.4	23.8	19.9	15.7	12.2
	DBStd	6.36	2.40	2.67	2.52	2.41	2.76	2.83	1.85	1.83	2.46	2.47	2.84	2.46
	HDD10.0	57	19	19	7	1	0	0	0	0	0	0	2	9
	HDD18.3	987	233	207	170	73	16	1	0	0	1	12	85	191
	CDD10.0	3129	44	46	96	186	303	418	523	539	415	308	173	77
	CDD18.3	1018	0	0	1	8	61	169	265	281	166	62	7	0
	CDH23.3	6861	0	0	1	21	193	1025	2232	2466	819	98	6	0
	CDH26.7	2142	0	0	0	3	36	278	751	878	188	8	0	0
Wind	WSAvg	1.9	2.3	2.4	2.2	1.8	1.7	1.4	1.4	1.3	1.5	1.6	2.3	2.3
Precipitation	PrecAvg	720	80	60	67	63	27	22	16	24	68	97	107	90
	PrecMax	1146	264	163	232	136	84	60	76	134	147	332	287	167
	PrecMin	463	9	6	0	24	6	2	0	1	7	3	28	0
	PrecStd	207	56	46	49	27	18	18	17	32	33	73	57	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	19.1	21.2	26.0	30.0	33.8	35.0	35.2	32.6	27.8	24.1	18.8
		MCWB	13.3	12.3	14.6	17.1	18.2	23.6	24.4	25.4	23.2	21.0	17.0	14.7
	2%	DB	15.5	16.2	19.1	22.9	27.1	31.4	33.2	33.4	30.2	25.8	21.7	17.0
		MCWB	12.9	12.3	13.6	16.0	19.0	24.3	24.6	25.0	22.6	20.1	17.5	13.8
	5%	DB	14.8	14.9	17.3	21.1	25.2	29.7	31.9	32.1	28.8	24.1	20.1	16.0
		MCWB	12.2	11.6	12.9	15.2	18.6	22.7	24.4	24.2	21.6	19.3	16.9	13.5
	10%	DB	13.8	13.9	16.0	19.9	23.9	28.1	30.6	31.0	27.1	23.0	19.0	15.1
		MCWB	11.5	11.4	12.1	14.8	18.1	22.0	23.7	24.1	21.2	18.8	16.0	12.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	14.5	16.7	19.2	22.5	26.6	28.7	29.4	26.1	23.6	20.0	15.7
		MCDB	15.7	16.6	19.2	22.2	25.8	31.7	32.4	33.0	30.0	26.1	21.4	17.3
	2%	WB	13.5	13.3	14.9	17.6	21.2	26.2	26.9	27.6	24.7	21.7	18.5	14.7
		MCDB	14.9	15.1	17.6	21.0	24.3	29.3	30.9	31.2	28.0	24.0	20.1	16.3
	5%	WB	12.7	12.6	13.9	16.6	20.2	24.5	25.9	26.5	23.7	20.7	17.4	13.9
		MCDB	14.1	14.3	16.1	19.9	23.3	27.7	29.5	29.9	26.5	22.9	19.3	15.5
	10%	WB	12.0	11.8	13.1	15.7	19.2	23.3	25.0	25.6	22.7	19.8	16.5	13.1
		MCDB	13.5	13.5	15.0	18.7	22.3	26.5	28.5	28.8	25.6	21.9	18.5	14.9
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.6	5.5	6.2	6.8	7.1	7.9	7.9	6.9	5.5	4.2	3.6
		MCDBR	4.6	5.6	7.3	7.8	8.6	8.8	9.5	9.3	8.6	7.0	4.9	4.2
		MCWBR	3.9	4.2	4.9	5.3	5.2	6.4	6.0	5.7	4.9	4.4	3.7	3.5
	5% WB	MCDBR	3.9	4.8	6.5	6.8	7.4	7.8	8.5	8.3	7.4	6.2	4.4	3.7
MCWBR		3.8	4.1	5.0	5.5	5.6	6.5	6.4	6.2	5.3	4.8	4.1	3.9	
Clear-Sky Solar Irradiance	taub	0.337	0.358	0.394	0.435	0.430	0.425	0.424	0.424	0.416	0.387	0.367	0.340	
	taud	2.494	2.421	2.319	2.211	2.279	2.337	2.352	2.354	2.370	2.437	2.431	2.484	
	Ebn at Noon	821	851	854	840	851	853	851	841	822	807	772	783	
	Edh at Noon	77	95	116	138	132	125	122	119	110	92	81	72	
All-Sky Solar Radiation	RadAvg	1.86	2.71	4.03	5.40	6.66	7.58	7.62	6.69	4.94	3.44	2.15	1.68	
	RadStd	0.17	0.30	0.45	0.37	0.39	0.29	0.36	0.38	0.18	0.30	0.18	0.17	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	-76	+135	+70	

Nomenclature: See separate page