

BRINDISI, Italy

WMO: 163200

Lat: 40.6578N

Lon: 17.9517E

Elev: 47

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.4	39.6	22.7	17.1	45.2	26.6	20.6	45.4	31.1	50.6	28.0	50.2	8.2	230	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	91.3	74.9	88.1	75.8	86.1	75.7	80.8	85.9	79.3	84.6	78.0	83.3	10.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.4	84.9	77.4	142.7	83.4	76.0	136.3	82.2	44.5	86.6	42.9	85.3	41.4	83.4	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.0	23.3	20.8	DB	32.7	99.1	2.3	5.2	31.1	102.9	29.8	105.9	28.5	108.9	26.8	112.7	
			WB	29.8	83.2	1.9	2.5	28.4	85.0	27.3	86.4	26.2	87.8	24.9	89.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.2	49.9	50.4	53.9	58.4	65.9	73.7	78.4	78.9	72.5	65.4	58.4	52.1
	DBStd	11.26	4.53	4.85	4.46	4.14	4.50	4.75	3.72	3.48	4.63	4.51	5.01	4.71
	HDD50	159	58	49	16	1	0	0	0	0	0	0	4	31
	HDD65	2123	469	408	345	200	44	2	0	0	3	49	203	400
	CDD50	4990	53	61	136	255	492	712	881	896	675	477	256	96
	CDD65	1481	0	0	1	3	71	264	416	431	228	61	6	0
	CDH74	11609	0	0	1	9	281	1801	3946	4153	1281	133	4	0
	CDH80	3251	0	0	0	0	43	448	1216	1275	259	10	0	0
Wind	WSAvg	9.1	9.5	10.5	9.6	9.0	8.5	8.5	8.9	8.5	8.4	8.3	9.1	10.0
Precipitation	PrecAvg	23.7	2.6	2.6	2.7	1.7	1.2	0.7	0.5	1.0	2.1	2.9	3.0	2.8
	PrecMax	35.2	5.6	6.7	7.3	4.7	3.1	2.8	2.0	4.1	6.7	6.9	10.8	7.2
	PrecMin	11.5	0.4	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.3	0.1
	PrecStd	5.2	1.5	1.7	1.9	1.0	0.8	0.7	0.5	1.2	1.7	1.9	2.4	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	66.6	70.1	75.1	84.5	92.8	96.8	95.1	90.2	80.9	73.7	66.3
		MCWB	58.5	59.9	58.3	61.4	67.2	71.2	73.5	74.9	75.0	69.7	65.6	60.6
	2%	DB	61.1	62.8	66.1	71.2	79.9	87.7	91.3	91.1	85.9	77.2	70.2	63.3
		MCWB	56.4	57.2	57.6	60.9	66.6	72.0	74.4	76.5	74.7	69.6	64.2	59.3
	5%	DB	59.1	60.5	63.3	68.1	77.0	84.4	88.0	88.0	82.5	75.0	68.1	61.2
		MCWB	55.0	55.8	56.9	59.7	65.9	72.0	76.1	77.1	73.1	68.4	63.2	57.4
	10%	DB	57.2	57.9	61.0	65.9	74.4	82.3	85.9	85.9	80.4	73.0	66.1	59.3
		MCWB	53.7	53.8	56.0	58.9	66.1	72.5	76.0	76.9	72.3	67.3	61.9	55.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.1	63.1	62.1	66.3	73.6	79.6	82.8	83.6	80.0	73.4	69.0	62.7
		MCDB	63.0	64.8	66.3	70.4	78.2	83.8	87.2	88.7	86.3	77.2	71.4	65.0
	2%	WB	57.6	58.5	59.7	63.2	70.9	77.6	80.6	81.1	77.4	71.1	66.2	60.1
		MCDB	60.1	61.4	63.2	67.8	75.8	82.5	85.7	86.2	83.1	75.1	69.1	62.6
	5%	WB	55.7	56.1	58.3	61.5	69.0	75.7	79.1	79.7	75.3	69.4	64.0	58.3
		MCDB	58.4	59.3	61.8	65.7	73.8	80.9	84.3	85.0	80.2	73.4	66.9	60.9
	10%	WB	54.0	54.5	56.8	60.1	67.3	74.1	77.7	78.3	73.5	67.7	62.1	56.5
		MCDB	56.8	57.6	60.2	64.1	71.9	79.5	83.1	83.7	78.4	71.8	65.2	59.2
Mean Daily Temperature Range	5% DB	MDBR	10.6	11.1	11.8	12.5	13.1	12.8	12.6	12.4	12.2	11.4	11.2	10.5
		MCDBR	13.3	14.2	15.3	16.3	17.6	17.2	17.5	16.8	15.4	14.0	12.8	12.2
		MCWBR	10.5	10.8	10.7	10.5	10.4	10.4	12.0	12.0	10.8	9.8	9.5	9.8
	5% WB	MCDBR	12.3	13.5	13.4	13.7	14.2	13.5	13.7	13.6	14.0	12.9	11.5	11.2
		MCWBR	10.6	11.2	10.7	10.5	10.7	10.9	11.5	11.4	11.5	10.2	9.7	9.7
Clear-Sky Solar Irradiance	taub	0.345	0.368	0.405	0.450	0.441	0.427	0.422	0.433	0.424	0.400	0.373	0.349	
	taud	2.454	2.367	2.262	2.145	2.233	2.317	2.335	2.305	2.331	2.373	2.405	2.446	
	Ebn at Noon	256	266	267	262	267	270	270	264	258	251	242	244	
	Edh at Noon	25	32	39	47	44	40	39	39	36	31	26	24	
All-Sky Solar Radiation	RadAvg	590	836	1257	1660	2032	2296	2317	2031	1501	1042	671	525	
	RadStd	54	82	121	120	104	105	76	95	89	82	53	64	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (11 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	-121	+166	N/A

Nomenclature: See separate page