

LECCE, Italy

WMO: 163320

Lat: 40.2383N

Lon: 18.1386E

Elev: 156

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.9	33.7	22.7	17.2	38.9	26.5	20.6	38.2	31.3	46.2	27.8	47.3	5.7	320	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.7	96.5	73.7	93.5	73.4	91.3	73.2	79.1	88.3	77.6	87.0	76.3	85.4	10.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.8	140.6	83.5	75.2	132.9	82.0	73.6	125.9	80.7	42.7	88.1	41.2	86.8	39.8	85.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.9	25.5	21.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	26.2	81.5	3.2	2.3	23.9	83.1	22.1	84.5	20.3	85.7	17.9	87.4	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.1	46.9	48.4	52.7	57.8	64.5	74.9	78.4	79.1	71.9	65.1	56.5	48.6
	DBStd	12.48	5.49	5.69	4.68	4.61	5.48	5.27	3.85	3.91	4.36	4.98	5.83	5.22
	HDD50	340	126	87	27	1	0	0	0	0	0	0	9	90
	HDD65	2539	563	465	380	220	75	2	0	0	3	59	264	508
	CDD50	4772	28	42	112	236	450	746	881	901	658	468	203	47
	CDD65	1495	0	0	0	5	60	298	416	436	211	62	7	0
	CDH74	15615	0	0	0	62	592	3286	4852	4987	1586	240	10	0
	CDH80	6896	0	0	0	8	138	1456	2370	2483	421	20	0	0
(14) Wind	WSAvg	8.4	7.7	9.9	9.6	8.9	8.4	8.3	9.0	8.0	7.3	7.0	8.4	8.3
(15) Precipitation	PrecAvg	26.1	3.0	2.1	2.8	2.0	1.1	0.8	0.7	1.3	2.3	3.2	3.5	3.3
	PrecMax	44.6	9.4	4.8	6.6	10.8	3.5	3.4	4.5	3.7	7.7	7.2	11.0	8.1
	PrecMin	11.5	0.2	0.4	0.4	0.2	0.0	0.0	0.0	0.6	0.2	0.1	0.1	1.5
	PrecStd	8.5	2.1	1.1	1.8	2.3	0.9	1.0	1.1	1.2	2.0	2.2	3.1	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.8	65.8	70.1	80.5	88.0	98.5	100.4	100.5	90.5	82.3	75.4	64.6
		MCWB	57.9	59.3	59.2	64.8	67.0	71.5	70.9	76.2	73.1	68.9	66.5	60.3
	2%	DB	59.5	62.5	66.8	75.0	84.0	94.6	96.3	96.5	87.4	78.7	71.4	62.6
		MCWB	56.0	57.1	58.2	62.1	67.3	71.8	72.4	76.0	73.3	69.1	67.6	59.5
	5%	DB	58.2	60.3	64.5	71.5	80.5	91.0	93.4	93.4	84.6	76.7	68.4	60.6
		MCWB	55.1	55.9	56.6	60.7	66.5	71.3	72.5	74.9	72.1	69.3	64.0	57.2
	10%	DB	56.5	58.6	62.3	68.2	77.0	87.7	91.0	91.3	82.5	74.5	66.3	58.7
		MCWB	53.6	54.7	56.1	59.4	64.5	70.3	72.7	74.6	71.4	68.3	62.6	55.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	60.9	62.5	66.9	74.0	78.3	79.3	81.9	78.9	75.1	69.9	61.7
		MCDB	61.3	63.7	67.0	76.0	82.0	88.4	89.3	90.9	85.0	78.0	72.6	63.9
	2%	WB	57.4	58.6	60.2	64.3	70.5	76.3	77.8	79.9	76.9	72.5	67.7	59.8
		MCDB	59.0	61.3	64.1	72.4	78.6	86.4	87.7	89.2	83.6	76.1	70.5	62.0
	5%	WB	55.8	56.8	58.4	62.2	68.6	74.5	76.5	78.4	75.2	70.6	65.3	58.0
		MCDB	57.8	59.5	62.1	68.7	76.3	84.8	86.5	88.1	81.2	74.8	68.1	60.1
	10%	WB	54.0	55.1	56.9	60.4	66.4	72.8	75.1	77.0	73.6	68.9	63.0	55.7
		MCDB	56.2	57.8	60.8	66.5	74.2	82.9	85.0	86.5	79.2	73.0	66.0	58.0
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	15.7	17.0	18.2	20.1	22.2	21.7	22.7	19.4	16.6	15.2	14.8
		MCDBR	15.9	17.1	19.9	24.3	25.1	27.2	27.7	26.9	21.6	18.1	16.0	15.3
	5% WB	MCWBR	13.0	12.8	13.2	14.2	11.9	10.8	11.0	11.5	11.3	11.1	11.6	12.2
		MCDWR	13.9	14.3	17.0	20.8	21.5	22.7	22.2	22.7	19.1	15.9	14.4	13.6
(40) Clear-Sky Solar Irradiance	taub		0.343	0.365	0.402	0.446	0.437	0.423	0.418	0.430	0.422	0.398	0.371	0.348
		taud	2.461	2.379	2.274	2.154	2.243	2.325	2.345	2.313	2.336	2.380	2.413	2.453
	Ebn at Noon		258	267	268	263	268	272	272	265	259	252	244	246
		Edh at Noon	25	31	39	47	43	40	39	39	36	31	26	24
(44) All-Sky Solar Radiation	RadAvg		604	856	1278	1680	2053	2321	2332	2046	1526	1060	686	540
	RadStd		53	82	117	121	94	102	77	89	87	88	54	67

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	-148	+229	N/A

Nomenclature: See separate page