

MONTE SCURO, Italy

WMO: 163440

Lat: 39.331N

Lon: 16.396E

Elev: 5502

StdP: 12.00

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.1	19.5	-7.7	4.5	41.5	2.1	7.5	39.5	40.9	30.1	34.4	28.5	13.1	70	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.3	76.6	58.6	73.5	58.4	71.4	58.0	64.7	69.6	62.8	68.3	61.2	67.3	6.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	106.0	66.8	60.9	98.3	65.6	59.0	91.7	64.1	33.0	70.1	31.4	67.7	30.1	66.8	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.5	27.8	22.3	DB	13.3	80.8	4.1	4.2	10.3	83.8	7.9	86.3	5.7	88.7	2.7	91.8	(4)
(5)			WB	12.0	68.4	3.4	2.7	9.6	70.3	7.6	71.9	5.7	73.4	3.3	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.5	32.2	32.5	36.6	41.8	50.3	57.9	62.2	62.9	54.4	49.7	41.6	34.7	
	DBStd	12.70	6.59	6.76	7.36	7.24	7.13	6.84	5.59	5.56	6.05	6.35	6.85	6.46	
	HDD50	2664	551	492	419	261	87	14	0	1	22	81	262	474	
	HDD65	6853	1016	911	881	695	458	226	123	105	323	474	702	939	
	CDD50	1377	0	0	2	17	95	251	377	400	153	72	10	0	
	CDD65	93	0	0	0	0	1	14	35	39	4	0	0	0	
	CDH74	220	0	0	0	0	2	21	78	114	4	1	0	0	
	CDH80	25	0	0	0	0	0	1	7	17	0	0	0	0	
Wind	WSAvg	8.6	10.6	10.6	10.9	9.0	8.1	7.0	6.4	6.0	7.2	7.6	9.2	10.7	
Precipitation	PrecAvg	36.2	5.1	3.6	3.6	2.8	2.1	1.2	0.9	1.0	3.0	3.9	5.0	5.1	
	PrecMax	59.5	14.0	8.3	10.4	6.1	4.4	3.6	2.9	3.5	5.6	7.9	10.4	10.0	
	PrecMin	20.6	0.8	0.1	0.0	1.3	0.4	0.0	0.0	0.0	0.9	0.3	1.7	0.2	
	PrecStd	10.2	3.6	2.5	2.6	1.5	1.3	1.1	0.8	1.0	1.5	2.1	2.1	2.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.5	54.0	57.3	64.6	71.7	76.8	80.4	82.3	73.4	68.2	61.1	53.6	
		MCWB	39.3	39.1	43.8	48.9	54.4	59.3	59.4	60.1	56.7	52.6	46.1	41.7	
	2%	DB	46.6	48.7	52.6	59.3	67.7	73.1	75.6	77.0	69.0	63.1	55.8	49.2	
		MCWB	36.6	37.2	41.6	47.1	53.0	58.5	58.9	59.1	55.9	50.4	45.2	40.6	
	5%	DB	43.5	45.0	49.9	55.7	64.2	70.1	73.3	73.6	66.1	60.5	52.8	45.9	
		MCWB	35.8	36.0	40.7	45.6	52.7	58.6	59.2	58.2	55.4	50.3	44.1	40.0	
	10%	DB	40.9	41.3	46.7	52.2	60.9	68.0	71.2	71.3	62.9	57.5	50.0	42.9	
		MCWB	36.0	35.6	39.1	43.4	50.9	57.4	58.7	57.6	54.1	49.8	43.0	38.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.9	43.5	47.9	54.0	60.3	66.8	67.5	66.5	61.9	57.4	51.9	46.5
			MCDB	46.3	47.2	51.7	58.5	65.3	70.5	71.3	70.7	66.2	61.4	53.8	48.2
2%		WB	40.7	40.9	44.9	49.8	56.9	63.3	65.0	63.9	59.6	55.0	48.7	43.9	
		MCDB	42.9	44.4	49.6	56.0	63.0	68.5	69.6	69.4	64.5	58.5	51.2	46.2	
5%		WB	38.8	38.6	42.7	47.2	54.7	61.2	62.9	62.3	57.7	53.2	46.9	41.4	
		MCDB	41.2	42.3	47.3	53.2	60.9	67.1	68.5	68.2	62.3	56.7	49.6	43.5	
10%		WB	37.0	36.9	40.6	44.9	52.6	59.2	61.1	60.8	56.1	51.7	45.2	39.5	
		MCDB	39.1	39.6	44.9	50.0	58.7	65.6	67.4	67.5	60.4	55.2	48.1	41.2	
Mean Daily Temperature Range		5% DB	MDBR	7.5	8.3	9.5	10.6	11.7	12.1	12.8	12.3	10.0	9.4	8.1	7.0
			MCDBR	11.9	13.8	13.1	14.6	14.9	13.4	14.6	15.6	12.8	12.9	11.2	9.9
	MCWBR		9.5	11.1	10.7	12.5	13.0	13.8	12.7	12.0	11.8	11.9	9.7	9.7	
	5% WB	MCDBR	9.7	10.9	12.0	13.0	13.5	12.1	12.0	12.3	10.6	10.2	8.8	8.4	
		MCWBR	9.1	10.0	10.8	12.4	13.1	13.9	13.1	12.3	11.3	11.3	9.5	9.2	
Clear-Sky Solar Irradiance	taub	0.273	0.288	0.315	0.344	0.342	0.333	0.331	0.335	0.334	0.314	0.295	0.277		
	taud	2.590	2.541	2.469	2.388	2.425	2.473	2.486	2.469	2.485	2.537	2.571	2.591		
	Ebn at Noon	292	300	300	295	297	298	298	295	289	285	279	281		
	Edh at Noon	22	27	32	37	36	35	34	34	31	26	23	21		
All-Sky Solar Radiation	RadAvg	628	853	1262	1628	1967	2238	2301	2049	1501	1066	706	563		
	RadStd	66	85	117	121	106	128	100	108	78	92	62	67		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.90	+1.98	N/A	N/A	N/A	+1.78	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page