

MONTE SCURO, Italy

WMO: 163440

Lat: 39.331N

Lon: 16.396E

Elev: 1677

StdP: 82.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.9	-6.9	-22.0	0.6	5.3	-16.6	1.1	4.2	18.3	-1.1	15.4	-1.9	5.9	70	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	24.8	14.8	23.1	14.7	21.9	14.5	18.1	20.9	17.1	20.2	16.2	19.6	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	15.1	19.3	16.1	14.0	18.7	15.0	13.1	17.8	58.8	21.2	55.2	19.8	52.1	19.3	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	14.5	12.4	10.0	DB	-10.4	27.1	2.3	2.4	-12.0	28.8	-13.4	30.2	-14.6	31.5	-16.3	33.2
(5)				WB	-11.1	20.2	1.9	1.5	-12.4	21.3	-13.5	22.2	-14.6	23.0	-15.9	24.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	0.1	0.3	2.5	5.5	10.1	14.4	16.8	17.2	12.4	9.8	5.3	1.5	(6)
(7)		DBStd	7.05	3.66	3.76	4.09	4.02	3.96	3.80	3.11	3.09	3.36	3.53	3.81	3.59	(7)
(8)		HDD10.0	1480	306	273	233	145	48	8	0	1	12	45	146	263	(8)
(9)		HDD18.3	3807	564	506	489	386	254	126	68	58	179	263	390	522	(9)
(10)		CDD10.0	765	0	0	1	9	53	139	209	222	85	40	6	0	(10)
(11)		CDD18.3	52	0	0	0	0	1	8	19	22	2	0	0	0	(11)
(12)		CDH23.3	122	0	0	0	0	1	12	43	63	2	1	0	0	(12)
(13)		CDH26.7	14	0	0	0	0	0	1	4	9	0	0	0	0	(13)
(14)	Wind	WSAvg	3.8	4.7	4.7	4.9	4.0	3.6	3.1	2.9	2.7	3.2	3.4	4.1	4.8	(14)
(15)	Precipitation	PrecAvg	919	130	92	91	71	54	31	24	25	75	98	128	130	(15)
(16)		PrecMax	1511	356	211	265	156	113	92	73	89	142	200	263	255	(16)
(17)		PrecMin	524	20	3	0	32	9	0	0	0	22	7	44	5	(17)
(18)		PrecStd	260	92	64	65	37	32	28	21	26	37	54	54	69	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	12.2	14.1	18.1	22.1	24.9	26.9	27.9	23.0	20.1	16.2	12.0	(19)
(20)		MCWB	4.1	3.9	6.6	9.4	12.5	15.1	15.2	15.6	13.7	11.4	7.8	5.4	(20)	
(21)		2%	DB	8.1	9.3	11.4	15.1	19.8	22.8	24.2	25.0	20.5	17.3	13.2	9.6	(21)
(22)		MCWB	2.5	2.9	5.3	8.4	11.7	14.7	14.9	15.0	13.3	10.2	7.4	4.8	(22)	
(23)		5%	DB	6.4	7.2	10.0	13.2	17.9	21.2	23.0	23.1	18.9	15.8	11.5	7.7	(23)
(24)		MCWB	2.1	2.2	4.8	7.5	11.5	14.8	15.1	14.6	13.0	10.2	6.7	4.5	(24)	
(25)		10%	DB	4.9	5.1	8.2	11.2	16.0	20.0	21.8	21.8	17.1	14.2	10.0	6.0	(25)
(26)		MCWB	2.2	2.0	4.0	6.3	10.5	14.1	14.8	14.2	12.3	9.9	6.1	3.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.4	8.8	12.2	15.7	19.3	19.7	19.2	16.6	14.1	11.1	8.0	(27)
(28)		MCDWB	7.9	8.4	11.0	14.7	18.5	21.4	21.9	21.5	19.0	16.4	12.1	9.0	(28)	
(29)		2%	WB	4.8	4.9	7.2	9.9	13.9	17.4	18.3	17.7	15.3	12.8	9.3	6.6	(29)
(30)		MCDWB	6.0	6.9	9.8	13.3	17.2	20.3	20.9	20.8	18.0	14.7	10.7	7.9	(30)	
(31)		5%	WB	3.8	3.7	6.0	8.5	12.6	16.2	17.2	16.8	14.3	11.8	8.3	5.2	(31)
(32)		MCDWB	5.1	5.7	8.5	11.8	16.0	19.5	20.3	20.1	16.8	13.7	9.8	6.4	(32)	
(33)		10%	WB	2.8	2.7	4.8	7.2	11.4	15.1	16.1	16.0	13.4	11.0	7.3	4.2	(33)
(34)		MCDWB	4.0	4.2	7.2	10.0	14.8	18.7	19.6	19.7	15.8	12.9	8.9	5.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.2	4.6	5.3	5.9	6.5	6.7	7.1	6.8	5.6	5.2	4.5	3.9	(35)	
(36)		5% DB	MCDBR	6.6	7.7	7.3	8.1	8.3	7.5	8.1	8.7	7.1	7.2	6.2	5.5	(36)
(37)		MCWBR	5.3	6.2	6.0	7.0	7.2	7.7	7.0	6.7	6.6	6.6	5.4	5.4	(37)	
(38)		5% WB	MCDBR	5.4	6.1	6.7	7.2	7.5	6.7	6.6	6.8	5.9	5.7	4.9	4.7	(38)
(39)		MCWBR	5.1	5.6	6.0	6.9	7.3	7.7	7.3	6.8	6.3	6.3	5.3	5.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.273	0.288	0.315	0.344	0.342	0.333	0.331	0.335	0.334	0.314	0.295	0.277	(40)	
(41)		taud	2.590	2.541	2.469	2.388	2.425	2.473	2.486	2.469	2.485	2.537	2.571	2.591	(41)	
(42)		Ebn at Noon	920	946	946	931	935	940	939	929	912	900	881	887	(42)	
(43)		Edh at Noon	70	84	100	116	114	109	107	106	98	83	71	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.98	2.69	3.98	5.13	6.20	7.05	7.25	6.46	4.73	3.36	2.23	1.77	(44)	
(45)		RadStd	0.21	0.27	0.37	0.38	0.33	0.40	0.32	0.34	0.25	0.29	0.20	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.50	+1.10	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page