

LAMEZIA TERME, Italy

WMO: 163620

Lat: 38.905N

Lon: 16.242E

Elev: 12

StdP: 101.18

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	2.3	-6.8	2.1	5.4	-4.1	2.7	6.5	13.8	13.0	12.4	13.1	2.6	90	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	31.8	23.0	30.2	24.0	29.2	23.9	26.5	28.8	25.8	28.4	25.1	27.9	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.3	28.0	25.0	20.1	27.6	24.1	19.0	27.1	82.7	28.8	79.5	28.7	76.4	27.9	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	10.0	8.7	-2.5	35.6	1.5	2.1	-3.6	37.1	-4.5	38.4	-5.4	39.6	-6.5	41.1
			-3.6	27.7	1.5	1.2	-4.7	28.6	-5.6	29.3	-6.5	30.0	-7.6	30.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	10.1	10.0	11.8	14.3	18.1	21.8	24.3	24.8	21.8	18.5	14.6	11.3	(6)
	DBStd	5.82	2.71	2.71	2.52	2.39	2.48	2.44	1.85	1.73	2.38	2.51	2.91	2.79	(7)
	HDD10.0	97	32	31	11	2	0	0	0	0	0	0	3	19	(8)
	HDD18.3	1216	256	233	204	122	35	2	0	0	2	28	114	219	(9)
	CDD10.0	2584	34	31	66	131	250	354	443	458	353	263	142	58	(10)
	CDD18.3	661	0	0	0	2	27	107	185	199	106	33	3	0	(11)
	CDH23.3	5244	0	0	4	14	133	719	1663	1889	711	108	3	0	(12)
	CDH26.7	1294	0	0	1	1	29	162	404	551	137	9	0	0	(13)
(14) Wind	WSAvg	3.8	4.1	4.1	4.3	4.4	4.0	3.5	3.5	3.3	3.5	3.5	3.9	4.0	(14)
(15) Precipitation	PrecAvg	961	119	102	81	68	48	27	21	29	75	106	132	154	(15)
	PrecMax	1341	196	353	143	125	95	116	78	90	150	299	223	380	(16)
	PrecMin	622	54	26	15	38	10	5	3	5	22	20	39	43	(17)
	PrecStd	182	42	69	38	23	26	24	19	28	33	65	46	75	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	18.8	22.5	25.2	30.1	33.8	34.3	32.0	27.8	23.5	19.9		(19)
		MCWB	13.7	13.5	15.1	16.2	19.6	21.8	22.5	23.9	22.6	20.3	17.8	15.6	(20)
	2%	DB	16.2	16.8	18.8	22.1	26.4	30.1	31.0	31.8	29.8	25.6	22.0	18.0	(21)
		MCWB	13.3	13.1	14.0	15.1	18.7	22.0	24.2	23.6	22.8	20.1	18.1	14.4	(22)
	5%	DB	15.4	15.4	17.1	20.2	24.3	28.2	29.8	30.1	28.1	24.3	20.9	17.0	(23)
		MCWB	12.8	12.2	13.5	14.9	18.7	22.7	24.2	24.8	22.4	19.8	17.1	13.9	(24)
	10%	DB	14.8	14.8	16.0	18.8	22.9	26.9	28.9	29.2	27.0	23.3	19.8	16.0	(25)
		MCWB	12.3	11.8	12.9	14.6	18.4	22.5	24.0	24.6	22.1	19.2	16.2	13.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	15.0	16.2	18.0	22.0	26.7	27.0	27.6	26.2	22.7	19.9	16.3	(27)
		MCDB	16.7	17.0	19.4	21.3	25.1	28.0	29.0	29.5	28.5	24.7	21.8	18.5	(28)
	2%	WB	14.2	13.9	15.0	16.7	20.8	25.3	26.1	26.6	24.6	21.6	18.6	15.3	(29)
		MCDB	15.9	15.8	17.6	19.7	23.8	27.4	28.6	29.0	27.4	24.0	21.0	17.2	(30)
	5%	WB	13.3	13.0	14.1	15.9	19.8	24.1	25.5	26.1	23.6	20.7	17.6	14.6	(31)
		MCDB	15.1	14.9	16.5	18.7	22.8	26.4	28.1	28.7	26.6	23.5	20.1	16.5	(32)
	10%	WB	12.4	12.2	13.4	15.3	19.0	23.0	24.8	25.4	22.6	19.8	16.5	13.7	(33)
		MCDB	14.4	14.3	15.6	17.8	22.0	25.7	27.6	28.3	25.9	22.7	19.0	15.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	8.1	8.2	8.1	8.4	8.7	8.7	9.1	9.4	9.1	8.4	8.2	(35)
		MCDBR	8.1	8.6	9.8	11.2	11.4	11.5	10.5	10.7	10.6	9.8	9.0	8.9	(36)
	5% WB	MCWBR	6.0	6.0	6.6	6.6	6.4	6.8	6.4	6.7	6.3	6.1	6.1	6.4	(37)
		MCWBR	7.0	7.6	8.4	8.6	9.2	9.0	8.6	9.2	9.3	8.6	7.9	7.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.352	0.375	0.416	0.459	0.455	0.437	0.434	0.441	0.441	0.413	0.382	0.356	(40)
		taud	2.434	2.345	2.222	2.113	2.178	2.278	2.301	2.280	2.273	2.325	2.373	2.427	(41)
	Ebn at Noon		813	839	837	821	832	846	844	829	803	786	766	776	(42)
		Edh at Noon	84	104	130	154	147	133	129	129	122	105	89	80	(43)
(44) All-Sky Solar Radiation	RadAvg		2.03	2.78	4.06	5.27	6.36	7.18	7.36	6.53	4.81	3.42	2.27	1.81	(44)
	RadStd		0.20	0.27	0.36	0.38	0.34	0.41	0.29	0.34	0.25	0.29	0.19	0.19	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	-0.58	-0.99	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.27	N/A	N/A	N/A	-0.41	-0.66	N/A	N/A	N/A	N/A

Nomenclature: See separate page