

USTICA, Italy

WMO: 164000

Lat: 38.7074N

Lon: 13.1779E

Elev: 797

StdP: 14.28

Time Zone: 1.00 (EUC)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.3	44.4	29.9	24.7	47.1	33.1	28.5	47.6	43.5	50.8	37.3	50.5	15.3	330	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	89.0	78.5	86.9	77.7	85.3	77.1	82.0	85.8	80.5	84.7	78.9	83.2	6.7	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	165.6	84.7	79.2	156.3	83.4	77.6	148.1	81.8	46.5	86.1	44.8	84.7	43.1	83.1	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
33.9	29.1	24.9		DB	36.5	93.6	3.0	3.7	34.3	96.3	32.6	98.4	30.9	100.5	28.7	103.3
				WB	34.3	83.8	3.2	2.0	32.0	85.2	30.1	86.3	28.3	87.4	25.9	88.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	53.3	52.3	54.9	58.1	64.2	71.7	78.2	80.4	75.3	70.0	61.8	55.7	(6)
	DBStd	10.43	3.52	3.87	3.77	3.60	4.17	4.00	3.54	3.09	3.38	4.51	4.51	4.22	(7)
	HDD50	48	12	21	8	0	0	0	0	0	0	0	0	7	(8)
	HDD65	1719	362	355	313	210	65	3	0	0	0	0	116	287	(9)
	CDD50	5426	115	86	160	243	441	650	874	942	758	619	353	185	(10)
	CDD65	1624	0	0	1	2	42	204	409	477	309	162	18	0	(11)
	CDH74	10045	0	0	1	3	78	757	3092	4264	1438	410	2	0	(12)
	CDH80	2497	0	0	0	0	5	100	832	1346	177	37	0	0	(13)
(14) Wind	WSAvg	10.7	12.5	13.1	12.0	12.4	9.9	8.4	7.3	6.7	9.7	10.2	13.1	13.0	(14)
(15) Precipitation	PrecAvg	15.7	1.7	1.6	1.3	1.2	0.7	0.4	0.1	0.4	1.4	2.8	2.5	2.6	(15)
	PrecMax	26.2	3.3	3.5	2.6	3.3	1.7	1.6	0.6	2.6	5.2	7.4	5.5	8.5	(16)
	PrecMin	7.2	0.3	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.5	0.4	(17)
	PrecStd	5.0	0.8	1.1	0.7	0.9	0.6	0.4	0.2	0.6	1.4	1.9	1.5	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.4	64.5	66.6	72.5	80.3	86.2	91.5	93.0	86.7	83.8	74.2	66.8	(19)
		MCWB	55.8	56.5	56.7	59.9	63.4	73.4	71.9	78.4	73.7	74.4	67.6	57.9	(20)
	2%	DB	60.3	60.8	64.0	68.2	75.8	82.6	87.9	90.1	83.9	80.5	71.1	64.1	(21)
		MCWB	55.4	56.1	56.6	58.5	65.0	71.9	77.9	79.6	75.2	74.1	65.2	58.2	(22)
	5%	DB	58.9	58.9	61.7	65.6	73.3	80.5	86.2	88.0	82.0	78.1	69.0	61.7	(23)
		MCWB	54.9	54.9	56.0	58.7	65.3	71.5	77.6	78.7	74.6	71.1	64.2	56.9	(24)
	10%	DB	57.5	57.1	60.0	63.6	70.9	78.4	84.5	86.2	80.3	75.9	67.5	60.5	(25)
		MCWB	53.8	53.6	55.2	57.9	64.1	70.8	76.6	78.3	73.7	69.9	63.5	56.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.1	58.9	60.3	63.0	70.7	78.0	83.7	84.5	80.4	78.6	69.1	61.0	(27)
		MCDB	60.6	61.9	64.1	67.6	74.2	82.0	86.3	89.0	83.4	81.9	73.3	64.1	(28)
	2%	WB	56.8	57.0	58.4	61.5	68.6	75.8	81.2	82.7	77.8	75.7	66.5	59.4	(29)
		MCDB	59.1	59.9	62.0	65.6	72.4	79.9	85.2	86.7	81.5	79.2	69.6	61.8	(30)
	5%	WB	55.6	55.5	57.0	60.2	66.8	73.8	79.6	81.4	76.4	73.0	65.2	58.2	(31)
		MCDB	57.7	58.1	60.3	63.8	70.7	78.1	84.1	85.4	79.9	76.2	68.0	60.7	(32)
	10%	WB	54.6	54.2	55.7	58.8	65.1	72.3	78.2	80.0	75.1	71.2	64.0	57.1	(33)
		MCDB	56.9	56.6	58.8	62.2	69.0	76.3	82.6	84.3	78.5	74.5	66.7	59.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	8.6	8.9	9.9	11.0	11.7	11.7	9.7	7.9	6.5	6.5	(35)
		MCDBR	7.9	8.9	10.6	11.1	11.7	13.0	13.0	13.2	11.3	9.5	7.2	8.1	(36)
	5% WB	MCWBR	6.2	6.8	8.3	8.6	8.3	9.9	9.3	9.3	7.3	7.9	6.5	5.8	(37)
		MCWBR	6.8	8.3	9.5	9.9	10.7	11.7	12.3	12.1	10.1	8.4	6.7	7.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.335	0.354	0.389	0.424	0.428	0.409	0.411	0.411	0.416	0.392	0.363	0.341	(40)
		taud	2.502	2.435	2.336	2.249	2.280	2.376	2.385	2.384	2.374	2.416	2.444	2.482	(41)
	Ebn at Noon		266	275	275	271	272	276	274	272	263	258	252	254	(42)
		Edh at Noon	25	30	37	43	42	38	38	37	35	30	26	24	(43)
(44) All-Sky Solar Radiation	RadAvg		674	946	1374	1777	2141	2386	2400	2101	1576	1145	778	601	(44)
	RadStd		49	88	118	96	111	67	57	102	70	79	48	50	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	-1.15	-1.37	N/A	N/A	N/A	N/A

Nomenclature: See separate page