

USTICA, Italy

WMO: 164000

Lat: 38.7074N

Lon: 13.1779E

Elev: 243

StdP: 98.44

Time Zone: 1.00 (EUC)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.7	6.9	-1.1	3.5	8.4	0.6	4.1	8.7	19.5	10.4	16.7	10.3	6.8	330	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	31.6	25.8	30.5	25.4	29.6	25.1	27.8	29.9	26.9	29.3	26.1	28.5	3.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.7	29.3	26.2	22.3	28.5	25.4	21.2	27.7	90.2	30.1	86.3	29.3	82.3	28.4	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.0	11.1	2.5	34.2	1.7	2.1	1.3	35.7	0.3	36.9	-0.6	38.1	-1.8	39.6		
(5)			1.3	28.8	1.8	1.1	0.0	29.5	-1.1	30.2	-2.1	30.8	-3.4	31.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	11.9	11.3	12.7	14.5	17.9	22.0	25.7	26.9	24.0	21.1	16.5	13.2	(6)
(7)		DBStd	5.80	1.96	2.15	2.09	2.00	2.32	2.22	1.96	1.72	1.88	2.50	2.50	2.35	(7)
(8)		HDD10.0	27	7	12	4	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD18.3	955	201	197	174	117	36	2	0	0	4	64	159		(9)
(10)		CDD10.0	3014	64	48	89	135	245	361	486	523	421	344	196	103	(10)
(11)		CDD18.3	902	0	0	1	1	23	113	227	265	172	90	10	0	(11)
(12)		CDH23.3	5581	0	0	1	2	43	421	1718	2369	799	228	1	0	(12)
(13)		CDH26.7	1387	0	0	0	0	3	56	462	748	98	21	0	0	(13)
(14)	Wind	WSAvg	4.8	5.6	5.9	5.3	5.6	4.4	3.7	3.3	3.0	4.4	5.9	5.8	(14)	
(15)	Precipitation	PrecAvg	400	42	41	33	30	17	9	2	11	36	71	63	66	(15)
(16)		PrecMax	665	84	90	65	85	44	41	16	67	131	189	139	217	(16)
(17)		PrecMin	184	7	2	1	4	1	0	0	0	2	13	11		(17)
(18)		PrecStd	126	21	28	19	24	15	11	5	15	36	49	37	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	18.1	19.2	22.5	26.8	30.1	33.1	33.9	30.4	28.8	23.4	19.3	(19)
(20)			MCWB	13.2	13.6	13.7	15.5	17.5	23.0	22.2	25.8	23.2	23.5	19.8	14.4	(20)
(21)		2%	DB	15.7	16.0	17.8	20.1	24.3	28.1	31.0	32.3	28.8	26.9	21.7	17.8	(21)
(22)			MCWB	13.0	13.4	13.7	14.7	18.4	22.2	25.5	26.4	24.0	23.4	18.5	14.5	(22)
(23)		5%	DB	14.9	14.9	16.5	18.6	23.0	26.9	30.1	31.1	27.8	25.6	20.6	16.5	(23)
(24)			MCWB	12.7	12.7	13.3	14.8	18.5	21.9	25.3	26.0	23.7	21.7	17.9	13.8	(24)
(25)		10%	DB	14.2	14.0	15.5	17.6	21.6	25.8	29.2	30.1	26.9	24.4	19.7	15.8	(25)
(26)			MCWB	12.1	12.0	12.9	14.4	17.9	21.5	24.8	25.7	23.2	21.1	17.5	13.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	14.9	15.7	17.2	21.5	25.6	28.7	29.2	26.9	25.9	20.6	16.1	(27)
(28)			MADB	15.9	16.6	17.8	19.8	23.5	27.8	30.2	31.7	28.6	27.7	22.9	17.8	(28)
(29)		2%	WB	13.8	13.9	14.6	16.4	20.3	24.4	27.3	28.2	25.5	24.3	19.2	15.2	(29)
(30)			MADB	15.0	15.5	16.7	18.7	22.4	26.6	29.5	30.4	27.5	26.2	20.9	16.6	(30)
(31)		5%	WB	13.1	13.1	13.9	15.7	19.3	23.2	26.4	27.4	24.7	22.8	18.4	14.5	(31)
(32)			MADB	14.3	14.5	15.7	17.7	21.5	25.6	28.9	29.7	26.6	24.6	20.0	15.9	(32)
(33)		10%	WB	12.6	12.3	13.2	14.9	18.4	22.4	25.7	26.7	24.0	21.8	17.8	13.9	(33)
(34)			MADB	13.8	13.7	14.9	16.8	20.6	24.6	28.1	29.1	25.8	23.6	19.3	15.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.7	4.2	4.8	5.0	5.5	6.1	6.5	5.4	4.4	3.6	3.6	(35)	
(36)			MCDBR	4.4	4.9	5.9	6.2	6.5	7.2	7.2	7.3	6.3	5.3	4.0	4.5	(36)
(37)			MCWBR	3.4	3.8	4.6	4.8	4.6	5.5	5.1	5.1	4.1	4.4	3.6	3.2	(37)
(38)		5% WB	MCDDBR	3.8	4.6	5.3	5.5	6.0	6.5	6.8	6.7	5.6	4.7	3.7	4.0	(38)
(39)			MCWBR	3.3	3.7	4.3	4.8	4.8	5.7	5.4	5.5	4.5	4.5	3.6	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.354	0.389	0.424	0.428	0.409	0.411	0.411	0.416	0.392	0.363	0.341	(40)	
(41)		taud	2.502	2.435	2.336	2.249	2.280	2.376	2.385	2.384	2.374	2.416	2.444	2.482	(41)	
(42)		Ebn at Noon	840	868	868	855	856	870	865	857	830	813	794	801	(42)	
(43)		Edh at Noon	79	95	116	134	133	121	119	116	111	96	83	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.13	2.98	4.33	5.60	6.75	7.52	7.57	6.62	4.97	3.61	2.45	1.89	(44)	
(45)		RadStd	0.15	0.28	0.37	0.30	0.35	0.21	0.18	0.32	0.22	0.25	0.15	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	-0.64	-0.76	N/A	N/A	N/A	N/A

Nomenclature: See separate page