

REGGIO CALABRIA, Italy

WMO: 164220

Lat: 38.071N

Lon: 15.652E

Elev: 96

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	42.4	44.3	24.6	18.8	48.6	28.6	22.6	50.2	31.3	56.9	27.1	56.0	7.8	50	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	94.6	71.5	91.5	71.9	89.3	72.0	79.8	84.8	77.7	84.2	76.0	83.8	14.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	149.4	83.5	75.6	134.4	81.5	73.5	125.1	81.2	43.5	85.5	41.2	83.3	39.5	83.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	21.9	20.0	DB	37.0	100.2	2.1	4.0	35.5	103.1	34.2	105.4	33.0	107.7	31.5	110.6	(4)
(5)			WB	33.4	81.3	2.3	4.0	31.7	84.2	30.4	86.5	29.1	88.7	27.5	91.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	53.6	53.4	56.7	61.7	68.1	76.3	82.2	81.9	75.8	69.4	62.6	56.4	(6)
(7)		DBStd	11.01	4.08	4.25	3.93	3.60	4.45	5.44	3.72	3.31	4.15	3.91	4.24	4.23	(7)
(8)		HDD50	33	13	13	2	0	0	0	0	0	0	0	0	5	(8)
(9)		HDD65	1439	354	325	257	111	18	1	0	0	0	11	95	267	(9)
(10)		CDD50	6091	125	109	211	351	560	790	997	989	774	603	377	205	(10)
(11)		CDD65	2018	0	0	0	11	114	340	532	524	324	149	22	2	(11)
(12)		CDH74	16915	0	0	1	27	397	2638	5633	5531	2217	441	28	2	(12)
(13)		CDH80	5926	0	0	0	1	69	876	2265	2138	546	30	1	0	(13)
(14)	Wind	WSAvg	10.1	9.4	10.0	10.5	10.5	11.2	11.5	12.2	11.1	8.9	8.2	8.4	8.8	(14)
(15)	Precipitation	PrecAvg	27.8	3.5	2.7	2.5	2.1	1.1	0.6	0.5	0.7	2.9	3.5	3.7	3.8	(15)
(16)		PrecMax	48.3	8.1	5.2	6.1	4.4	2.8	3.3	1.7	3.5	7.0	11.4	10.5	8.1	(16)
(17)		PrecMin	18.4	1.2	0.4	0.0	0.4	0.0	0.0	0.0	0.0	0.6	0.3	1.1	0.9	(17)
(18)		PrecStd	6.7	1.8	1.4	1.6	1.1	0.8	0.7	0.5	0.9	1.4	2.6	2.1	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.6	67.9	71.3	77.2	86.2	97.2	100.1	98.2	91.8	83.9	77.4	71.5	(19)
(20)			MCWB	56.3	56.8	56.4	60.0	66.1	71.3	73.3	71.8	71.1	67.6	66.3	59.2	(20)
(21)		2%	DB	64.2	64.3	68.0	73.2	81.1	91.7	94.6	93.3	87.8	80.3	73.7	66.6	(21)
(22)			MCWB	55.8	55.0	55.6	58.5	63.9	70.7	71.7	71.3	71.5	68.2	64.3	58.4	(22)
(23)		5%	DB	62.2	62.3	65.8	70.1	78.5	87.9	91.6	91.0	84.6	78.5	71.6	64.7	(23)
(24)			MCWB	55.0	54.4	55.1	58.1	63.7	71.1	72.6	72.0	71.2	67.5	63.5	57.1	(24)
(25)		10%	DB	60.5	60.6	63.0	68.2	75.5	84.5	89.3	88.2	82.7	76.7	69.8	63.0	(25)
(26)			MCWB	53.8	53.8	54.8	58.0	63.0	69.3	72.4	72.5	70.9	67.4	62.4	56.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.1	58.9	59.9	63.8	71.5	80.2	84.0	82.0	79.9	74.0	69.2	62.0	(27)
(28)			MCD B	63.9	64.0	65.2	69.6	76.5	85.7	89.0	85.8	83.6	77.4	73.6	66.7	(28)
(29)		2%	WB	57.3	57.1	58.4	62.1	69.1	76.8	80.4	79.1	76.7	71.5	66.6	60.1	(29)
(30)			MCD B	62.4	61.7	63.8	67.7	75.1	84.0	85.7	84.3	81.5	76.4	71.6	65.0	(30)
(31)		5%	WB	55.6	55.6	57.1	60.9	67.1	74.3	77.8	77.3	74.6	69.7	64.8	58.7	(31)
(32)			MCD B	60.7	60.9	62.4	66.5	73.9	82.3	84.7	84.6	81.1	75.4	70.4	64.3	(32)
(33)		10%	WB	54.3	54.1	55.9	59.7	65.2	71.9	75.8	75.7	72.8	68.3	63.1	57.0	(33)
(34)			MCD B	59.4	59.7	61.5	65.4	72.9	80.8	84.3	84.1	80.3	74.5	68.6	62.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.5	11.5	12.1	13.0	13.8	14.0	14.1	13.9	13.1	12.6	11.8	10.7	(35)
(36)			MCD BR	11.4	12.6	14.3	15.3	16.8	17.6	16.9	16.0	14.8	14.2	12.8	12.0	(36)
(37)			MCWBR	8.0	8.5	8.4	8.5	8.8	10.1	10.8	10.9	10.1	9.4	8.7	8.4	(37)
(38)		5% WB	MCD BR	10.9	11.9	12.9	13.0	14.0	15.1	14.4	14.3	13.6	13.0	11.6	11.2	(38)
(39)			MCWBR	8.5	8.8	9.2	8.9	9.9	11.1	11.6	12.5	11.2	9.7	9.3	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.374	0.416	0.449	0.448	0.431	0.429	0.436	0.440	0.418	0.383	0.357	(40)	
(41)		taud	2.447	2.364	2.237	2.163	2.214	2.303	2.327	2.308	2.298	2.321	2.386	2.435	(41)	
(42)		Ebn at Noon	260	269	267	264	266	270	270	265	256	249	245	249	(42)	
(43)		Edh at Noon	27	33	41	47	45	41	40	40	38	34	28	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	688	940	1352	1736	2084	2319	2372	2095	1551	1120	764	609	(44)	
(45)		RadStd	56	78	102	115	109	115	71	103	78	85	58	49	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	-0.63	N/A	N/A	N/A	N/A	

Nomenclature: See separate page