

REGGIO CALABRIA, Italy

WMO: 164220

Lat: 38.071N

Lon: 15.652E

Elev: 29

StdP: 100.97

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.8	6.8	-4.1	2.7	9.2	-1.9	3.2	10.1	14.0	13.8	12.1	13.3	3.5	50	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	34.8	21.9	33.0	22.2	31.9	22.2	26.6	29.3	25.4	29.0	24.5	28.8	6.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.3	28.6	24.2	19.2	27.5	23.1	17.9	27.3	83.4	29.7	78.0	28.5	74.0	28.9	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.8	8.9	2.8	37.9	1.2	2.2	1.9	39.5	1.2	40.8	0.6	42.1	-0.3	43.7		
(5)			0.8	27.4	1.3	2.2	-0.2	29.0	-0.9	30.3	-1.6	31.5	-2.5	33.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	12.0	11.9	13.7	16.5	20.0	24.6	27.9	27.7	24.3	20.8	17.0	13.6	(6)
(7)		DBStd	6.12	2.26	2.36	2.18	2.00	2.47	3.02	2.06	1.84	2.30	2.17	2.36	2.35	(7)
(8)		HDD10.0	18	7	7	1	0	0	0	0	0	0	0	0	3	(8)
(9)		HDD18.3	799	197	181	143	62	10	1	0	0	0	6	53	148	(9)
(10)		CDD10.0	3384	69	61	117	195	311	439	554	549	430	335	209	114	(10)
(11)		CDD18.3	1121	0	0	0	6	63	189	296	291	180	83	12	1	(11)
(12)		CDH23.3	9397	0	0	1	15	221	1466	3129	3073	1232	245	16	1	(12)
(13)	CDH26.7	3292	0	0	0	1	38	487	1258	1188	303	17	1	0	(13)	
(14)	Wind	WSAvg	4.5	4.2	4.5	4.7	4.7	5.0	5.1	5.4	4.9	4.0	3.7	3.8	3.9	(14)
(15)	Precipitation	PrecAvg	707	89	68	64	54	27	16	13	18	74	90	95	96	(15)
(16)		PrecMax	1227	205	133	156	112	70	84	43	88	178	289	266	205	(16)
(17)		PrecMin	468	31	10	1	9	1	0	0	0	14	8	28	24	(17)
(18)		PrecStd	170	45	36	40	28	20	19	13	23	36	67	53	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	19.9	21.8	25.1	30.1	36.2	37.8	36.8	33.2	28.8	25.2	22.0	(19)
(20)			MCWB	13.5	13.8	13.5	15.6	19.0	21.8	22.9	22.1	21.7	19.8	19.1	15.1	(20)
(21)		2%	DB	17.9	17.9	20.0	22.9	27.3	33.2	34.8	34.0	31.0	26.8	23.2	19.2	(21)
(22)			MCWB	13.2	12.8	13.1	14.7	17.7	21.5	22.1	21.8	21.9	20.1	17.9	14.7	(22)
(23)		5%	DB	16.8	16.8	18.8	21.2	25.8	31.1	33.1	32.8	29.2	25.8	22.0	18.2	(23)
(24)			MCWB	12.8	12.4	12.8	14.5	17.6	21.7	22.6	22.2	21.8	19.7	17.5	14.0	(24)
(25)		10%	DB	15.8	15.9	17.2	20.1	24.1	29.2	31.9	31.2	28.2	24.8	21.0	17.2	(25)
(26)			MCWB	12.1	12.1	12.6	14.4	17.2	20.7	22.4	22.5	21.6	19.7	16.9	13.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.0	15.5	17.7	21.9	26.8	28.9	27.8	26.6	23.3	20.7	16.7	(27)
(28)			MADB	17.7	17.8	18.5	20.9	24.7	29.9	31.7	29.9	28.7	25.2	23.1	19.3	(28)
(29)		2%	WB	14.0	14.0	14.7	16.7	20.6	24.9	26.9	26.2	24.9	21.9	19.2	15.6	(29)
(30)			MADB	16.9	16.5	17.7	19.8	23.9	28.9	29.8	29.0	27.5	24.7	22.0	18.3	(30)
(31)		5%	WB	13.1	13.1	13.9	16.0	19.5	23.5	25.4	25.1	23.7	21.0	18.2	14.9	(31)
(32)			MADB	15.9	16.0	16.9	19.2	23.3	27.9	29.3	29.2	27.3	24.1	21.3	17.9	(32)
(33)		10%	WB	12.4	12.3	13.3	15.4	18.4	22.2	24.3	24.3	22.7	20.2	17.3	13.9	(33)
(34)			MADB	15.2	15.4	16.4	18.6	22.7	27.1	29.1	28.9	26.8	23.6	20.3	16.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.8	6.4	6.7	7.2	7.7	7.8	7.7	7.3	7.0	6.5	5.9	(35)	
(36)			MCDBR	6.3	7.0	8.0	8.5	9.3	9.8	9.4	8.9	8.2	7.9	7.1	6.6	(36)
(37)			MCWBR	4.4	4.7	4.6	4.7	4.9	5.6	6.0	6.1	5.6	5.2	4.8	4.6	(37)
(38)		5% WB	MADB	6.0	6.6	7.2	7.2	7.8	8.4	8.0	7.9	7.6	7.2	6.4	6.2	(38)
(39)			MCWBR	4.7	4.9	5.1	5.0	5.5	6.2	6.5	6.9	6.2	5.4	5.2	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.374	0.416	0.449	0.448	0.431	0.429	0.436	0.440	0.418	0.383	0.357	(40)	
(41)		taud	2.447	2.364	2.237	2.163	2.214	2.303	2.327	2.308	2.298	2.321	2.386	2.435	(41)	
(42)		Ebn at Noon	821	847	841	833	839	851	850	836	808	786	773	784	(42)	
(43)		Edh at Noon	84	103	129	147	142	130	126	126	120	107	89	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.17	2.96	4.26	5.47	6.57	7.31	7.48	6.60	4.89	3.53	2.41	1.92	(44)	
(45)		RadStd	0.18	0.25	0.32	0.36	0.36	0.34	0.36	0.22	0.33	0.25	0.27	0.18	0.15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.35	N/A	N/A	N/A	N/A

Nomenclature: See separate page