

PANTELLERIA, Italy

WMO: 164700

Lat: 36.814N

Lon: 11.971E

Elev: 198

StdP: 98.97

Time Zone: 1.00 (EUC)

Period: 86-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.9	7.9	-2.3	3.2	15.7	-0.1	3.8	13.3	19.6	11.2	17.0	11.1	6.4	250	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	34.2	20.9	32.0	20.4	30.2	21.0	26.6	28.7	25.6	27.7	24.8	27.0	5.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.9	28.0	24.9	20.5	27.2	24.0	19.4	26.3	84.3	28.6	79.8	27.6	76.1	27.2	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.4	13.4	11.7	DB	5.4	37.4	2.0	2.6	3.9	39.3	2.8	40.8	1.7	42.2	0.2	44.1	(4)
(5)			WB	2.9	28.5	1.6	1.4	1.8	29.5	0.9	30.4	0.0	31.2	-1.1	32.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	12.2	12.0	13.3	15.3	18.8	22.7	25.4	26.1	24.0	21.4	16.8	13.3	(6)	
	DBStd	5.66	1.85	2.02	2.55	2.29	3.35	3.34	2.65	1.97	2.18	2.27	2.38	2.30	(7)	
	HDD10.0	16	4	6	4	0	0	0	0	0	0	0	0	3	(8)	
	HDD18.3	872	191	177	158	97	32	2	0	0	0	2	57	156	(9)	
	CDD10.0	3111	72	61	106	158	273	380	477	500	419	354	205	106	(10)	
	CDD18.3	926	0	0	2	5	46	132	219	242	169	98	12	1	(11)	
	CDH23.3	6140	0	0	3	21	284	885	1737	2034	905	263	8	0	(12)	
	CDH26.7	1738	0	0	0	3	104	314	557	558	177	26	0	0	(13)	
(14) Wind	WSAvg	5.2	5.5	5.8	6.0	6.0	5.3	4.4	4.3	4.5	4.6	4.9	5.3	5.8	(14)	
(15) Precipitation	PrecAvg	591	89	61	51	38	16	8	3	6	73	79	83	92	(15)	
	PrecMax	1284	285	173	150	138	56	100	38	40	455	198	280	258	(16)	
	PrecMin	278	15	0	0	0	0	0	0	0	2	4	9	8	(17)	
	PrecStd	187	73	44	41	29	14	20	8	10	92	44	51	61	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	19.8	23.2	26.0	33.7	37.5	37.7	35.9	33.2	29.6	24.4	20.9	(19)	
		MCWB	11.6	11.7	12.8	16.0	21.6	22.9	22.8	21.6	19.6	19.9	16.7	15.6	(20)	
	2%	DB	16.5	17.1	20.1	22.8	30.0	33.0	34.2	32.9	30.1	27.1	22.5	19.2	(21)	
		MCWB	12.5	12.2	12.0	14.7	17.9	20.3	20.4	21.1	20.7	20.0	18.0	15.7	(22)	
	5%	DB	15.2	15.6	18.1	20.6	26.2	29.9	31.7	31.0	28.3	25.8	21.1	17.8	(23)	
		MCWB	12.5	12.6	12.0	14.2	17.1	18.7	21.0	21.8	22.1	20.5	17.5	15.0	(24)	
	10%	DB	14.4	14.5	16.5	18.9	23.9	28.0	29.8	29.6	27.1	24.8	20.1	16.2	(25)	
		MCWB	12.2	12.3	12.6	14.0	16.5	18.9	21.8	22.5	22.1	20.6	17.1	14.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	14.8	16.0	18.2	23.1	24.9	28.2	28.2	26.1	24.6	21.1	17.6	(27)	
		MCDB	15.9	16.4	18.1	21.9	29.2	28.1	29.8	30.2	27.8	26.3	22.5	19.6	(28)	
	2%	WB	13.8	13.8	14.7	16.9	21.0	23.5	26.6	26.7	25.1	23.0	19.2	16.1	(29)	
		MCDB	15.3	15.7	16.9	19.8	24.5	26.9	28.7	28.8	27.1	24.8	20.8	18.2	(30)	
	5%	WB	13.1	13.1	14.0	15.9	19.5	22.5	25.5	25.7	24.1	22.2	18.4	15.2	(31)	
		MCDB	14.6	14.8	16.0	18.5	23.5	25.9	27.7	27.7	26.3	24.3	20.2	16.9	(32)	
	10%	WB	12.5	12.5	13.3	15.1	18.3	21.6	24.5	25.0	23.3	21.5	17.5	14.4	(33)	
		MCDB	14.1	14.1	15.2	17.5	21.7	24.8	26.9	27.1	25.5	23.8	19.5	16.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.2	3.6	4.2	5.0	5.6	6.1	5.5	5.2	4.9	4.5	3.6	3.2	(35)	
		MCDBR	4.4	5.0	6.9	8.3	9.3	9.6	8.6	8.0	6.9	6.1	4.5	4.4	(36)	
	5% WB	MCWBR	3.9	3.8	5.2	6.2	5.9	6.2	7.2	7.1	6.4	5.3	4.2	4.1	(37)	
		MCWBR	3.8	4.0	4.8	6.4	7.6	7.1	5.8	5.8	5.2	4.0	3.4	3.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.362	0.408	0.448	0.455	0.426	0.440	0.437	0.439	0.413	0.377	0.351	(40)	
		taud	2.483	2.414	2.266	2.168	2.190	2.319	2.287	2.308	2.301	2.341	2.404	2.456	(41)	
	Ebn at Noon		843	868	854	837	835	857	842	838	814	799	792	806	(42)	
		Edh at Noon	83	100	126	147	146	128	132	126	121	106	89	81	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.40	3.29	4.62	5.88	6.92	7.66	7.73	6.85	5.15	3.84	2.71	2.16	(44)	
	RadStd		0.17	0.26	0.32	0.32	0.36	0.29	0.17	0.24	0.23	0.22	0.13	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page