

LAMPEDUSA, Italy

WMO: 164900

Lat: 35.498N

Lon: 12.618E

Elev: 70

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	47.6	49.8	30.8	25.0	50.7	34.1	28.8	52.3	36.6	53.0	33.2	55.0	13.9	300	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	89.7	79.1	87.6	78.2	85.9	78.0	81.8	85.8	80.4	84.8	79.4	83.8	8.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	159.8	85.0	79.1	151.4	83.8	78.1	146.1	83.0	45.5	86.3	44.1	85.4	43.0	84.0	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
30.1	26.7	23.4	DB	45.7	93.3	3.0	2.5	43.5	95.1	41.8	96.6	40.1	98.0	37.9	99.8
			WB	40.9	83.2	2.5	1.8	39.2	84.5	37.7	85.5	36.4	86.5	34.6	87.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.9	57.2	56.4	58.2	61.8	67.3	74.3	79.9	81.2	78.1	73.8	66.3	60.0	(6)
	DBStd	9.52	3.00	3.66	2.88	2.59	3.69	4.42	3.19	2.90	3.36	3.67	3.93	3.93	(7)
	HDD50	5	1	3	0	0	0	0	0	0	0	0	0	1	(8)
	HDD65	996	243	240	212	99	13	0	0	0	0	1	28	160	(9)
	CDD50	6552	223	183	254	354	537	729	928	968	842	736	488	310	(10)
	CDD65	2069	0	0	0	3	85	279	463	503	392	273	66	5	(11)
	CDH74	15268	1	0	0	1	160	1431	4327	5180	3032	1070	66	0	(12)
	CDH80	3568	0	0	0	0	19	311	1159	1490	533	56	0	0	(13)
(14) Wind	WSAvg	11.0	13.1	12.4	11.9	12.0	11.2	9.3	9.1	8.6	9.0	10.5	12.1	13.5	(14)
(15) Precipitation	PrecAvg	10.6	1.6	1.3	0.9	0.6	0.3	0.1	0.0	0.1	0.6	2.2	1.4	2.0	(15)
	PrecMax	18.6	6.1	4.8	3.8	1.6	1.2	1.2	0.1	1.5	2.4	8.2	4.8	6.9	(16)
	PrecMin	4.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	(17)
	PrecStd	4.3	1.5	1.3	0.9	0.4	0.3	0.3	0.0	0.3	0.7	1.9	1.3	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.5	65.4	66.6	71.4	84.4	91.4	91.8	93.0	89.2	83.7	78.7	69.8	(19)
		MCWB	59.5	59.1	60.5	61.2	72.9	75.7	78.5	82.3	76.6	77.6	71.0	65.0	(20)
	2%	DB	63.4	64.1	64.8	68.2	79.0	86.1	89.5	89.6	86.1	81.2	75.8	68.1	(21)
		MCWB	58.4	58.7	59.4	61.8	69.5	75.3	78.9	80.7	79.4	75.8	70.1	63.2	(22)
	5%	DB	62.5	62.7	64.0	66.8	75.4	82.8	87.4	87.6	84.4	80.2	73.7	66.6	(23)
		MCWB	57.6	57.9	58.9	61.2	67.4	73.4	77.5	79.1	78.2	74.6	67.8	62.0	(24)
	10%	DB	61.1	61.4	62.6	66.0	73.2	80.6	85.5	86.0	82.7	78.8	71.8	65.7	(25)
		MCWB	56.4	56.7	58.1	60.9	66.3	73.0	77.3	78.4	76.6	73.1	66.1	61.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	60.9	62.3	64.8	73.9	79.7	82.6	85.7	82.6	78.9	73.8	65.9	(27)
		MCDB	63.9	63.9	65.2	68.2	82.0	87.0	87.5	90.1	85.2	82.1	76.6	68.3	(28)
	2%	WB	59.6	59.6	60.9	63.4	71.2	77.2	81.0	82.5	80.3	77.3	70.9	64.6	(29)
		MCDB	62.6	62.8	63.9	66.9	77.7	83.0	86.0	86.4	83.9	80.5	74.9	67.3	(30)
	5%	WB	58.5	58.5	59.7	62.3	68.9	75.7	79.7	81.0	79.1	75.9	68.9	63.2	(31)
		MCDB	61.7	61.8	62.6	65.8	73.8	80.7	84.7	85.1	83.0	78.9	73.1	66.2	(32)
	10%	WB	57.2	57.3	58.9	61.4	67.2	74.2	78.5	79.8	78.0	74.4	67.2	61.6	(33)
		MCDB	60.6	60.8	61.7	64.8	71.8	79.1	83.5	84.1	82.0	77.6	71.1	65.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.4	6.7	7.1	7.9	8.4	8.7	8.0	7.5	7.0	6.4	5.9	(35)
		MCDBR	6.8	6.9	8.0	8.2	11.0	11.4	11.1	9.9	8.4	7.6	7.3	6.3	(36)
	5% WB	MCWBR	5.5	5.3	5.8	5.6	6.4	7.2	7.7	6.6	5.8	5.6	5.8	5.4	(37)
		MCWBR	6.0	5.9	7.2	7.3	9.4	9.6	8.9	8.4	8.0	6.5	6.1	5.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.346	0.364	0.417	0.460	0.464	0.436	0.448	0.447	0.453	0.420	0.381	0.356	(40)
		taud	2.492	2.429	2.251	2.142	2.172	2.299	2.277	2.294	2.280	2.341	2.416	2.461	(41)
	Ebn at Noon		270	277	270	263	263	270	266	264	256	253	253	257	(42)
		Edh at Noon	27	32	41	48	47	42	42	41	40	34	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		865	1147	1572	1963	2288	2482	2499	2224	1727	1285	948	759	(44)
	RadStd		58	81	80	103	104	99	45	77	61	65	47	54	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	+0.40	N/A	N/A	N/A	-0.68	-0.77	N/A	N/A	+158	+85

Nomenclature: See separate page