

LAMPEDUSA, Italy

WMO: 164900

Lat: 35.498N

Lon: 12.618E

Elev: 21

StdP: 101.07

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.7	9.9	-0.7	3.6	10.4	1.2	4.1	11.3	16.4	11.7	14.8	12.8	6.2	300	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	32.1	26.2	30.9	25.6	29.9	25.5	27.7	29.9	26.9	29.4	26.3	28.8	3.8	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.8	29.5	26.2	21.6	28.8	25.6	20.9	28.4	88.0	30.1	84.7	29.7	82.1	28.9	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	11.9	10.5	7.6	34.1	1.7	1.4	6.4	35.1	5.4	35.9	4.5	36.7	3.3	37.7		
(5)			5.0	28.4	1.4	1.0	4.0	29.1	3.2	29.7	2.4	30.3	1.4	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	14.0	13.6	14.5	16.6	19.6	23.5	26.6	27.3	25.6	23.2	19.0	15.5	(6)
(7)		DBStd	5.29	1.67	2.03	1.60	1.44	2.05	2.46	1.77	1.61	1.87	2.04	2.18	2.19	(7)
(8)		HDD10.0	3	1	2	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	553	135	133	118	55	7	0	0	0	0	1	16	89	(9)
(10)		CDD10.0	3640	124	102	141	197	298	405	516	538	468	409	271	172	(10)
(11)		CDD18.3	1149	0	0	0	2	47	155	257	279	218	152	37	3	(11)
(12)		CDH23.3	8482	1	0	0	1	89	795	2404	2878	1684	594	37	0	(12)
(13)		CDH26.7	1982	0	0	0	0	11	173	644	828	296	31	0	0	(13)
(14)	Wind	WSAvg	4.9	5.9	5.5	5.3	5.4	5.0	4.1	4.0	3.9	4.0	4.7	5.4	6.0	(14)
(15)	Precipitation	PrecAvg	270	41	32	23	15	7	3	0	3	16	56	35	50	(15)
(16)		PrecMax	473	155	123	97	41	31	31	3	37	60	208	122	176	(16)
(17)		PrecMin	104	4	0	1	0	0	0	0	0	0	3	0	1	(17)
(18)		PrecStd	109	37	32	23	11	8	7	1	8	19	49	32	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.6	18.6	19.2	21.9	29.1	33.0	33.2	33.9	31.8	28.7	26.0	21.0	(19)
(20)			MCWB	15.3	15.1	15.8	16.2	22.7	24.3	25.8	28.0	24.8	25.3	21.7	18.4	(20)
(21)		2%	DB	17.5	17.8	18.2	20.1	26.1	30.1	32.0	32.0	30.1	27.4	24.3	20.1	(21)
(22)			MCWB	14.7	14.8	15.2	16.6	20.8	24.1	26.1	27.0	26.3	24.3	21.2	17.3	(22)
(23)		5%	DB	16.9	17.1	17.8	19.4	24.1	28.2	30.8	30.9	29.1	26.8	23.2	19.2	(23)
(24)			MCWB	14.2	14.4	14.9	16.2	19.7	23.0	25.3	26.2	25.7	23.7	19.9	16.7	(24)
(25)		10%	DB	16.2	16.3	17.0	18.9	22.9	27.0	29.7	30.0	28.2	26.0	22.1	18.7	(25)
(26)			MCWB	13.5	13.7	14.5	16.0	19.1	22.8	25.2	25.8	24.8	22.9	18.9	16.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.1	16.8	18.2	23.3	26.5	28.1	29.8	28.1	26.1	23.2	18.8	(27)
(28)			MCDB	17.7	17.7	18.5	20.1	27.8	30.6	30.8	32.3	29.5	27.8	24.8	20.2	(28)
(29)		2%	WB	15.3	15.3	16.1	17.5	21.8	25.1	27.2	28.1	26.9	25.2	21.6	18.1	(29)
(30)			MCDB	17.0	17.1	17.7	19.4	25.4	28.3	30.0	30.2	28.8	27.0	23.8	19.6	(30)
(31)		5%	WB	14.7	14.7	15.4	16.8	20.5	24.3	26.5	27.2	26.2	24.4	20.5	17.4	(31)
(32)			MCDB	16.5	16.6	17.0	18.8	23.2	27.1	29.3	29.5	28.3	26.1	22.9	19.0	(32)
(33)		10%	WB	14.0	14.0	14.9	16.3	19.6	23.4	25.9	26.6	25.6	23.5	19.5	16.5	(33)
(34)			MCDB	15.9	16.0	16.5	18.2	22.1	26.1	28.6	28.9	27.8	25.4	21.7	18.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.3	3.6	3.7	3.9	4.4	4.7	4.8	4.5	4.2	3.9	3.6	3.3	(35)
(36)			MCDBR	3.8	3.8	4.4	4.5	6.1	6.3	6.2	5.5	4.7	4.2	4.0	3.5	(36)
(37)			MCWBR	3.1	2.9	3.2	3.1	3.6	4.0	4.3	3.6	3.2	3.1	3.2	3.0	(37)
(38)		5% WB	MCDBR	3.3	3.3	4.0	4.1	5.2	5.3	4.9	4.7	4.5	3.6	3.4	3.0	(38)
(39)			MCWBR	3.2	2.9	3.3	3.0	3.5	3.9	3.8	3.6	3.5	3.1	3.2	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.364	0.417	0.460	0.464	0.436	0.448	0.447	0.453	0.420	0.381	0.356	(40)	
(41)		taud	2.492	2.429	2.251	2.142	2.172	2.299	2.277	2.294	2.280	2.341	2.416	2.461	(41)	
(42)		Ebn at Noon	851	874	850	830	829	850	837	831	806	799	799	811	(42)	
(43)		Edh at Noon	84	100	130	152	149	131	133	129	125	108	91	83	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.73	3.62	4.96	6.19	7.21	7.82	7.88	7.01	5.44	4.05	2.99	2.39	(44)	
(45)		RadStd	0.18	0.26	0.25	0.32	0.33	0.31	0.14	0.24	0.19	0.20	0.15	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.22	N/A	N/A	N/A	-0.38	-0.43	N/A	N/A	+88	+47

Nomenclature: See separate page