

ALGHERO, Italy

WMO: 165200

Lat: 40.632N

Lon: 8.291E

Elev: 27

StdP: 101.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.3	1.9	-2.9	3.0	4.4	-1.2	3.4	4.6	11.2	12.7	10.3	12.9	1.1	20	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	34.9	21.4	33.1	21.7	31.7	21.6	25.0	29.2	24.1	28.7	23.4	28.1	4.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	18.8	26.8	22.9	17.7	26.3	22.0	16.7	25.8	76.2	29.0	72.6	28.7	69.8	28.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.8	8.5	7.4	-1.9	38.3	1.1	1.3	-2.7	39.2	-3.3	40.0	-3.9	40.7	-4.7	41.7
			-2.5	26.1	1.1	1.3	-3.3	27.0	-4.0	27.8	-4.6	28.5	-5.5	29.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	9.8	9.6	11.4	13.9	17.7	21.8	24.6	24.8	21.4	18.4	14.1	11.0
	DBStd	6.01	2.66	2.58	2.47	2.24	2.63	2.86	2.30	2.37	2.49	2.65	2.91	2.81
	HDD10.0	112	37	35	14	1	0	0	0	0	0	0	4	22
	HDD18.3	1296	265	244	214	133	43	4	0	0	4	32	129	227
	CDD10.0	2521	30	24	58	118	239	355	453	459	343	259	128	53
	CDD18.3	662	0	0	0	1	24	109	194	201	97	33	2	0
	CDH23.3	6366	0	0	1	18	255	1059	2034	2088	717	188	4	0
	CDH26.7	2517	0	0	0	3	61	402	902	934	184	31	0	0
Wind	WSAvg	3.0	3.2	3.2	3.4	3.4	3.1	3.0	2.9	2.7	2.8	2.7	3.1	3.2
Precipitation	PrecAvg	583	62	62	52	43	29	11	1	6	40	73	116	87
	PrecMax	831	132	160	113	90	139	41	9	50	138	225	370	181
	PrecMin	390	0	1	0	8	0	0	0	0	0	1	0	26
	PrecStd	146	36	40	30	25	33	10	2	11	37	58	100	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	18.2	21.8	25.3	31.1	35.2	36.4	37.9	32.8	29.9	23.8	19.1
		MCWB	13.8	13.3	14.5	16.5	18.9	20.3	21.3	21.3	21.1	19.5	17.1	14.7
	2%	DB	16.2	16.2	19.1	22.9	28.1	33.0	34.6	35.1	30.2	27.1	22.1	17.8
		MCWB	13.4	12.5	13.5	15.6	18.3	20.7	21.4	21.9	21.2	19.7	16.9	14.5
	5%	DB	15.2	15.2	17.8	21.0	26.1	31.0	33.0	33.1	28.9	25.2	20.8	16.9
		MCWB	12.7	12.2	13.2	15.2	17.8	20.5	21.9	22.1	21.1	19.4	16.6	14.0
	10%	DB	14.5	14.3	16.4	19.2	24.1	29.0	31.2	31.2	27.2	23.9	19.2	15.9
		MCWB	12.0	11.7	12.9	14.6	17.1	20.5	21.9	22.3	20.7	18.8	15.9	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	14.5	15.9	18.0	20.9	24.0	25.7	26.7	25.0	22.4	19.3	16.2
		MCDB	16.5	16.4	19.1	22.6	26.4	28.8	30.0	29.7	27.4	25.2	21.3	17.6
	2%	WB	14.2	13.7	14.9	16.9	19.7	22.9	24.7	25.4	23.6	21.2	18.1	15.2
		MCDB	15.7	15.5	17.6	21.0	24.9	28.0	29.5	29.4	26.7	24.4	20.5	16.9
	5%	WB	13.2	13.0	14.1	16.0	18.9	22.1	23.9	24.4	22.6	20.4	17.0	14.5
		MCDB	14.9	14.9	16.6	19.3	23.7	27.2	28.8	29.0	26.3	23.8	19.8	16.3
	10%	WB	12.4	12.2	13.4	15.2	18.2	21.3	23.2	23.6	21.7	19.5	16.1	13.7
		MCDB	14.3	14.2	15.8	18.3	22.6	26.5	28.2	28.5	25.8	23.0	18.9	15.6
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.8	9.6	9.9	10.9	11.7	12.0	12.4	10.7	10.3	8.8	8.2
		MCDBR	8.2	9.7	12.0	13.8	15.1	15.3	15.3	15.7	12.7	12.0	10.6	8.6
		MCWBR	6.4	7.0	7.7	8.0	7.1	5.8	5.8	6.1	6.0	6.2	6.5	6.3
	5% WB	MCDBR	7.2	8.0	9.6	11.2	12.4	12.6	12.4	12.7	10.6	10.3	8.9	7.5
		MCWBR	6.1	6.4	6.9	7.3	6.8	6.2	6.0	6.5	6.1	6.3	6.3	6.1
Clear-Sky Solar Irradiance	taub	0.340	0.359	0.389	0.421	0.435	0.419	0.425	0.419	0.415	0.395	0.372	0.344	
	taud	2.465	2.399	2.327	2.244	2.246	2.336	2.327	2.352	2.356	2.385	2.386	2.440	
	Ebn at Noon	814	848	859	852	847	859	850	845	822	796	761	773	
	Edh at Noon	79	96	115	134	136	125	125	119	111	97	85	75	
All-Sky Solar Radiation	RadAvg	1.88	2.76	4.18	5.40	6.50	7.55	7.62	6.58	4.94	3.46	2.13	1.68	
	RadStd	0.17	0.28	0.38	0.37	0.54	0.27	0.25	0.34	0.17	0.27	0.16	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	+0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page