

CAPO BELLAVISTA, Italy

WMO: 165500

Lat: 39.930N

Lon: 9.713E

Elev: 492

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	40.6	42.5	21.0	16.1	50.1	24.7	19.1	49.9	42.2	49.9	36.3	49.4	15.3	300	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.5	91.2	76.6	89.1	76.1	86.9	75.3	81.3	87.2	79.7	85.6	78.1	84.0	7.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	157.4	85.3	78.0	148.3	83.9	76.3	140.0	82.6	45.4	87.1	43.6	85.7	42.0	84.0	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
33.0	27.5	22.9	DB	36.0	95.9	2.9	3.2	33.9	98.2	32.2	100.0	30.5	101.8	28.4	104.1	
			WB	31.9	84.1	1.9	2.3	30.6	85.7	29.5	87.1	28.4	88.3	27.1	90.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	52.3	52.2	55.4	59.5	65.8	73.7	79.6	80.6	74.0	67.8	59.7	54.3
	DBStd	10.94	4.41	4.59	4.55	4.15	4.36	4.50	3.45	3.55	4.36	4.35	4.75	4.68
	HDD50	82	26	27	9	1	0	0	0	0	0	0	3	16
	HDD65	1786	395	359	298	171	42	2	0	0	1	21	166	331
	CDD50	5435	96	89	178	286	491	712	917	949	720	553	294	150
	CDD65	1663	0	0	2	6	68	264	452	484	271	109	6	1
	CDH74	11443	0	0	3	11	164	1438	3790	4388	1411	232	4	2
	CDH80	3542	0	0	0	1	13	315	1288	1594	313	18	0	0
(14) Wind	WSAvg	9.8	11.2	11.3	11.0	9.8	9.0	7.7	7.7	7.7	9.2	9.6	11.0	11.9
(15) Precipitation	PrecAvg	22.5	2.2	2.0	1.9	2.2	1.3	0.6	0.4	0.7	1.7	2.5	3.1	3.4
	PrecMax	32.6	6.1	4.8	7.0	6.5	2.9	2.3	1.6	2.2	6.8	6.8	9.1	7.6
	PrecMin	15.8	0.7	0.6	0.3	0.7	0.4	0.1	0.0	0.1	0.4	0.2	0.7	0.9
	PrecStd	4.5	1.6	1.2	1.5	1.3	0.6	0.5	0.4	0.6	1.4	1.6	1.8	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	66.4	72.7	75.2	81.6	89.7	93.7	94.7	89.7	82.4	73.6	70.0
		MCWB	55.3	54.3	57.5	62.0	66.0	74.1	77.5	77.8	74.3	70.8	62.0	56.7
	2%	DB	63.0	62.9	67.9	71.0	77.6	86.0	91.0	91.7	86.1	78.9	70.1	64.8
		MCWB	53.8	52.8	56.2	59.9	65.5	73.2	76.3	77.4	73.4	69.7	61.8	56.3
	5%	DB	60.6	60.7	64.6	68.3	75.4	83.5	88.7	89.6	83.5	76.7	68.0	62.6
		MCWB	52.7	52.5	55.9	58.9	64.7	72.4	75.7	76.7	72.4	68.5	60.7	55.3
	10%	DB	58.6	58.8	62.2	66.0	73.1	81.1	86.3	87.6	80.9	74.1	66.1	60.6
		MCWB	51.9	51.7	54.3	58.1	63.6	71.0	75.1	76.4	71.2	67.1	60.3	54.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.1	58.0	61.6	65.7	71.2	79.7	82.7	83.9	80.3	74.4	66.8	60.9
		MCDB	63.3	61.8	67.4	71.0	77.2	85.5	88.6	89.8	84.8	78.6	69.5	65.2
	2%	WB	56.2	55.8	59.1	63.0	68.4	77.0	80.8	81.9	77.4	72.2	64.6	59.0
		MCDB	60.6	59.8	64.3	67.9	74.4	82.6	87.0	87.8	82.3	76.6	67.8	63.0
	5%	WB	54.6	54.3	57.5	61.1	66.8	74.9	79.2	80.4	75.5	70.4	62.7	57.1
		MCDB	58.7	58.6	62.4	65.9	72.8	81.2	85.2	86.2	80.6	74.5	66.3	61.3
	10%	WB	53.0	52.9	55.8	59.3	65.2	73.1	77.5	78.8	73.6	68.8	61.1	55.5
		MCDB	57.1	57.3	60.3	63.7	71.0	79.1	83.5	84.9	78.9	72.7	64.8	59.3
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.3	11.1	11.9	12.8	13.7	14.6	14.5	13.1	11.5	9.4	9.1
		MCDBR	11.5	12.8	14.2	15.3	15.6	15.9	17.1	16.6	16.1	14.1	11.4	11.2
		MCWBR	9.7	10.5	11.1	11.9	12.5	13.4	13.9	13.5	12.6	11.5	10.1	9.7
	5% WB	MCDBR	10.3	11.8	12.7	13.9	13.9	14.4	15.4	15.0	14.3	12.5	10.1	10.1
		MCWBR	9.6	10.5	10.9	12.0	11.9	13.5	13.5	13.4	12.6	11.1	9.9	9.7
(40) Clear-Sky Solar Irradiance	taub		0.324	0.341	0.374	0.409	0.420	0.402	0.410	0.405	0.403	0.383	0.358	0.331
	taud		2.512	2.457	2.375	2.290	2.292	2.381	2.371	2.391	2.396	2.431	2.453	2.494
	Ebn at Noon		267	278	279	275	273	278	274	273	266	259	251	254
	Edh at Noon		24	29	35	41	42	38	38	36	34	30	25	23
(44) All-Sky Solar Radiation	RadAvg		634	912	1298	1684	2033	2340	2386	2084	1547	1101	702	569
(45)	RadStd		66	79	144	127	162	89	87	108	59	85	53	50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.94	N/A	N/A	N/A	N/A

Nomenclature: See separate page