

CAPO BELLAVISTA, Italy

WMO: 165500

Lat: 39.930N

Lon: 9.713E

Elev: 150

StdP: 99.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.8	5.9	-6.1	2.3	10.0	-4.0	2.7	9.9	18.9	9.9	16.2	9.7	6.8	300	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	32.9	24.8	31.7	24.5	30.5	24.1	27.4	30.7	26.5	29.8	25.6	28.9	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.5	29.6	25.6	21.2	28.8	24.6	20.0	28.1	87.8	30.6	83.6	29.8	79.7	28.9	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.7	12.3	10.2	2.2	35.5	1.6	1.8	1.0	36.8	0.1	37.8	-0.8	38.8	-2.0	40.0		
(5)			0.0	29.0	1.0	1.3	-0.8	29.9	-1.4	30.6	-2.0	31.3	-2.7	32.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	11.3	11.2	13.0	15.3	18.8	23.2	26.4	27.0	23.3	19.9	15.4	12.4	(6)
(7)		DBStd	6.08	2.45	2.55	2.53	2.30	2.42	2.50	1.92	1.97	2.42	2.42	2.64	2.60	(7)
(8)		HDD10.0	46	14	15	5	1	0	0	0	0	0	0	2	9	(8)
(9)		HDD18.3	992	219	199	166	95	23	1	0	0	1	12	92	184	(9)
(10)		CDD10.0	3019	53	49	99	159	273	396	509	527	400	307	163	83	(10)
(11)		CDD18.3	924	0	0	1	3	38	147	251	269	151	61	3	1	(11)
(12)		CDH23.3	6357	0	0	2	6	91	799	2106	2438	784	129	2	1	(12)
(13)	CDH26.7	1968	0	0	0	1	7	175	716	886	174	10	0	0	(13)	
(14)	Wind	WSAvg	4.4	5.0	5.1	4.9	4.4	4.0	3.4	3.5	3.4	4.1	4.3	4.9	5.3	(14)
(15)	Precipitation	PrecAvg	572	57	52	49	56	32	15	11	17	42	63	80	86	(15)
(16)		PrecMax	827	155	123	178	164	74	58	41	55	172	172	230	192	(16)
(17)		PrecMin	401	19	14	8	19	10	3	1	2	10	4	17	23	(17)
(18)		PrecStd	115	40	31	38	32	15	13	9	15	35	41	46	52	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	19.1	22.6	24.0	27.5	32.1	34.3	34.8	32.0	28.0	23.1	21.1	(19)
(20)			MCWB	12.9	12.4	14.2	16.7	18.9	23.4	25.3	25.4	23.5	21.5	16.7	13.7	(20)
(21)		2%	DB	17.2	17.2	19.9	21.7	25.4	30.0	32.8	33.2	30.1	26.0	21.2	18.2	(21)
(22)			MCWB	12.1	11.6	13.4	15.5	18.6	22.9	24.6	25.2	23.0	20.9	16.5	13.5	(22)
(23)		5%	DB	15.9	15.9	18.1	20.2	24.1	28.6	31.5	32.0	28.6	24.8	20.0	17.0	(23)
(24)			MCWB	11.5	11.4	13.3	14.9	18.2	22.5	24.3	24.9	22.5	20.3	16.0	13.0	(24)
(25)	10%	DB	14.8	14.9	16.8	18.9	22.8	27.3	30.2	30.9	27.2	23.4	19.0	15.9	(25)	
(26)		MCWB	11.1	11.0	12.4	14.5	17.6	21.7	23.9	24.7	21.8	19.5	15.7	12.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	14.5	16.4	18.7	21.8	26.5	28.2	28.8	26.9	23.6	19.3	16.1	(27)
(28)			MCD B	17.4	16.6	19.7	21.7	25.1	29.7	31.5	32.1	29.4	25.9	20.8	18.4	(28)
(29)		2%	WB	13.4	13.2	15.1	17.2	20.2	25.0	27.1	27.7	25.2	22.4	18.1	15.0	(29)
(30)			MCD B	15.9	15.5	18.0	19.9	23.5	28.1	30.6	31.0	27.9	24.8	19.9	17.2	(30)
(31)		5%	WB	12.6	12.4	14.2	16.2	19.4	23.8	26.2	26.9	24.2	21.4	17.1	14.0	(31)
(32)			MCD B	14.8	14.8	16.9	18.8	22.7	27.3	29.6	30.1	27.0	23.6	19.1	16.3	(32)
(33)	10%	WB	11.7	11.6	13.2	15.2	18.5	22.8	25.3	26.0	23.1	20.4	16.1	13.0	(33)	
(34)		MCD B	14.0	14.0	15.7	17.6	21.6	26.1	28.6	29.4	26.0	22.6	18.2	15.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.2	5.7	6.2	6.6	7.1	7.6	8.1	8.0	7.3	6.4	5.2	5.1	(35)	
(36)		5% DB	MCD BR	6.4	7.1	7.9	8.5	8.6	8.8	9.5	9.2	9.0	7.8	6.3	6.2	(36)
(37)			MCWBR	5.4	5.8	6.2	6.6	6.9	7.4	7.7	7.5	7.0	6.4	5.6	5.4	(37)
(38)		5% WB	MCD BR	5.7	6.5	7.0	7.7	7.7	8.0	8.6	8.3	7.9	7.0	5.6	5.6	(38)
(39)			MCWBR	5.3	5.8	6.1	6.7	6.6	7.5	7.5	7.4	7.0	6.2	5.5	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.324	0.341	0.374	0.409	0.420	0.402	0.410	0.405	0.403	0.383	0.358	0.331	(40)	
(41)		taud	2.512	2.457	2.375	2.290	2.292	2.381	2.371	2.391	2.396	2.431	2.453	2.494	(41)	
(42)		Ebn at Noon	843	876	879	867	861	875	864	860	838	816	790	802	(42)	
(43)		Edh at Noon	76	92	110	128	131	120	120	115	107	93	80	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.00	2.87	4.09	5.31	6.41	7.38	7.52	6.57	4.88	3.47	2.21	1.79	(44)	
(45)		RadStd	0.21	0.25	0.45	0.40	0.51	0.28	0.28	0.34	0.19	0.27	0.17	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.52	N/A	N/A	N/A		

Nomenclature: See separate page