

CAPO CARBONARA, Italy

WMO: 165640

Lat: 39.104N

Lon: 9.514E

Elev: 118

StdP: 99.92

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.0	7.3	-1.2	3.5	8.4	0.8	4.1	9.3	25.5	12.2	23.6	12.0	9.5	290	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	32.1	26.6	31.1	26.1	30.1	25.3	28.0	30.9	27.1	30.2	26.2	29.4	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	23.2	30.7	26.1	21.8	29.9	25.1	20.6	29.1	90.3	31.3	86.2	30.4	82.2	29.9	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	18.8	16.1	3.7	34.4	1.7	1.1	2.5	35.2	1.5	35.9	0.6	36.5	-0.7	37.3		
(5)			1.1	29.8	1.1	0.6	0.3	30.3	-0.4	30.6	-1.0	31.0	-1.8	31.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	12.7	12.0	13.6	16.1	18.9	23.2	26.6	27.3	24.5	21.1	16.7	13.8	(6)
(7)		DBStd	5.70	1.87	2.27	1.98	1.81	2.27	2.04	1.65	1.58	1.96	2.30	2.72	2.32	(7)
(8)		HDD10.0	17	3	8	2	0	0	0	0	0	0	0	0	3	(8)
(9)		HDD18.3	797	175	178	147	71	19	0	0	0	5	61	141	(9)	
(10)		CDD10.0	3266	87	64	113	182	276	395	516	535	434	344	200	121	(10)
(11)		CDD18.3	1004	0	0	0	3	37	145	257	277	184	91	11	1	(11)
(12)		CDH23.3	6792	0	0	0	1	63	683	2288	2572	998	183	3	0	(12)
(13)		CDH26.7	1859	0	0	0	0	5	111	677	864	192	11	0	0	(13)
(14)	Wind	WSAvg	6.9	8.1	8.2	8.3	7.5	6.9	5.9	5.4	4.8	6.0	6.5	7.5	7.9	(14)
(15)	Precipitation	PrecAvg	414	39	38	42	41	27	8	4	8	35	49	67	58	(15)
(16)		PrecMax	729	92	92	111	133	60	36	29	27	74	97	176	148	(16)
(17)		PrecMin	281	14	10	13	12	8	1	0	1	5	15	20	28	(17)
(18)		PrecStd	98	20	21	27	28	13	7	7	8	21	22	35	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	18.8	19.9	22.8	27.1	30.8	33.1	34.0	31.1	28.0	23.8	20.2	(19)
(20)			MCWB	15.0	15.2	16.0	17.2	21.0	24.3	26.5	26.9	25.8	23.5	19.1	16.8	(20)
(21)		2%	DB	16.9	17.1	18.8	21.2	24.9	29.2	31.9	32.8	29.8	26.7	22.0	18.3	(21)
(22)			MCWB	14.3	14.6	15.3	16.9	20.0	23.5	26.3	26.8	24.9	22.3	19.0	15.3	(22)
(23)		5%	DB	16.0	16.0	17.4	20.1	23.8	28.0	30.9	31.6	28.8	25.2	21.0	17.2	(23)
(24)			MCWB	13.5	13.4	14.6	16.3	19.7	23.1	25.9	26.6	23.9	21.0	18.1	14.6	(24)
(25)		10%	DB	15.1	15.0	16.5	19.1	22.6	26.9	30.0	30.6	27.8	24.1	20.0	16.6	(25)
(26)			MCWB	12.9	12.5	14.0	15.8	18.8	22.4	25.3	26.0	23.2	20.5	17.5	14.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	16.4	16.9	19.1	22.7	26.9	28.9	29.6	27.2	25.0	20.6	17.2	(27)
(28)			MCDWB	17.4	17.9	18.9	21.3	25.0	29.5	31.7	32.1	29.9	26.7	22.4	19.7	(28)
(29)		2%	WB	14.7	14.9	15.8	18.0	21.4	25.1	27.7	28.4	25.9	23.2	19.5	16.0	(29)
(30)			MCDWB	16.3	16.8	17.8	20.2	23.9	27.8	30.6	31.2	28.9	25.4	21.3	18.2	(30)
(31)		5%	WB	14.0	13.8	15.1	17.1	20.3	24.0	26.9	27.5	24.9	22.1	18.6	15.1	(31)
(32)			MCDWB	15.6	15.6	17.1	19.4	23.0	26.8	30.0	30.7	27.9	24.8	20.5	17.0	(32)
(33)		10%	WB	13.1	12.9	14.1	16.1	19.1	22.9	26.0	26.6	24.0	21.1	17.7	14.2	(33)
(34)			MCDWB	15.0	14.8	16.1	18.6	21.9	26.1	29.3	30.0	26.8	23.7	19.7	16.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	5.1	5.3	5.7	6.1	6.5	6.8	7.1	6.3	5.6	4.9	4.5	(35)
(36)			MCDBR	5.1	5.8	6.3	6.7	7.2	7.6	7.8	7.8	7.0	6.3	5.7	4.9	(36)
(37)			MCWBR	4.5	5.2	5.6	5.5	6.0	6.8	6.8	7.0	5.8	5.2	4.7	4.2	(37)
(38)		5% WB	MCDWR	5.0	5.6	6.0	6.3	6.4	6.8	7.3	7.2	6.4	6.0	5.2	4.6	(38)
(39)			MCWBR	4.7	5.2	5.5	5.7	6.0	6.7	7.0	7.2	5.8	5.3	4.8	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.351	0.389	0.427	0.440	0.416	0.429	0.421	0.419	0.397	0.369	0.342	(40)	
(41)		taud	2.495	2.441	2.334	2.238	2.239	2.351	2.323	2.352	2.353	2.384	2.419	2.469	(41)	
(42)		Ebn at Noon	836	869	866	851	845	864	848	847	825	804	782	795	(42)	
(43)		Edh at Noon	79	94	116	136	138	124	126	120	113	99	85	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	3.05	4.28	5.51	6.58	7.51	7.60	6.69	5.03	3.65	2.37	1.96	(44)	
(45)		RadStd	0.20	0.24	0.44	0.41	0.46	0.26	0.24	0.30	0.20	0.25	0.16	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.29	N/A	N/A	N/A	-0.50	-0.61	N/A	N/A	N/A	N/A

Nomenclature: See separate page