

KAVALA MEGAS ALEXANDROS, Greece

WMO: 166240

Lat: 40.913N

Lon: 24.619E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.9	(c) -1.2	(d) -10.0	(e) 1.6	(f) 1.0	(g) -7.9	(h) 1.9	(i) 1.9	(j) 10.4	(k) 4.7	(l) 9.1	(m) 5.9	(n) 2.2	(o) 60	(p) 0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.8	(c) 33.0	(d) 21.9	(e) 31.8	(f) 21.8	(g) 30.2	(h) 21.7	(i) 24.2	(j) 29.5	(k) 23.4	(l) 28.8	(m) 22.7	(n) 28.2	(o) 4.0	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	16.9	27.3	21.8	16.4	26.9	20.9	15.6	26.3	72.8	29.5	69.7	29.1	67.2	28.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.4	(b) 7.3	(c) 6.2	(e) -5.8	(f) 35.3	(g) 2.2	(h) 1.5	(i) -7.3	(j) 36.4	(k) -8.6	(l) 37.3	(m) -9.8	(n) 38.1	(o) -11.4	(p) 39.2		
(a) 8.4	(b) 7.3	(c) 6.2	(e) -7.1	(f) 25.6	(g) 2.1	(h) 1.0	(i) -8.6	(j) 26.3	(k) -9.8	(l) 26.8	(m) -11.0	(n) 27.4	(o) -12.5	(p) 28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	5.7	6.7	9.3	13.4	18.5	22.8	25.0	25.1	20.8	15.8	11.4	7.2
	DBStd	7.51	3.39	3.41	3.04	2.74	2.51	2.50	1.82	2.05	2.53	2.99	3.46	3.69
	HDD10.0	422	139	100	49	6	0	0	0	0	0	2	24	102
	HDD18.3	1828	393	327	279	150	29	1	0	0	8	87	209	344
	CDD10.0	2316	4	7	28	107	264	386	466	468	323	181	66	16
	CDD18.3	678	0	0	0	1	35	136	207	210	82	8	0	0
	CDH23.3	5942	0	0	0	6	178	1114	2042	2048	523	30	0	0
	CDH26.7	1931	0	0	0	0	16	308	729	788	90	1	0	0
Wind	WSAvg	2.4	2.4	2.7	2.8	2.5	2.3	2.2	2.2	2.3	2.4	2.3	2.2	2.4
Precipitation	PrecAvg	636	70	63	59	41	42	33	26	19	36	62	77	106
	PrecMax	1160	176	205	206	137	128	95	83	95	132	157	197	233
	PrecMin	346	0	8	4	2	14	7	6	0	0	2	18	28
	PrecStd	197	42	47	42	27	25	22	19	24	32	39	40	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	16.7	19.0	24.0	28.2	33.8	34.1	35.2	30.9	26.0	21.9	18.2
		MCWB	12.7	13.2	12.9	15.5	18.8	22.4	21.8	22.1	21.2	19.8	17.0	15.5
	2%	DB	14.1	15.0	17.1	21.2	26.6	31.2	32.2	33.2	28.9	24.0	20.0	16.1
		MCWB	11.4	11.7	13.0	14.7	18.6	21.8	21.8	21.9	20.6	18.4	16.5	13.8
	5%	DB	12.8	13.8	15.9	20.0	25.1	29.9	31.2	32.0	27.8	22.8	18.2	14.2
		MCWB	10.3	11.0	12.2	14.5	18.1	21.4	21.8	21.8	20.4	17.5	14.8	12.1
	10%	DB	11.0	12.1	14.8	18.8	24.0	28.2	30.1	30.8	26.3	21.2	17.0	13.0
		MCWB	8.8	9.7	11.5	13.7	17.6	20.8	21.8	21.8	19.6	16.5	14.1	10.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	13.9	14.7	17.3	20.9	24.6	24.8	25.6	23.1	21.1	18.0	15.8
		MCDB	15.4	15.8	17.3	22.3	26.0	30.1	30.3	30.3	27.6	24.3	20.8	17.4
	2%	WB	12.1	12.4	13.7	15.9	19.7	23.2	23.9	24.4	22.1	19.5	16.8	14.2
		MCDB	13.9	14.4	16.2	19.7	24.7	28.8	29.4	29.5	26.7	22.6	19.2	15.9
	5%	WB	10.7	11.2	12.7	15.1	19.0	22.3	23.2	23.6	21.3	18.4	15.7	12.7
		MCDB	12.3	13.2	15.2	18.8	23.6	28.0	28.6	28.9	25.8	21.5	17.9	14.1
	10%	WB	9.3	10.2	11.7	14.2	18.2	21.5	22.6	22.8	20.5	17.3	14.7	11.3
		MCDB	10.6	11.7	14.1	17.7	22.7	27.0	28.1	28.3	25.0	20.3	16.5	12.8
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.6	7.8	8.6	9.0	9.4	9.8	10.4	9.7	8.9	8.2	7.4
		MCDBR	9.1	9.2	9.4	10.3	10.6	10.9	11.0	12.0	11.0	10.5	9.5	8.5
		MCWBR	6.8	6.7	6.3	5.6	5.1	5.0	5.0	5.3	5.9	6.1	6.5	6.5
	5% WB	MCDBR	7.9	8.3	8.7	9.2	9.6	10.1	10.0	10.7	10.0	9.6	8.4	7.1
		MCWBR	6.4	6.3	6.1	5.6	5.0	5.1	5.2	5.6	5.8	6.1	6.1	5.8
Clear-Sky Solar Irradiance	taub	0.356	0.388	0.435	0.488	0.471	0.467	0.464	0.472	0.454	0.417	0.387	0.366	
	taud	2.363	2.249	2.130	1.997	2.123	2.179	2.193	2.163	2.183	2.261	2.291	2.319	
	Ebn at Noon	783	807	807	789	814	817	814	795	780	765	733	732	
	Edh at Noon	86	111	140	171	154	146	143	143	131	109	92	84	
All-Sky Solar Radiation	RadAvg	1.74	2.57	3.78	4.99	6.21	6.79	7.09	6.37	4.73	3.17	2.06	1.54	
	RadStd	0.24	0.29	0.33	0.50	0.38	0.48	0.35	0.28	0.32	0.33	0.21	0.25	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-64	-146	+78

Nomenclature: See separate page