

CORFU KERKYRA, Greece

WMO: 166410

Lat: 39.602N

Lon: 19.912E

Elev: 2

StdP: 101.30

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.3	-6.5	2.2	6.8	-3.9	2.7	7.0	12.3	13.4	10.4	13.0	0.7	290	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	35.1	23.6	33.9	23.5	32.5	23.3	26.2	31.7	25.2	30.8	24.4	30.0	3.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	19.7	30.3	23.4	18.2	28.8	22.8	17.5	28.1	81.5	31.6	77.1	30.9	73.6	30.0	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.5	7.4	-1.6	37.8	2.0	2.0	-3.0	39.3	-4.2	40.4	-5.3	41.5	-6.7	43.0
			-2.6	27.3	2.0	1.3	-4.1	28.3	-5.2	29.1	-6.4	29.8	-7.8	30.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	9.8	10.4	12.2	15.2	19.5	23.8	26.5	26.8	22.8	18.9	14.9	11.3
	DBStd	6.51	2.81	2.77	2.54	2.57	2.34	2.70	1.91	1.96	2.37	2.42	3.05	2.90
	HDD10.0	96	38	26	9	1	0	0	0	0	0	3	19	
	HDD18.3	1141	266	223	191	97	14	1	0	1	22	109	218	
	CDD10.0	2917	31	37	77	158	296	416	511	521	384	277	149	59
	CDD18.3	919	0	0	0	4	52	166	252	263	136	41	5	0
	CDH23.3	8667	0	0	0	27	334	1557	2769	2858	962	156	4	0
	CDH26.7	3566	0	0	0	4	52	587	1292	1358	262	11	0	0
Wind	WSAvg	2.3	2.5	2.7	2.6	2.4	2.1	2.1	2.2	2.0	2.1	2.0	2.7	2.6
Precipitation	PrecAvg	1078	132	133	97	61	37	16	9	20	84	134	182	179
	PrecMax	1646	294	304	229	158	105	79	69	158	236	392	447	504
	PrecMin	624	1	9	1	0	0	0	0	0	0	2	7	6
	PrecStd	235	73	77	57	42	26	18	16	32	67	90	95	98
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	19.9	21.8	26.2	29.9	35.2	37.0	37.2	33.0	28.1	23.9	20.0
		MCWB	13.7	14.2	15.2	18.0	20.4	23.6	23.9	24.0	23.3	21.1	18.3	16.3
	2%	DB	16.7	17.3	19.6	23.2	28.1	33.2	35.0	35.3	31.0	26.1	22.2	18.2
		MCWB	13.5	13.0	14.2	16.5	20.1	23.4	23.8	23.5	23.2	20.2	18.1	15.1
	5%	DB	15.8	16.2	18.2	22.0	26.8	31.8	33.8	34.0	29.3	25.0	21.1	17.2
		MCWB	12.8	12.7	13.6	15.8	19.5	23.1	23.5	23.4	22.5	20.0	17.4	14.4
	10%	DB	14.9	15.1	17.1	20.3	25.1	30.0	32.2	32.8	28.0	23.9	20.0	16.2
		MCWB	12.0	12.1	13.1	15.1	18.9	22.1	23.1	23.3	21.8	19.3	16.5	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.2	16.3	19.2	22.3	26.5	28.0	27.9	26.2	22.9	20.2	17.1
		MCDB	16.8	17.9	19.8	25.0	27.4	32.2	34.1	34.0	30.3	25.7	22.1	19.1
	2%	WB	14.0	14.1	15.1	17.5	21.0	24.8	26.2	26.2	24.7	21.6	18.8	15.7
		MCDB	16.1	16.4	18.4	22.0	26.2	30.7	31.8	31.8	28.9	24.7	21.4	17.6
	5%	WB	13.1	13.2	14.3	16.6	20.2	23.8	25.1	25.1	23.7	20.7	17.8	15.0
		MCDB	15.1	15.5	17.3	20.5	25.2	29.8	30.9	30.8	27.6	23.9	20.5	17.0
	10%	WB	12.3	12.5	13.6	15.7	19.4	22.9	24.2	24.3	22.7	19.9	16.9	14.0
		MCDB	14.4	14.9	16.4	19.4	24.1	28.5	30.1	30.1	26.5	23.0	19.4	16.1
Mean Daily Temperature Range	5% DB	MDBR	8.1	7.9	8.6	9.0	9.8	10.7	11.2	11.2	9.5	9.0	8.1	8.0
		MCDBR	8.4	9.2	10.0	11.2	12.0	12.7	13.2	13.2	11.0	10.1	8.5	8.4
		MCWBR	5.9	5.9	6.0	5.8	5.7	5.7	5.6	5.3	5.2	5.5	5.4	5.9
	5% WB	MCDBR	7.1	8.0	9.0	10.3	11.0	11.7	11.6	11.6	10.0	9.0	7.8	7.0
		MCWBR	5.5	5.7	5.8	5.8	5.8	5.9	6.3	5.8	5.6	5.6	5.5	5.5
Clear-Sky Solar Irradiance	taub	0.350	0.378	0.423	0.472	0.458	0.442	0.445	0.463	0.439	0.413	0.381	0.357	
	taud	2.444	2.338	2.204	2.084	2.187	2.281	2.275	2.220	2.282	2.324	2.375	2.414	
	Ebn at Noon	809	831	826	808	828	840	834	808	803	781	761	766	
	Edh at Noon	82	104	132	158	145	132	132	136	121	104	88	79	
All-Sky Solar Radiation	RadAvg	1.94	2.72	4.07	5.34	6.58	7.52	7.67	6.71	4.98	3.46	2.25	1.74	
	RadStd	0.18	0.32	0.42	0.45	0.35	0.37	0.28	0.28	0.29	0.29	0.19	0.27	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		+0.46	N/A	N/A	+0.76	N/A	N/A	N/A	-107	+190
Regional (8 neighbors)		+0.38	N/A	N/A	+0.80	N/A	N/A	N/A	-96	+148

Nomenclature: See separate page