

LIMNOS, Greece

WMO: 166500

Lat: 39.917N

Lon: 25.236E

Elev: 14

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.3	33.4	19.7	14.8	36.4	23.1	17.4	37.1	40.7	36.5	36.4	41.1	10.8	60	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	91.2	70.8	89.2	70.5	87.2	70.3	74.7	84.1	73.6	82.8	72.5	82.0	10.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.9	117.9	79.3	70.2	111.3	78.6	69.5	108.4	78.3	38.3	84.0	37.1	82.9	36.2	82.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
30.7	27.1	23.4	DB	26.9	94.9	2.8	3.0	24.9	97.1	23.3	98.8	21.7	100.5	19.7	102.6
			WB	25.1	77.4	3.1	1.5	22.8	78.4	21.0	79.3	19.3	80.2	17.0	81.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	45.9	47.0	50.3	56.1	64.9	73.3	78.4	78.7	70.8	62.3	55.2	48.8
	DBStd	12.79	6.61	6.66	5.91	4.83	4.43	4.46	3.16	3.42	4.41	5.22	6.25	6.55
	HDD50	493	162	125	71	9	0	0	0	0	0	23	103	
	HDD65	2797	593	504	455	267	57	2	0	0	6	112	298	503
	CDD50	4530	34	41	81	193	461	699	882	890	624	382	177	66
	CDD65	1360	0	0	0	1	53	251	417	425	181	29	3	0
	CDH74	11468	0	0	0	8	275	2093	4043	3945	1042	61	1	0
	CDH80	3659	0	0	0	0	25	608	1492	1357	176	1	0	0
Wind	WSAvg	9.8	11.0	11.3	10.7	8.5	8.0	7.9	9.5	10.4	9.3	10.1	9.6	11.0
Precipitation	PrecAvg	18.9	2.8	2.2	2.1	1.1	0.9	0.6	0.4	0.3	1.1	1.6	2.6	3.3
	PrecMax	35.9	7.3	6.6	6.9	4.1	4.0	3.6	3.6	1.9	6.6	6.2	8.1	9.7
	PrecMin	10.6	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0
	PrecStd	5.6	1.9	1.5	1.5	1.0	0.9	0.8	0.7	0.4	1.5	1.6	2.0	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	64.1	66.5	75.0	82.7	91.6	95.2	93.4	87.8	78.9	71.7	66.3
		MCWB	57.2	57.1	56.7	61.9	66.9	71.0	70.8	70.5	70.8	68.1	64.5	61.7
	2%	DB	60.9	61.2	64.1	70.1	79.2	88.2	91.4	91.0	84.1	75.4	68.8	64.0
		MCWB	56.2	56.1	57.0	60.1	65.0	69.7	70.6	71.1	68.4	66.6	63.1	59.6
	5%	DB	59.2	59.8	62.4	67.7	77.0	86.0	89.3	88.6	82.1	73.3	66.7	62.0
		MCWB	54.8	55.3	56.3	59.0	64.0	69.0	70.2	71.0	68.2	65.3	62.2	57.9
	10%	DB	57.3	58.3	60.6	65.2	74.8	83.8	87.4	86.4	79.8	71.4	64.8	59.4
		MCWB	53.4	54.1	55.4	57.6	63.6	68.1	70.3	70.7	67.6	64.5	60.6	55.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.6	58.7	59.8	63.2	69.4	75.0	76.3	76.8	74.1	71.0	66.3	62.1
		MCDB	61.7	62.2	63.9	70.6	78.3	85.5	85.4	85.1	80.9	75.3	69.7	65.4
	2%	WB	56.9	57.2	58.5	61.3	67.4	72.6	74.6	74.9	72.3	68.8	64.4	60.0
		MCDB	60.1	60.5	62.3	67.5	76.0	82.4	84.3	84.1	79.0	73.1	67.8	63.0
	5%	WB	55.4	55.8	57.2	60.1	66.0	71.2	73.4	73.7	70.9	67.1	63.0	58.3
		MCDB	58.6	59.2	60.9	65.7	73.8	81.1	83.1	83.1	78.0	71.5	66.4	61.3
	10%	WB	53.6	54.5	55.8	58.9	64.7	69.9	72.3	72.6	69.5	65.3	61.3	56.1
		MCDB	57.2	58.0	59.5	64.1	72.2	79.6	82.3	82.3	76.7	70.1	64.6	59.4
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.2	12.9	14.7	16.4	17.5	16.5	15.3	15.1	13.2	12.9	11.5
		MCDBR	14.2	14.4	14.8	18.4	20.2	20.5	19.8	17.6	18.3	16.0	13.8	12.7
		MCWBR	10.9	10.8	10.2	11.1	9.9	8.5	8.2	7.5	9.3	9.9	9.8	9.8
	5% WB	MCDBR	12.7	12.7	13.0	16.3	18.0	18.2	17.3	16.4	16.7	14.7	12.0	10.9
		MCWBR	10.4	10.0	9.8	11.0	10.1	8.7	8.4	8.1	9.7	10.0	8.8	8.9
Clear-Sky Solar Irradiance	taub	0.366	0.394	0.432	0.473	0.447	0.432	0.432	0.439	0.432	0.415	0.390	0.376	
	taud	2.372	2.273	2.174	2.083	2.235	2.324	2.327	2.299	2.304	2.311	2.320	2.327	
	Ebn at Noon	248	257	259	256	266	269	268	263	256	246	236	232	
	Edh at Noon	28	35	43	50	44	40	40	40	37	33	29	27	
All-Sky Solar Radiation	RadAvg	547	821	1271	1717	2161	2390	2442	2154	1632	1085	695	484	
	RadStd	72	83	109	162	103	123	67	53	89	89	62	73	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.04	N/A	N/A	N/A	N/A	N/A	-90	-286	+275	+119
Regional (8 neighbors)		+0.90	N/A	N/A	N/A	N/A	N/A	-121	-295	+257	+122

Nomenclature: See separate page