

LIMNOS, Greece

WMO: 166500

Lat: 39.917N

Lon: 25.236E

Elev: 4

StdP: 101.27

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.9	(c) 0.8	(d) -6.8	(e) 2.1	(f) 2.5	(g) -4.9	(h) 2.5	(i) 2.8	(j) 18.2	(k) 2.5	(l) 16.3	(m) 5.0	(n) 4.8	(o) 60	(p) 0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	32.9	21.6	31.8	21.4	30.6	21.3	23.7	28.9	23.1	28.2	22.5	27.8	4.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	16.8	26.3	21.2	15.9	25.9	20.8	15.5	25.7	71.2	28.9	68.5	28.3	66.4	27.9	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.7	(b) 12.1	(c) 10.4	(e) -2.8	(f) 35.0	(g) 1.5	(h) 1.6	(i) -3.9	(j) 36.2	(k) -4.8	(l) 37.1	(m) -5.7	(n) 38.0	(o) -6.8	(p) 39.2		
(a) 13.7	(b) 12.1	(c) 10.4	(e) -3.9	(f) 25.2	(g) 1.7	(h) 0.8	(i) -5.1	(j) 25.8	(k) -6.1	(l) 26.3	(m) -7.1	(n) 26.8	(o) -8.3	(p) 27.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	7.7	8.3	10.2	13.4	18.3	22.9	25.8	25.9	21.6	16.8	12.9	9.3		
	DBStd	7.11	3.67	3.70	3.28	2.69	2.46	2.48	1.75	1.90	2.45	2.90	3.47	3.64		
	HDD10.0	274	90	69	39	5	0	0	0	0	0	0	13	57		
	HDD18.3	1554	329	280	253	148	32	1	0	0	3	62	166	279		
	CDD10.0	2517	19	23	45	107	256	388	490	494	347	212	98	37		
	CDD18.3	756	0	0	0	1	29	139	232	236	101	16	2	0		
	CDH23.3	6371	0	0	0	4	153	1163	2246	2192	579	34	1	0		
	CDH26.7	2033	0	0	0	0	14	338	829	754	98	1	0	0		
(14) Wind	WSAvg	4.4	4.9	5.1	4.8	3.8	3.6	3.5	4.3	4.6	4.2	4.5	4.3	4.9		
(15) Precipitation	PrecAvg	480	71	56	53	29	24	16	10	7	27	40	67	83		
	PrecMax	911	186	167	176	104	101	92	92	47	167	158	206	247		
	PrecMin	270	0	2	3	0	0	0	0	0	0	0	7	0		
	PrecStd	143	49	38	37	25	23	20	17	11	38	41	51	60		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.8	19.2	23.9	28.2	33.1	35.1	34.1	31.0	26.1	22.0	19.0		
		MCWB	14.0	14.0	13.7	16.6	19.4	21.7	21.6	21.4	21.5	20.1	18.1	16.5		
	2%	DB	16.0	16.2	17.8	21.2	26.2	31.2	33.0	32.8	29.0	24.1	20.4	17.8		
		MCWB	13.4	13.4	13.9	15.6	18.3	21.0	21.5	21.7	20.2	19.2	17.3	15.3		
	5%	DB	15.1	15.4	16.9	19.9	25.0	30.0	31.8	31.5	27.8	23.0	19.3	16.7		
		MCWB	12.6	12.9	13.5	15.0	17.8	20.6	21.2	21.7	20.1	18.5	16.8	14.4		
	10%	DB	14.1	14.6	15.9	18.4	23.8	28.8	30.8	30.2	26.5	21.9	18.2	15.2		
		MCWB	11.9	12.3	13.0	14.2	17.5	20.0	21.3	21.5	19.8	18.0	15.9	13.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	14.8	15.5	17.3	20.8	23.9	24.6	24.9	23.4	21.7	19.1	16.7		
		MCDB	16.5	16.8	17.7	21.4	25.7	29.7	29.7	29.5	27.2	24.0	20.9	18.6		
	2%	WB	13.8	14.0	14.7	16.3	19.7	22.6	23.7	23.8	22.4	20.5	18.0	15.5		
		MCDB	15.6	15.9	16.9	19.7	24.5	28.0	29.1	28.9	26.1	22.8	19.9	17.2		
	5%	WB	13.0	13.2	14.0	15.6	18.9	21.8	23.0	23.2	21.6	19.5	17.2	14.6		
		MCDB	14.8	15.1	16.1	18.7	23.2	27.3	28.4	28.4	25.5	21.9	19.1	16.3		
	10%	WB	12.0	12.5	13.2	14.9	18.2	21.0	22.4	22.6	20.9	18.5	16.3	13.4		
		MCDB	14.0	14.5	15.3	17.8	22.3	26.5	27.9	27.9	24.8	21.2	18.1	15.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.8	7.2	8.1	9.1	9.7	9.2	8.5	8.4	7.4	7.2	6.4		
		MCDBR	7.9	8.0	8.2	10.2	11.2	11.4	11.0	9.8	10.1	8.9	7.6	7.0		
	5% WB	MCWBR	6.1	6.0	5.7	6.2	5.5	4.7	4.5	4.2	5.2	5.5	5.4	5.4		
		MCWBR	7.0	7.1	7.2	9.0	10.0	10.1	9.6	9.1	9.3	8.2	6.6	6.1		
(40) Clear-Sky Solar Irradiance	taub	0.366	0.394	0.432	0.473	0.447	0.432	0.432	0.432	0.439	0.432	0.415	0.390	0.376		
		taud	2.372	2.273	2.174	2.083	2.235	2.324	2.327	2.299	2.304	2.311	2.320	2.327		
	Ebn at Noon	782	809	816	806	837	849	845	828	808	777	743	732	732		
		Edh at Noon	88	111	135	158	138	127	125	126	118	105	92	86		
(44) All-Sky Solar Radiation	RadAvg	1.72	2.59	4.01	5.41	6.81	7.54	7.70	6.79	5.14	3.42	2.19	1.53			
	RadStd	0.23	0.26	0.34	0.51	0.33	0.39	0.21	0.17	0.28	0.28	0.20	0.23			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	-50	-159	+153	+66
Regional (8 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	-67	-164	+143	+68

Nomenclature: See separate page