

MITILINI, Greece

WMO: 166670

Lat: 39.057N

Lon: 26.598E

Elev: 60

StdP: 14.66

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	37.6	24.6	18.7	38.3	26.7	20.7	39.6	34.3	47.2	31.3	48.4	9.8	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	94.7	73.9	91.8	73.3	89.8	72.8	77.9	89.3	76.2	87.9	74.7	86.4	9.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.0	126.9	85.9	72.0	118.7	84.7	70.7	113.4	83.7	41.4	89.2	39.8	88.5	38.3	86.5	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.7	22.7	19.2	30.9	100.8	2.1	2.6	29.4	102.6	28.2	104.2	27.1	105.6	25.6	107.5		
			28.1	80.5	2.4	1.8	26.4	81.8	25.0	82.8	23.6	83.9	21.9	85.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	49.7	50.1	53.7	60.4	69.3	77.4	81.9	81.7	74.6	66.4	58.3	52.0
	DBStd	12.84	6.40	6.39	6.01	5.44	4.76	4.40	3.38	3.41	4.12	5.07	6.02	6.44
	HDD50	256	85	73	32	3	0	0	0	0	0	0	10	53
	HDD65	2076	475	418	352	155	17	0	0	0	0	44	210	405
	CDD50	5624	75	75	146	314	600	822	987	983	738	509	260	115
	CDD65	1971	0	0	1	16	151	372	522	518	289	89	11	2
	CDH74	17180	0	0	4	67	822	3264	5555	5381	1829	252	6	0
	CDH80	6454	0	0	0	6	163	1169	2370	2254	472	20	0	0
Wind	WSAvg	7.6	8.5	9.1	9.1	7.0	6.1	7.0	7.9	7.5	6.2	6.6	7.3	8.5
Precipitation	PrecAvg	26.1	5.1	3.9	3.0	1.9	0.8	0.2	0.1	0.1	0.4	1.5	3.8	5.9
	PrecMax	36.5	12.5	9.2	6.8	6.5	2.9	2.3	0.9	0.9	3.2	9.4	12.1	13.6
	PrecMin	9.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.1
	PrecStd	5.7	3.2	2.2	1.7	1.5	0.7	0.5	0.2	0.2	0.7	1.9	2.8	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	66.2	72.0	80.6	88.1	95.2	98.4	97.1	91.5	82.5	74.2	69.8
		MCWB	57.2	56.8	59.5	63.4	66.6	73.2	75.1	74.4	72.1	68.5	65.4	60.0
	2%	DB	62.7	64.0	68.0	75.5	84.2	91.5	94.8	94.7	87.7	79.0	71.3	66.3
		MCWB	56.6	56.4	57.4	62.0	66.8	72.1	74.2	73.9	70.7	67.6	63.6	59.1
	5%	DB	61.0	61.2	65.4	72.2	81.0	89.2	91.8	91.8	84.8	76.9	69.4	64.1
		MCWB	55.7	55.3	56.2	60.4	66.7	71.5	73.4	73.9	69.8	66.6	62.5	58.0
	10%	DB	59.2	59.4	62.9	69.7	78.7	86.2	89.8	89.7	82.5	74.4	66.6	61.9
		MCWB	54.2	54.4	55.6	59.7	65.7	70.7	73.2	73.4	69.6	65.4	60.6	56.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.9	58.7	60.8	66.2	72.4	77.8	80.5	80.0	76.0	71.6	67.0	62.0
		MCDB	62.9	63.3	69.8	75.9	81.6	89.8	90.9	90.5	86.6	78.6	72.2	67.5
	2%	WB	57.3	57.2	58.8	63.8	70.0	75.3	78.0	77.9	73.7	69.2	64.4	59.7
		MCDB	61.7	62.1	65.4	72.4	79.8	87.3	89.2	89.3	83.2	76.0	69.7	64.9
	5%	WB	55.8	55.8	57.4	61.9	68.4	73.5	76.4	76.3	72.1	67.7	62.8	58.3
		MCDB	60.2	60.6	63.5	70.2	78.3	85.5	88.1	87.9	81.4	74.9	68.0	63.2
	10%	WB	54.6	54.7	56.0	60.2	66.8	71.9	74.8	74.8	70.6	66.3	61.1	56.6
		MCDB	59.0	59.5	61.9	68.0	76.6	83.6	86.7	86.4	79.9	73.1	66.0	61.3
Mean Daily Temperature Range	5% DB	MDBR	9.4	10.4	12.3	14.3	16.3	16.8	16.6	16.5	15.1	12.7	11.1	9.5
		MCDBR	9.3	11.3	14.8	18.3	19.9	19.6	19.2	19.0	18.1	15.2	11.9	9.4
		MCWBR	7.0	8.1	9.2	10.4	11.1	10.4	9.9	9.7	9.7	9.0	7.9	6.7
	5% WB	MCDBR	8.7	10.6	13.4	16.4	18.2	18.1	17.9	17.2	16.1	13.5	11.2	8.8
		MCWBR	7.1	8.1	9.2	10.5	11.6	11.2	11.3	10.6	10.4	9.0	8.3	6.8
Clear-Sky Solar Irradiance	taub	0.359	0.390	0.425	0.464	0.437	0.408	0.408	0.411	0.407	0.401	0.377	0.365	
	taud	2.392	2.280	2.180	2.096	2.246	2.366	2.370	2.350	2.357	2.350	2.366	2.379	
	Ebn at Noon	254	260	262	259	269	276	275	272	266	253	244	241	
	Edh at Noon	28	35	43	49	43	39	38	38	36	32	28	26	
All-Sky Solar Radiation	RadAvg	612	854	1305	1710	2127	2400	2476	2195	1708	1177	777	560	
	RadStd	72	82	99	163	106	138	63	58	89	81	64	74	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (13 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-205	+189	+94	

Nomenclature: See separate page