

MITILINI, Greece

WMO: 166670

Lat: 39.057N

Lon: 26.598E

Elev: 18

StdP: 101.11

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.1	-4.1	2.7	3.5	-2.9	3.0	4.2	15.3	8.4	14.0	9.1	4.4	20	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	34.8	23.3	33.2	23.0	32.1	22.7	25.5	31.8	24.6	31.1	23.7	30.2	4.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	18.1	29.9	22.2	17.0	29.3	21.5	16.2	28.7	78.4	31.8	74.7	31.4	71.3	30.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.4	10.1	8.6	-0.6	38.2	1.1	1.4	-1.4	39.2	-2.1	40.1	-2.7	40.9	-3.6	42.0		
			-2.2	26.9	1.3	1.0	-3.1	27.7	-3.9	28.2	-4.6	28.8	-5.6	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	9.8	10.0	12.1	15.8	20.7	25.2	27.7	27.6	23.7	19.1	14.6	11.1
	DBStd	7.14	3.55	3.55	3.34	3.02	2.65	2.44	1.88	1.89	2.29	2.82	3.35	3.58
	HDD10.0	142	47	41	18	2	0	0	0	0	0	0	6	29
	HDD18.3	1153	264	232	196	86	9	0	0	0	0	24	117	225
	CDD10.0	3124	42	42	81	174	333	457	548	546	410	283	144	64
	CDD18.3	1095	0	0	1	9	84	207	290	288	161	49	6	1
	CDH23.3	9544	0	0	2	37	457	1813	3086	2989	1016	140	3	0
CDH26.7	3586	0	0	0	3	91	649	1317	1252	262	11	0	0	
Wind	WSAvg	3.4	3.8	4.1	4.0	3.2	2.7	3.1	3.5	3.4	2.8	3.0	3.3	3.8
Precipitation	PrecAvg	662	130	98	75	47	21	6	2	2	10	37	96	150
	PrecMax	928	318	234	173	164	73	58	24	24	81	238	307	345
	PrecMin	246	0	0	0	0	0	0	0	0	0	0	12	2
	PrecStd	146	81	56	44	38	19	12	6	5	19	48	72	88
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	19.0	22.2	27.0	31.2	35.1	36.9	36.1	33.0	28.0	23.5	21.0
		MCWB	14.0	13.8	15.3	17.4	19.2	22.9	24.0	23.5	22.3	20.3	18.5	15.6
	2%	DB	17.1	17.8	20.0	24.1	29.0	33.1	34.9	34.8	31.0	26.1	21.9	19.1
		MCWB	13.7	13.5	14.1	16.7	19.3	22.3	23.5	23.3	21.5	19.8	17.6	15.1
	5%	DB	16.1	16.2	18.5	22.4	27.2	31.8	33.2	33.2	29.3	24.9	20.8	17.8
		MCWB	13.2	13.0	13.4	15.8	19.3	21.9	23.0	23.3	21.0	19.2	17.0	14.4
	10%	DB	15.1	15.2	17.1	21.0	25.9	30.1	32.1	32.0	28.1	23.6	19.2	16.6
		MCWB	12.3	12.4	13.1	15.4	18.7	21.5	22.9	23.0	20.9	18.6	15.9	13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.9	14.8	16.0	19.0	22.5	25.4	27.0	26.7	24.4	22.0	19.4	16.7
		MCDB	17.2	17.4	21.0	24.4	27.6	32.1	32.7	32.5	30.3	25.9	22.3	19.7
	2%	WB	14.0	14.0	14.9	17.7	21.1	24.0	25.6	25.5	23.2	20.7	18.0	15.4
		MCDB	16.5	16.7	18.5	22.5	26.5	30.7	31.8	31.8	28.5	24.4	21.0	18.3
	5%	WB	13.2	13.2	14.1	16.6	20.2	23.0	24.6	24.6	22.3	19.9	17.1	14.6
		MCDB	15.7	15.9	17.5	21.2	25.7	29.7	31.2	31.1	27.4	23.8	20.0	17.4
	10%	WB	12.5	12.6	13.3	15.7	19.3	22.2	23.8	23.8	21.4	19.0	16.2	13.7
		MCDB	15.0	15.3	16.6	20.0	24.8	28.7	30.4	30.2	26.6	22.9	18.9	16.3
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.8	6.8	8.0	9.1	9.3	9.2	9.1	8.4	7.0	6.1	5.3
		MCDBR	5.2	6.3	8.2	10.2	11.0	10.9	10.7	10.5	10.0	8.5	6.6	5.2
		MCWBR	3.9	4.5	5.1	5.8	6.2	5.8	5.5	5.4	5.4	5.0	4.4	3.7
	5% WB	MCDBR	4.8	5.9	7.5	9.1	10.1	10.0	9.9	9.5	9.0	7.5	6.2	4.9
		MCWBR	3.9	4.5	5.1	5.8	6.5	6.2	6.3	5.9	5.8	5.0	4.6	3.8
Clear-Sky Solar Irradiance	taub	0.359	0.390	0.425	0.464	0.437	0.408	0.408	0.411	0.407	0.401	0.377	0.365	
	taud	2.392	2.280	2.180	2.096	2.246	2.366	2.370	2.350	2.357	2.350	2.366	2.379	
	Ebn at Noon	800	820	826	816	847	871	867	856	837	799	769	760	
	Edh at Noon	87	111	135	156	137	122	120	120	112	102	89	83	
All-Sky Solar Radiation	RadAvg	1.93	2.69	4.11	5.39	6.71	7.57	7.81	6.92	5.38	3.71	2.45	1.76	
	RadStd	0.23	0.26	0.31	0.51	0.34	0.43	0.20	0.18	0.28	0.26	0.20	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-114	+105	+52

Nomenclature: See separate page