

SKIROS, Greece

WMO: 166840

Lat: 38.9629N

Lon: 24.4907E

Elev: 21

StdP: 101.08

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	3.7	-4.1	2.7	4.9	-2.4	3.1	5.7	21.0	2.8	17.6	7.6	6.4	30	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	31.3	21.9	30.0	21.9	29.0	22.0	24.3	28.5	23.7	27.9	23.1	27.5	3.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	17.8	27.2	22.2	16.9	26.8	21.6	16.3	26.5	73.8	28.5	71.1	28.0	68.8	27.5	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.8	11.8	10.1	0.4	35.3	1.7	2.9	-0.8	37.4	-1.8	39.1	-2.8	40.7	-4.0	42.8		
			-0.9	25.6	1.7	1.2	-2.1	26.5	-3.1	27.2	-4.0	27.9	-5.3	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	9.8	10.2	11.8	14.6	19.0	23.1	25.4	25.5	22.2	18.2	14.8	11.2
	DBStd	6.28	3.24	3.38	3.27	2.89	2.69	2.41	1.71	1.61	2.32	2.68	2.97	3.25
	HDD10.0	126	43	36	18	2	0	0	0	0	0	2	25	
	HDD18.3	1207	266	228	204	116	23	0	0	1	34	112	223	
	CDD10.0	2743	36	41	73	141	279	392	476	479	367	254	145	61
	CDD18.3	783	0	0	1	4	44	142	218	221	118	30	6	1
	CDH23.3	5597	0	0	5	11	173	946	1916	1885	586	69	6	0
	CDH26.7	1187	0	0	1	1	24	197	469	400	90	6	1	0
Wind	WSAvg	4.3	5.4	5.4	4.8	3.8	3.4	3.3	3.7	4.2	4.1	4.3	4.5	5.4
Precipitation	PrecAvg	468	67	60	53	27	19	16	5	8	24	42	53	93
	PrecMax	854	142	177	164	79	64	132	33	46	97	110	149	279
	PrecMin	200	4	5	1	2	0	0	0	0	0	7	12	
	PrecStd	168	35	42	40	20	17	29	7	12	27	36	37	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	19.2	22.8	24.7	29.1	33.2	34.2	32.2	31.1	27.2	24.0	20.5
		MCWB	13.5	13.6	15.2	15.0	18.5	21.0	22.0	23.1	21.2	19.7	17.2	15.7
	2%	DB	16.8	17.2	19.8	22.4	26.9	30.1	31.8	30.8	28.9	25.1	21.9	18.4
		MCWB	13.4	13.0	13.7	14.8	17.9	20.7	21.9	22.8	21.4	19.6	17.1	14.7
	5%	DB	15.8	16.2	18.1	21.0	25.1	28.7	30.1	29.8	27.2	23.7	20.7	17.2
		MCWB	12.6	12.5	13.0	14.6	17.3	20.6	22.0	22.7	21.0	19.1	16.8	14.0
	10%	DB	14.8	15.1	16.8	19.4	23.9	27.3	29.0	28.8	26.2	22.2	19.2	16.0
		MCWB	11.9	11.9	12.5	14.0	17.1	20.6	22.1	22.6	20.5	18.4	16.2	13.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	14.6	16.0	17.4	20.8	24.1	25.2	25.5	24.5	21.8	18.9	16.4
		MCDB	17.0	17.6	21.0	21.5	26.0	29.0	29.7	29.4	28.0	25.2	21.8	19.2
	2%	WB	13.6	13.6	14.5	16.1	19.4	23.0	24.2	24.5	22.9	20.6	18.0	15.2
		MCDB	16.1	16.5	18.3	20.3	23.9	27.4	28.6	28.5	26.5	23.6	20.7	17.9
	5%	WB	12.9	12.9	13.6	15.3	18.6	22.2	23.6	23.8	22.1	19.7	17.2	14.2
		MCDB	15.4	15.7	16.9	19.2	23.0	26.5	28.0	27.9	25.7	22.6	19.9	16.8
	10%	WB	12.0	12.2	12.9	14.7	18.0	21.5	22.9	23.3	21.3	18.8	16.4	13.2
		MCDB	14.5	14.9	16.0	18.4	22.4	25.9	27.4	27.6	25.1	21.6	19.0	15.6
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.2	5.6	6.3	6.8	6.7	6.2	5.6	5.9	5.3	5.3	4.8
		MCDBR	6.0	6.5	7.5	8.4	8.9	8.8	8.3	7.0	7.8	7.6	6.5	6.0
		MCWBR	4.2	4.3	4.3	4.8	4.6	4.8	5.1	4.3	5.0	4.6	4.0	4.1
	5% WB	MCDBR	5.6	6.0	6.7	7.4	7.5	7.0	6.7	6.1	6.9	6.7	5.7	5.4
		MCWBR	4.2	4.4	4.4	4.9	4.7	4.6	4.7	4.3	4.9	4.6	3.9	4.0
Clear-Sky Solar Irradiance	taub	0.368	0.394	0.431	0.469	0.446	0.424	0.426	0.435	0.429	0.415	0.392	0.377	
	taud	2.375	2.280	2.187	2.102	2.241	2.347	2.348	2.315	2.322	2.315	2.324	2.337	
	Ebn at Noon	790	815	821	812	840	857	851	835	815	783	750	743	
	Edh at Noon	89	111	134	156	138	124	123	124	117	106	93	87	
All-Sky Solar Radiation	RadAvg	1.75	2.57	4.01	5.42	6.64	7.46	7.53	6.66	5.09	3.41	2.22	1.53	
	RadStd	0.24	0.33	0.34	0.52	0.31	0.36	0.19	0.14	0.27	0.29	0.21	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	-114	+97	N/A

Nomenclature: See separate page