

TRIPOLIS, Greece

WMO: 167100

Lat: 37.525N

Lon: 22.397E

Elev: 2134

StdP: 13.60

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	26.3	15.3	12.9	31.3	18.9	15.4	32.6	23.8	45.8	20.9	47.5	1.0	0	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.7	93.3	64.0	90.4	63.3	87.9	62.8	67.2	82.6	66.1	81.7	65.1	80.9	9.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	95.1	69.1	61.8	89.4	68.8	60.3	84.5	68.4	32.8	82.4	31.9	81.4	31.1	80.8	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.7	14.7	17.9	99.2	3.4	3.6	15.5	101.8	13.5	103.9	11.7	106.0	9.2	108.6		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	40.9	42.6	45.8	51.6	60.5	68.2	73.0	72.9	67.5	57.5	50.1	42.8		
	DBStd	12.79	5.94	5.65	5.75	5.97	5.39	5.71	3.84	4.23	4.65	5.64	5.41	5.55		
	HDD50	1002	287	213	150	51	1	0	0	0	0	9	60	231		
	HDD65	3965	747	627	595	402	158	31	0	3	26	241	448	687		
	CDD50	3264	4	6	20	99	328	547	714	709	525	240	63	9		
	CDD65	752	0	0	0	0	19	127	249	247	102	8	0	0		
	CDH74	9470	0	0	0	28	402	1765	3119	2825	1213	118	0	0		
	CDH80	3727	0	0	0	0	80	670	1372	1185	391	29	0	0		
	WSAvg	4.7	4.9	5.1	5.5	4.8	5.3	4.8	4.6	5.1	4.6	3.9	3.6	4.0		
	PrecAvg	31.6	4.7	3.9	2.7	2.3	1.4	0.8	0.7	0.6	1.1	3.0	4.3	6.1		
(15) Precipitation	PrecMax	47.0	13.0	7.8	5.4	5.0	4.1	3.3	3.5	2.5	4.6	7.4	9.3	13.6		
	PrecMin	15.7	0.1	0.8	0.0	0.6	0.1	0.0	0.0	0.0	0.0	0.1	0.7	0.8		
	PrecStd	6.7	2.8	1.8	1.5	1.3	0.9	0.9	0.8	0.7	1.1	2.0	2.2	3.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	66.2	68.5	77.4	87.2	95.4	97.6	95.8	91.7	84.3	69.8	60.2		
		MCWB	49.3	50.3	51.0	55.8	63.4	65.2	64.4	63.8	63.0	60.8	55.3	51.7		
	2%	DB	56.1	59.4	64.3	73.5	82.0	90.5	93.4	92.8	87.9	77.1	65.5	57.4		
		MCWB	48.6	48.3	49.7	55.1	60.4	63.3	64.5	63.6	62.0	59.0	55.2	50.5		
	5%	DB	53.6	55.9	60.8	69.2	78.5	87.2	90.5	89.5	84.6	72.8	62.4	55.3		
		MCWB	47.0	47.5	48.9	53.3	59.0	62.8	63.7	62.7	61.5	58.1	54.4	49.3		
	10%	DB	51.0	52.8	57.5	65.2	75.0	83.7	87.6	86.7	81.3	69.2	59.7	52.8		
		MCWB	45.8	46.5	47.7	51.9	57.6	61.8	63.3	62.4	60.8	56.9	52.8	47.8		
	0.4%	WB	53.2	52.6	54.3	58.4	65.8	67.8	68.5	68.5	66.6	64.0	59.7	54.4		
		MCDB	56.7	59.4	62.9	71.6	82.4	84.4	83.6	82.0	78.5	77.2	64.7	57.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	50.1	50.3	51.7	55.9	62.3	66.0	67.2	67.0	65.2	62.0	57.1	52.2		
		MCDB	54.3	56.9	59.7	70.0	76.9	83.6	83.3	81.5	77.8	72.0	62.7	55.9		
	5%	WB	48.2	48.7	50.2	54.2	60.3	64.8	66.0	65.8	63.9	60.1	55.4	50.3		
		MCDB	52.3	54.8	58.6	67.2	74.3	81.9	82.7	80.2	76.8	68.8	60.8	53.9		
	10%	WB	46.2	46.9	48.5	52.6	58.8	63.2	64.8	64.6	62.7	58.6	53.9	48.5		
		MCDB	50.1	52.3	56.5	63.8	72.9	79.6	82.2	79.4	75.8	67.0	58.4	52.2		
	5% DB	MDBR	15.2	15.8	18.3	21.2	24.8	26.9	27.7	26.3	25.0	20.3	17.6	16.9		
		MCDBR	21.0	23.8	26.6	29.7	30.4	31.9	32.7	30.8	31.5	28.1	22.3	21.2		
		MCWBR	13.0	13.8	14.4	13.8	12.4	11.1	10.0	8.9	10.6	12.0	12.4	13.6		
		MCWBR	14.9	19.2	23.0	26.5	28.3	29.1	28.6	26.3	25.0	22.4	17.7	14.6		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.354	0.395	0.431	0.422	0.401	0.405	0.414	0.401	0.378	0.353	0.334		
		taud	2.457	2.356	2.227	2.137	2.221	2.323	2.318	2.286	2.323	2.361	2.408	2.442		
	Ebn at Noon		272	276	274	270	274	279	277	272	269	264	258	259		
		Edh at Noon	27	33	41	48	45	41	40	41	37	33	28	25		
(44) All-Sky Solar Radiation	RadAvg		663	900	1307	1693	2004	2285	2379	2146	1634	1139	789	598		
	RadStd		79	95	112	162	100	154	108	81	104	94	72	76		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.52	N/A	N/A	+1.08	N/A	N/A	-130	+153	N/A

Nomenclature: See separate page