

TRIPOLIS, Greece

WMO: 167100

Lat: 37.525N

Lon: 22.397E

Elev: 651

StdP: 93.75

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.8	(c) -3.2	(d) -9.3	(e) 1.8	(f) -0.4	(g) -7.3	(h) 2.2	(i) 0.4	(j) 10.6	(k) 7.7	(l) 9.3	(m) 8.6	(n) 0.5	(o) 0	(p) 0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	34.0	17.8	32.5	17.4	31.0	17.1	19.6	28.1	18.9	27.6	18.4	27.1	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	13.6	20.6	16.6	12.8	20.5	15.7	12.1	20.2	58.5	28.0	56.4	27.4	54.5	27.1	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.5	(b) 7.5	(c) 6.6	(e) -7.8	(f) 37.4	(g) 1.9	(h) 2.0	(i) -9.2	(j) 38.8	(k) -10.3	(l) 40.0	(m) -11.3	(n) 41.1	(o) -12.7	(p) 42.5		
(4) 8.5	(5) 7.5	(6) 6.6	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	4.9	5.9	7.7	10.9	15.8	20.1	22.8	22.7	19.7	14.1	10.0	6.0		
	DBStd	7.11	3.30	3.14	3.20	3.32	3.00	3.17	2.14	2.35	2.58	3.14	3.01	3.08		
	HDD10.0	557	159	118	83	28	1	0	0	0	0	5	33	128		
	HDD18.3	2203	415	348	331	223	88	17	0	2	14	134	249	382		
	CDD10.0	1813	2	3	11	55	182	304	397	394	292	133	35	5		
	CDD18.3	418	0	0	0	0	11	71	138	137	57	4	0	0		
	CDH23.3	5261	0	0	0	16	223	981	1733	1569	674	66	0	0		
	CDH26.7	2071	0	0	0	0	44	372	762	658	217	16	0	0		
(14) Wind	WSAvg	2.1	2.2	2.3	2.5	2.2	2.4	2.1	2.0	2.3	2.0	1.7	1.6	1.8		
(15) Precipitation	PrecAvg	802	119	99	69	59	36	21	18	16	27	77	110	154		
	PrecMax	1193	330	198	138	127	104	84	90	64	118	187	237	346		
	PrecMin	399	3	20	0	16	2	0	0	0	0	2	17	20		
	PrecStd	171	72	46	37	32	24	23	21	18	27	52	55	84		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	19.0	20.3	25.2	30.7	35.2	36.4	35.5	33.2	29.0	21.0	15.7		
		MCWB	9.6	10.1	10.6	13.2	17.4	18.4	18.0	17.7	17.2	16.0	12.9	10.9		
	2%	DB	13.4	15.2	17.9	23.0	27.8	32.5	34.1	33.8	31.1	25.0	18.6	14.1		
		MCWB	9.2	9.0	9.8	12.9	15.8	17.4	18.1	17.5	16.7	15.0	12.9	10.3		
	5%	DB	12.0	13.3	16.0	20.7	25.8	30.7	32.5	32.0	29.2	22.7	16.9	13.0		
		MCWB	8.3	8.6	9.4	11.9	15.0	17.1	17.6	17.1	16.4	14.5	12.5	9.6		
	10%	DB	10.5	11.6	14.2	18.4	23.9	28.7	30.9	30.4	27.4	20.7	15.4	11.6		
		MCWB	7.7	8.1	8.7	11.1	14.2	16.5	17.4	16.9	16.0	13.8	11.5	8.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	11.4	12.4	14.7	18.8	19.9	20.3	20.3	19.2	17.8	15.4	12.5		
		MCDB	13.7	15.2	17.1	22.0	28.0	29.1	28.7	27.8	25.8	25.1	18.2	14.1		
	2%	WB	10.1	10.1	11.0	13.3	16.8	18.9	19.5	19.5	18.4	16.7	13.9	11.2		
		MCDB	12.4	13.8	15.4	21.1	24.9	28.7	28.5	27.5	25.4	22.2	17.1	13.3		
	5%	WB	9.0	9.3	10.1	12.3	15.7	18.2	18.9	18.8	17.7	15.6	13.0	10.2		
		MCDB	11.3	12.7	14.8	19.5	23.5	27.7	28.2	26.8	24.9	20.4	16.0	12.2		
	10%	WB	7.9	8.3	9.2	11.4	14.9	17.3	18.2	18.1	17.1	14.8	12.2	9.2		
		MCDB	10.1	11.3	13.6	17.7	22.7	26.4	27.9	26.3	24.3	19.4	14.7	11.2		
(35) Mean Daily Temperature Range	MDBR		8.5	8.8	10.2	11.8	13.8	15.0	15.4	14.6	13.9	11.3	9.8	9.4		
	5% DB	MCDBR	11.7	13.2	14.8	16.5	16.9	17.7	18.1	17.1	17.5	15.6	12.4	11.8		
		MCWBR	7.2	7.6	8.0	7.7	6.9	6.2	5.5	4.9	5.9	6.7	6.9	7.5		
	5% WB	MCDBR	8.3	10.7	12.8	14.7	15.7	16.2	15.9	14.6	13.9	12.4	9.9	8.1		
		MCWBR	5.9	6.6	7.5	7.3	7.2	6.3	5.5	4.6	5.4	6.1	6.1	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.354	0.395	0.431	0.422	0.401	0.405	0.414	0.401	0.378	0.353	0.334		
	taud		2.457	2.356	2.227	2.137	2.221	2.323	2.318	2.286	2.323	2.361	2.408	2.442		
	Ebn at Noon		856	871	863	850	863	879	872	856	847	831	813	818		
	Edh at Noon		84	104	130	151	141	128	127	128	117	103	87	80		
(44) All-Sky Solar Radiation	RadAvg		2.09	2.84	4.12	5.34	6.32	7.20	7.50	6.77	5.15	3.59	2.49	1.89		
	RadStd		0.25	0.30	0.35	0.51	0.32	0.49	0.34	0.26	0.33	0.30	0.23	0.24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	+0.29	N/A	N/A	+0.60	N/A	N/A	N/A	-72	+85	N/A

Nomenclature: See separate page