

NAXOS, Greece

WMO: 167320

Lat: 37.1014N

Lon: 25.3731E

Elev: 10

StdP: 101.21

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	7.7	-1.1	3.4	8.0	0.5	3.9	8.9	23.9	9.0	21.6	10.2	10.7	0	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	30.1	22.3	29.0	22.3	28.2	22.1	24.1	28.3	23.6	27.7	23.0	27.1	4.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.7	17.4	27.2	22.1	16.8	26.8	21.5	16.2	26.4	72.7	28.4	70.4	27.9	68.4	27.1	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.3	16.8	14.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	12.5	13.1	13.7	15.8	20.0	23.7	25.4	25.3	24.0	19.9	16.4	13.5
	DBStd	5.28	2.54	2.36	2.41	2.45	1.90	2.01	1.49	1.31	1.78	2.03	2.46	2.45
	HDD10.0	19	9	3	2	1	0	0	0	0	0	0	1	3
	HDD18.3	783	182	148	143	81	6	0	0	0	0	8	66	149
	CDD10.0	3174	85	89	118	176	311	409	477	476	421	307	192	113
	CDD18.3	897	0	1	1	6	59	159	219	217	171	57	7	1
	CDH23.3	5282	0	1	1	8	129	896	1641	1604	929	71	2	0
	CDH26.7	715	0	0	0	0	11	153	262	181	105	3	0	0
Wind	WSAvg	6.8	7.6	7.8	7.8	6.1	5.3	5.3	6.8	6.7	5.8	7.5	6.9	7.9
Precipitation	PrecAvg	366	63	63	41	19	13	1	1	0	7	36	52	69
	PrecMax	555	156	156	100	76	56	15	27	4	37	187	130	128
	PrecMin	215	0	2	0	0	0	0	0	0	0	4	4	4
	PrecStd	81	32	41	28	19	13	3	5	1	11	42	35	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	20.5	21.3	24.5	28.1	31.8	32.7	30.7	30.6	26.6	23.0	20.6
		MCWB	14.2	13.7	14.6	16.4	18.2	22.1	21.4	22.4	22.4	20.0	17.4	15.9
	2%	DB	17.6	18.5	19.5	22.3	26.1	29.5	30.2	29.2	28.7	25.0	21.9	19.1
		MCWB	14.2	13.9	13.8	16.1	18.2	21.5	22.5	23.1	22.3	20.9	17.6	15.4
	5%	DB	16.9	17.4	18.3	21.0	24.7	28.3	29.0	28.4	27.8	23.9	20.8	18.0
		MCWB	14.0	13.8	13.8	15.7	18.3	21.2	22.2	22.8	22.0	20.4	17.0	14.7
	10%	DB	16.1	16.6	17.3	19.8	23.5	27.2	28.0	27.6	27.0	22.9	20.0	17.0
		MCWB	13.3	13.4	13.5	15.2	18.0	20.9	22.2	22.5	21.7	19.3	16.6	14.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.9	15.6	15.8	18.1	20.6	24.1	24.7	24.9	24.2	22.6	19.2	17.1
		MCDB	17.3	18.5	18.4	21.5	25.4	29.6	28.8	28.3	28.4	24.9	21.6	19.6
	2%	WB	15.1	14.8	15.0	17.1	19.8	22.8	24.1	24.1	23.4	21.6	18.2	15.9
		MCDB	16.8	17.4	17.9	21.1	24.1	27.8	28.2	28.0	27.3	24.1	21.0	18.2
	5%	WB	14.3	14.2	14.5	16.4	19.2	22.1	23.5	23.5	22.8	20.6	17.4	15.1
		MCDB	16.4	16.8	17.5	20.1	23.1	26.8	27.7	27.5	26.6	23.5	20.3	17.6
	10%	WB	13.5	13.6	14.0	15.7	18.6	21.6	22.8	23.1	22.3	19.6	16.7	14.3
		MCDB	15.8	16.2	17.1	19.2	22.4	26.2	27.1	27.0	26.2	22.5	19.6	16.8
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.1	4.1	4.8	5.0	4.8	3.8	3.1	4.1	3.1	3.9	3.5
		MCDBR	5.2	5.7	5.9	7.1	7.5	6.8	6.1	5.0	6.1	5.1	5.7	4.9
		MCWBR	3.6	3.8	3.8	5.1	4.3	4.4	4.0	3.7	4.3	3.8	3.6	3.3
	5% WB	MCDBR	4.6	5.3	5.1	6.6	6.0	5.7	5.2	4.2	5.4	4.4	4.8	4.4
		MCWBR	3.6	4.0	3.8	5.0	3.9	4.3	3.9	3.4	4.3	3.6	3.4	3.2
Clear-Sky Solar Irradiance	taub	0.362	0.391	0.427	0.459	0.440	0.407	0.408	0.411	0.412	0.405	0.386	0.369	
	taud	2.406	2.305	2.197	2.135	2.253	2.391	2.391	2.370	2.376	2.353	2.367	2.394	
	Ebn at Noon	814	831	833	826	848	874	870	860	840	806	777	777	
	Edh at Noon	89	111	135	152	137	119	119	119	112	105	92	86	
All-Sky Solar Radiation	RadAvg	2.12	2.89	4.41	5.76	6.86	7.75	7.73	6.88	5.54	3.88	2.61	1.92	
	RadStd	0.19	0.27	0.27	0.42	0.31	0.27	0.11	0.09	0.24	0.19	0.18	0.20	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.37	N/A	N/A	N/A	+0.33	+0.37	N/A	-76	+94	N/A

Nomenclature: See separate page