

METHONI, Greece

WMO: 167340

Lat: 36.825N

Lon: 21.704E

Elev: 52

StdP: 100.70

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.5	-6.2	2.2	8.6	-3.2	2.9	8.9	14.0	13.1	12.3	13.1	3.8	50	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	31.0	22.5	30.0	23.0	29.1	23.1	25.2	28.4	24.6	28.0	24.1	27.6	4.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	19.2	27.6	23.5	18.5	27.1	22.9	17.7	26.6	77.6	28.4	75.0	28.1	72.6	27.6	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.7	8.5	1.7	35.0	1.0	2.8	1.0	37.0	0.4	38.6	-0.1	40.2	-0.9	42.2		
			-0.3	25.9	1.5	1.0	-1.4	26.6	-2.3	27.2	-3.1	27.7	-4.2	28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	11.4	11.8	12.9	15.4	18.9	22.6	25.0	26.1	23.7	19.8	16.1	12.6
	DBStd	5.60	2.48	2.23	2.33	2.42	2.08	2.10	1.57	1.47	1.92	2.42	2.50	2.46
	HDD10.0	34	14	7	5	1	0	0	0	0	0	0	1	7
	HDD18.3	939	213	183	168	93	18	0	0	0	14	71	178	
	CDD10.0	2979	59	58	95	162	276	379	464	501	409	303	185	87
	CDD18.3	843	0	0	1	6	36	129	206	242	159	59	6	0
	CDH23.3	5744	0	0	1	20	74	678	1557	2258	999	155	1	0
	CDH26.7	1252	0	0	0	3	7	119	319	646	153	4	0	0
Wind	WSAvg	4.1	4.2	4.3	4.2	4.2	4.0	4.2	4.4	4.1	4.1	3.5	4.0	4.1
Precipitation	PrecAvg	688	110	83	64	34	14	2	0	3	34	92	112	140
	PrecMax	1034	220	184	164	86	63	15	7	30	181	522	296	346
	PrecMin	401	23	13	1	2	0	0	0	0	5	7	36	
	PrecStd	150	47	40	35	23	15	3	1	6	42	87	62	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	20.0	21.8	25.7	27.6	31.8	32.5	34.2	30.0	27.3	23.4	19.9
		MCWB	14.9	12.3	14.5	13.4	17.1	20.7	20.5	21.0	22.6	20.7	17.6	15.9
	2%	DB	17.0	17.5	18.9	22.7	25.2	29.2	30.2	31.5	29.1	25.9	22.3	18.4
		MCWB	13.9	13.2	14.0	14.8	17.6	21.4	22.9	22.4	22.9	20.8	17.9	15.1
	5%	DB	16.2	16.4	17.6	20.9	23.7	27.9	29.3	30.4	28.3	25.0	21.4	17.6
		MCWB	13.3	13.0	13.8	14.6	18.5	21.7	23.2	23.2	22.7	20.3	17.4	14.5
	10%	DB	15.5	15.5	16.7	19.6	22.7	26.6	28.5	29.6	27.6	24.1	20.4	16.8
		MCWB	12.7	12.4	13.4	14.4	18.2	21.4	23.0	23.4	22.3	19.4	16.7	13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	15.1	16.0	17.3	21.2	24.9	25.6	26.4	25.0	23.1	19.5	16.8
		MCDB	17.8	17.2	19.5	21.0	23.9	28.1	28.7	29.4	28.1	25.3	21.7	18.7
	2%	WB	14.8	14.3	15.0	16.5	20.2	23.4	25.0	25.5	24.2	22.0	18.7	15.9
		MCDB	16.4	16.5	17.5	20.1	23.0	26.8	28.1	28.8	27.6	24.7	21.2	17.7
	5%	WB	14.0	13.6	14.4	15.8	19.5	22.7	24.3	24.8	23.6	21.1	18.0	15.1
		MCDB	15.8	15.8	16.8	19.2	22.4	26.1	27.6	28.3	27.0	23.9	20.6	17.0
	10%	WB	13.1	13.0	13.8	15.1	18.8	22.0	23.7	24.3	22.9	20.1	17.1	14.2
		MCDB	15.3	15.1	16.2	18.3	21.7	25.3	27.2	27.8	26.4	23.2	19.6	16.4
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.1	6.3	6.7	6.4	6.4	6.1	6.7	6.8	7.3	6.6	6.4
		MCDBR	6.5	6.4	7.1	8.4	7.7	8.5	7.3	8.2	7.5	7.8	7.5	6.7
		MCWBR	4.6	4.3	4.5	4.8	4.7	5.4	4.8	5.2	4.5	4.6	4.5	4.5
	5% WB	MCDBR	5.4	5.7	6.0	6.9	6.2	6.6	6.1	6.4	6.4	6.7	6.1	5.3
MCWBR		4.4	4.3	4.3	4.8	4.7	5.1	4.5	4.9	4.5	4.6	4.6	4.5	
Clear-Sky Solar Irradiance	taub	0.355	0.383	0.427	0.461	0.453	0.428	0.432	0.446	0.430	0.410	0.383	0.364	
	taud	2.434	2.331	2.191	2.115	2.200	2.321	2.313	2.275	2.318	2.339	2.382	2.412	
	Ebn at Noon	826	842	834	825	837	856	849	829	822	802	784	786	
	Edh at Noon	87	108	136	155	145	128	128	131	119	106	91	84	
All-Sky Solar Radiation	RadAvg	2.22	3.04	4.50	5.86	6.87	7.72	7.84	6.96	5.38	3.78	2.59	1.99	
	RadStd	0.21	0.26	0.30	0.42	0.31	0.31	0.17	0.18	0.26	0.25	0.23	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)		+0.26	N/A	N/A	+0.70	-0.35	-0.56	N/A	-67	+93	N/A

Nomenclature: See separate page