

MILOS, Greece

WMO: 167380

Lat: 36.739N

Lon: 24.429E

Elev: 167

StdP: 99.34

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.5	5.7	-5.3	2.5	6.8	-3.3	2.9	8.0	19.5	6.9	18.6	8.3	11.2	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	33.4	19.4	31.8	19.3	30.5	19.3	23.3	27.7	22.5	27.1	21.9	26.6	3.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	16.9	26.0	21.1	16.0	25.4	20.3	15.3	25.0	70.4	27.5	67.3	27.3	65.0	26.4	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.1	15.0	13.7	DB	3.8	37.1	1.9	1.8	2.5	38.3	1.4	39.4	0.3	40.4	-1.1	41.6
			WB	1.5	24.6	2.1	1.4	0.0	25.5	-1.2	26.3	-2.4	27.1	-3.9	28.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	11.1	11.3	12.6	15.4	20.1	24.2	26.6	26.4	24.0	19.9	16.0	12.5
	DBStd	6.24	2.70	2.64	2.91	2.73	2.56	2.40	2.02	1.73	2.10	2.67	2.99	2.70
	HDD10.0	61	20	17	9	1	0	0	0	0	0	0	2	11
	HDD18.3	981	224	197	178	93	11	0	0	0	0	15	80	182
	CDD10.0	3120	54	53	91	163	313	426	516	508	421	307	181	88
	CDD18.3	999	0	0	1	5	66	176	257	250	171	63	9	0
	CDH23.3	7211	0	0	3	16	284	1276	2406	2142	936	143	5	0
	CDH26.7	2133	0	0	1	1	50	381	853	639	197	11	0	0
Wind	WSAvg	5.8	6.8	7.1	6.7	5.4	4.9	5.3	5.8	6.0	4.6	5.6	5.4	6.8
Precipitation	PrecAvg	409	76	51	47	24	13	2	0	0	6	42	61	90
	PrecMax	570	260	138	99	108	72	30	4	6	45	175	174	242
	PrecMin	239	2	3	0	3	0	0	0	0	0	0	1	21
	PrecStd	85	51	30	26	25	17	6	1	1	10	44	50	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.6	17.9	22.7	25.5	30.6	34.5	36.5	34.8	33.0	28.1	24.3	19.1
		MCWB	13.4	13.1	12.9	14.8	17.5	18.7	19.0	21.0	19.1	18.7	17.5	15.1
	2%	DB	16.2	16.5	19.4	22.7	27.9	31.9	33.8	32.5	30.2	26.4	22.3	17.7
		MCWB	12.8	12.5	13.0	14.5	16.7	18.1	19.1	20.1	19.8	19.0	17.6	14.6
	5%	DB	15.5	15.6	17.7	21.1	26.2	30.2	32.0	31.1	28.7	24.9	20.9	16.8
		MCWB	12.6	12.1	12.9	13.9	15.9	18.0	19.1	20.1	20.1	18.7	16.8	13.9
	10%	DB	14.7	14.8	16.4	19.6	24.7	28.8	30.7	29.8	27.6	23.5	19.8	16.0
		MCWB	12.2	11.8	12.3	13.5	15.6	18.2	19.3	20.3	19.7	18.4	16.4	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	14.4	15.2	17.1	19.5	22.8	24.3	25.1	23.6	22.6	19.6	16.3
		MCDB	16.3	16.8	18.7	21.7	25.1	28.3	28.0	30.3	27.2	25.5	22.6	18.1
	2%	WB	13.9	13.5	14.3	15.9	18.4	21.5	22.7	23.6	22.5	21.2	18.4	15.4
		MCDB	15.5	15.6	17.4	20.2	24.5	26.9	27.7	28.3	26.1	24.1	21.1	17.1
	5%	WB	13.2	12.8	13.6	15.1	17.6	20.6	21.9	22.7	21.8	20.2	17.7	14.6
		MCDB	14.9	14.7	16.4	18.8	23.0	26.1	27.4	27.5	25.7	23.0	20.1	16.3
	10%	WB	12.5	12.2	12.9	14.5	17.0	19.9	21.2	22.1	21.2	19.4	16.9	13.9
		MCDB	14.5	14.3	15.7	18.1	21.8	25.4	27.0	26.9	25.5	22.3	19.2	15.7
Mean Daily Temperature Range	5% DB	MDBR	3.6	4.0	4.7	5.9	7.2	7.5	7.0	6.1	6.0	4.8	4.0	3.5
		MCDBR	4.4	5.1	6.6	8.1	9.3	9.4	9.2	8.0	7.8	6.5	5.4	4.7
		MCWBR	3.0	3.4	3.7	3.9	3.8	3.9	3.9	3.7	3.8	3.3	3.2	3.3
	5% WB	MCDBR	4.1	4.6	5.8	6.8	7.8	7.6	7.0	6.4	6.8	5.9	5.2	4.5
		MCWBR	3.2	3.5	3.9	3.9	3.8	3.9	4.2	3.4	3.8	3.5	3.4	3.6
Clear-Sky Solar Irradiance	taub	0.356	0.382	0.419	0.447	0.431	0.401	0.403	0.407	0.410	0.399	0.380	0.364	
	taud	2.426	2.336	2.221	2.164	2.275	2.401	2.401	2.381	2.381	2.370	2.385	2.402	
	Ebn at Noon	826	845	843	838	857	880	875	865	843	815	788	786	
	Edh at Noon	88	108	132	148	134	118	117	117	112	103	91	85	
All-Sky Solar Radiation	RadAvg	2.19	2.98	4.51	5.90	6.98	7.89	7.86	7.03	5.62	3.90	2.60	1.92	
	RadStd	0.19	0.30	0.30	0.41	0.30	0.26	0.12	0.12	0.26	0.21	0.22	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.33	N/A	N/A	N/A	+0.45	+0.47	N/A	-70	N/A	N/A

Nomenclature: See separate page