

KOS, Greece

WMO: 167420

Lat: 36.793N

Lon: 27.092E

Elev: 126

StdP: 99.83

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.1	-5.2	2.5	5.3	-3.8	2.8	6.2	13.7	11.7	12.6	12.4	6.6	0	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.8	21.5	32.1	21.2	31.0	21.1	24.1	28.5	23.5	27.9	23.0	27.3	5.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.0	25.4	22.2	17.1	25.2	21.8	16.8	25.1	72.8	28.4	70.6	27.6	68.6	27.6	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	10.0	9.1	DB	2.3	36.7	2.2	2.0	0.8	38.1	-0.5	39.2	-1.7	40.3	-3.3	41.8	(4)
(5)			WB	-0.7	25.1	1.8	0.7	-1.9	25.6	-3.0	26.1	-3.9	26.5	-5.2	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	11.4	11.6	13.3	16.1	20.4	24.7	26.9	27.0	24.2	20.3	16.4	12.9	(6)	
	DBStd	6.18	2.90	2.91	2.51	2.50	2.30	2.39	1.79	1.69	2.01	2.47	2.81	2.94	(7)	
	HDD10.0	55	21	17	6	1	0	0	0	0	0	0	2	9	(8)	
	HDD18.3	887	215	188	157	73	7	0	0	0	0	11	68	168	(9)	
	CDD10.0	3273	63	62	107	185	321	441	524	528	426	321	194	101	(10)	
	CDD18.3	1063	0	0	0	7	70	191	266	270	176	73	10	1	(11)	
	CDH23.3	7788	0	0	0	16	256	1404	2491	2474	984	157	6	0	(12)	
(13)	CDH26.7	2514	0	0	0	1	39	436	926	889	213	11	0	0	(13)	
(14)	Wind	WSAvg	4.6	4.7	4.8	4.7	4.3	4.1	4.9	5.5	5.2	4.5	4.1	3.9	4.5	(14)
(15) Precipitation	PrecAvg	687	164	122	78	37	15	4	0	1	10	55	78	150	(15)	
	PrecMax	1126	405	260	164	168	100	42	7	26	79	430	218	355	(16)	
	PrecMin	233	3	10	0	0	0	0	0	0	0	0	8	25	(17)	
	PrecStd	202	105	61	47	39	20	9	2	5	23	85	54	79	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	18.6	20.3	25.2	30.0	35.0	36.0	35.7	32.2	28.1	24.1	20.0	(19)	
		MCWB	14.3	14.2	14.3	16.8	18.5	21.6	21.5	21.6	20.8	19.1	18.6	16.2	(20)	
	2%	DB	16.9	17.1	18.9	23.1	27.7	32.2	33.8	33.2	30.2	26.1	22.2	18.9	(21)	
		MCWB	13.7	13.6	13.8	15.6	18.1	20.7	21.4	21.9	20.8	19.3	17.8	15.7	(22)	
	5%	DB	16.1	16.2	17.9	21.2	26.0	30.8	32.1	32.0	28.9	25.0	21.1	17.9	(23)	
		MCWB	13.1	13.1	13.5	15.1	17.9	20.4	21.1	21.6	20.5	19.1	17.3	14.7	(24)	
	10%	DB	15.2	15.3	16.9	20.0	24.8	29.0	30.9	30.9	27.9	24.0	20.1	17.0	(25)	
		MCWB	12.4	12.4	13.0	14.7	17.6	20.2	21.1	21.6	20.5	18.5	16.7	14.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	15.4	15.6	18.1	20.5	23.9	24.6	25.0	23.8	22.0	19.7	17.2	(27)	
		MCDB	17.0	17.6	18.4	23.0	26.1	29.7	29.3	29.4	27.4	24.7	22.1	19.4	(28)	
	2%	WB	14.2	14.3	14.9	16.7	19.6	22.6	23.7	24.3	23.0	21.1	18.8	16.1	(29)	
		MCDB	16.1	16.5	17.4	21.0	24.6	28.1	28.5	28.5	26.2	23.7	21.3	18.3	(30)	
	5%	WB	13.4	13.5	14.2	16.0	18.9	21.9	23.2	23.7	22.4	20.5	18.0	15.1	(31)	
		MCDB	15.6	15.8	16.7	19.6	23.7	26.9	27.9	27.9	25.7	23.2	20.7	17.2	(32)	
	10%	WB	12.7	12.8	13.6	15.4	18.4	21.3	22.6	23.3	21.7	19.7	17.2	14.2	(33)	
		MCDB	15.0	15.2	16.2	18.8	22.9	26.5	27.4	27.4	25.3	22.7	19.9	16.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.9	5.3	6.2	7.1	7.7	8.1	7.6	6.7	5.9	5.2	4.4	(35)	
		MCDBR	4.9	5.4	6.0	7.8	8.9	9.6	9.6	9.2	7.9	6.7	6.0	4.9	(36)	
	5% WB	MCWBR	3.7	3.7	3.8	3.9	3.8	3.7	3.5	3.4	3.6	3.3	3.4	3.4	(37)	
		MCWBR	4.5	5.0	5.4	6.9	7.9	8.4	8.2	7.7	7.0	6.1	5.5	4.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.352	0.381	0.414	0.444	0.431	0.396	0.393	0.403	0.392	0.391	0.371	0.356	(40)	
		taud	2.440	2.341	2.235	2.179	2.274	2.416	2.422	2.389	2.427	2.401	2.420	2.445	(41)	
	Ebn at Noon	Ebn at Noon	830	845	848	841	856	884	884	869	861	824	800	798	(42)	
		Edh at Noon	87	107	130	145	134	116	115	116	106	100	88	82	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.28	3.10	4.60	5.96	7.11	7.98	7.97	7.12	5.79	4.16	2.83	2.08	(44)	
	RadStd	RadStd	0.23	0.25	0.26	0.41	0.30	0.23	0.11	0.11	0.21	0.19	0.19	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A

Nomenclature: See separate page