

KITHIRA, Greece

WMO: 167430

Lat: 36.274N

Lon: 23.017E

Elev: 319

StdP: 97.56

Time Zone: 2.00 (EUE)

Period: 90-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.4	(c) 5.6	(d) -4.0	(e) 2.8	(f) 6.8	(g) -2.0	(h) 3.3	(i) 7.4	(j) 25.8	(k) 6.8	(l) 22.7	(m) 7.4	(n) 9.1	(o) 40	(p) 0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.1	(c) 33.8	(d) 20.5	(e) 32.1	(f) 20.3	(g) 30.8	(h) 19.7	(i) 23.6	(j) 28.2	(k) 23.0	(l) 27.5	(m) 22.3	(n) 26.9	(o) 5.3	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	17.5	26.0	21.5	16.8	25.8	20.8	16.1	25.5	72.2	28.1	69.7	27.5	67.3	27.1	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 18.8	(b) 15.2	(c) 13.1	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 18.8	(b) 15.2	(c) 13.1	(d) WB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	11.2	11.3	12.3	15.4	18.9	23.9	26.6	27.1	23.8	20.1	16.3	12.4
	DBStd	6.30	2.56	2.65	2.67	2.51	2.82	2.77	2.65	2.22	2.30	2.79	2.47	2.71
	HDD10.0	55	18	15	9	1	0	0	0	0	0	0	1	11
	HDD18.3	999	222	198	189	96	28	0	0	0	0	14	68	183
	CDD10.0	3083	54	51	80	161	276	416	513	529	414	313	190	86
	CDD18.3	986	0	0	1	7	46	166	255	271	164	69	7	0
	CDH23.3	7364	0	0	1	16	124	1104	2433	2663	887	136	1	0
(13)	CDH26.7	2270	0	0	0	1	13	301	867	913	146	29	0	0
(14)	Wind	WSAvg	5.4	6.2	6.2	6.0	5.0	4.8	4.4	4.7	4.9	5.8	5.4	6.6
(15) Precipitation	PrecAvg	554	98	69	47	26	12	2	1	5	19	41	116	117
	PrecMax	902	226	141	115	71	65	11	4	30	84	163	298	238
	PrecMin	342	25	6	0	2	0	0	0	1	1	2	48	18
	PrecStd	146	55	38	31	22	14	3	1	7	22	44	57	54
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	19.2	21.1	25.2	28.2	33.4	37.7	35.7	32.2	30.6	22.7	19.7
		MCWB	14.5	12.8	13.5	15.1	18.3	18.9	19.8	20.2	20.6	16.3	18.1	16.2
	2%	DB	16.1	16.7	18.3	22.7	26.3	31.2	34.2	33.6	29.7	26.0	21.5	17.9
		MCWB	13.4	12.8	12.9	14.2	17.2	19.2	20.6	20.6	19.4	19.3	17.3	14.9
	5%	DB	15.4	15.6	16.5	20.8	24.8	29.7	32.1	32.1	28.1	24.5	20.5	16.9
		MCWB	12.7	12.6	12.6	13.2	16.6	19.0	20.3	20.4	19.9	19.3	17.0	13.7
	10%	DB	14.7	14.7	15.4	19.1	23.3	28.3	30.8	30.8	27.0	23.4	19.7	16.0
		MCWB	12.1	12.2	12.5	13.1	16.2	18.6	19.7	20.0	19.7	19.1	16.5	13.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	14.5	15.0	16.9	20.2	22.8	24.5	24.8	23.9	22.0	19.8	16.6
		MCDB	16.7	15.9	17.4	22.6	25.5	29.1	30.9	29.3	27.1	23.8	22.1	18.7
	2%	WB	14.1	13.7	14.2	15.5	18.8	21.6	23.4	23.7	22.8	21.3	18.3	15.4
		MCDB	15.5	15.3	16.2	19.0	23.4	27.4	28.3	28.3	26.5	23.5	20.2	17.1
	5%	WB	13.2	13.2	13.6	14.8	18.0	20.8	22.7	23.1	22.1	20.6	17.5	14.7
		MCDB	14.9	15.0	15.5	18.0	22.1	26.0	27.4	27.8	25.7	23.2	19.8	16.1
	10%	WB	12.4	12.6	13.0	14.2	17.3	20.1	22.0	22.5	21.5	19.8	16.9	13.9
		MCDB	14.4	14.6	15.0	17.4	21.3	25.4	27.2	27.4	25.3	22.9	19.4	15.9
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.7	3.8	4.7	5.0	6.2	6.3	6.1	5.1	4.1	3.8	3.7
		MCDBR	4.1	4.6	5.3	7.7	7.1	7.8	8.4	7.8	6.4	5.4	4.6	4.9
		MCWBR	3.3	3.3	3.6	4.7	5.0	4.9	5.1	5.2	4.6	3.6	3.2	3.5
	5% WB	MCDBR	3.5	3.5	4.3	5.7	6.1	6.8	6.7	6.3	5.5	4.4	3.9	3.6
		MCWBR	3.4	3.1	3.4	4.2	5.0	5.1	5.0	4.9	4.4	3.8	3.3	3.4
(40) Clear-Sky Solar Irradiance	taub		0.347	0.372	0.411	0.437	0.426	0.399	0.404	0.413	0.408	0.393	0.373	0.356
	taud		2.457	2.363	2.239	2.185	2.278	2.395	2.389	2.364	2.379	2.388	2.408	2.429
	Ebn at Noon		842	858	853	848	861	881	874	861	846	825	801	802
	Edh at Noon		86	106	130	145	134	119	119	120	112	102	90	84
(44) All-Sky Solar Radiation	RadAvg		2.29	3.09	4.54	5.92	6.91	7.75	7.79	6.96	5.54	3.87	2.63	2.01
	RadStd		0.20	0.28	0.29	0.40	0.29	0.27	0.14	0.12	0.25	0.24	0.23	0.18

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page