

CHANIA SOUDA, Greece

WMO: 167460

Lat: 35.532N

Lon: 24.150E

Elev: 490

StdP: 14.44

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.7	42.7	29.8	24.3	48.0	32.4	27.3	48.1	30.6	54.4	27.0	54.2	8.5	0	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	95.1	71.0	91.8	70.2	89.6	69.8	75.8	86.2	74.4	84.4	73.1	83.1	9.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.0	124.7	81.7	71.5	118.2	80.1	69.9	112.0	78.8	39.7	86.2	38.3	84.4	37.1	82.8	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.7	21.6	19.1	DB	36.1	102.2	3.1	3.5	33.9	104.7	32.1	106.8	30.3	108.8	28.1	111.4	(4)
(5)			WB	34.2	78.2	3.0	3.1	32.0	80.5	30.3	82.3	28.6	84.1	26.4	86.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.7	52.4	52.9	56.0	61.1	68.6	76.2	80.3	80.2	75.1	68.0	61.2	55.1	(6)	
	DBStd	11.11	4.64	5.07	5.10	5.15	4.93	4.71	3.68	3.14	4.06	4.90	4.91	4.88	(7)	
	HDD50	76	29	25	9	0	0	0	0	0	0	0	1	12	(8)	
	HDD65	1641	391	341	285	140	19	0	0	0	0	25	132	308	(9)	
	CDD50	5792	103	106	193	332	577	786	941	935	753	557	338	171	(10)	
	CDD65	1883	0	1	5	22	131	336	476	470	304	117	19	2	(11)	
	CDH74	16230	1	4	29	147	832	3001	5014	4649	2031	457	59	6	(12)	
	CDH80	6184	0	0	8	37	208	1134	2201	1908	598	84	5	1	(13)	
(14) Wind	WSAvg	7.9	8.3	8.8	9.1	8.7	8.3	8.2	7.9	7.4	7.3	6.7	6.7	7.5	(14)	
(15) Precipitation	PrecAvg	23.4	4.6	3.9	2.7	1.1	0.4	0.1	0.0	0.1	0.6	2.2	3.5	4.7	(15)	
	PrecMax	39.8	9.4	10.8	8.7	3.8	2.5	0.6	0.4	0.8	3.8	6.2	7.6	10.6	(16)	
	PrecMin	11.2	1.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	1.1	(17)	
	PrecStd	7.3	2.3	2.5	2.0	0.9	0.6	0.1	0.1	0.2	0.8	1.8	2.0	2.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	72.0	77.1	85.6	89.8	99.1	100.8	97.2	94.7	86.6	80.3	72.6	(19)	
		MCWB	55.6	57.1	59.5	62.4	65.5	68.8	70.0	69.6	71.7	66.4	61.9	59.3	(20)	
	2%	DB	64.4	66.6	71.3	77.3	85.3	92.3	95.3	93.4	89.2	82.2	75.1	67.7	(21)	
		MCWB	54.7	55.4	56.8	59.7	64.3	69.4	71.2	70.6	69.7	67.4	62.7	58.1	(22)	
	5%	DB	62.1	64.0	67.8	73.7	82.0	88.9	91.8	91.2	85.9	78.7	71.7	64.7	(23)	
		MCWB	54.2	54.6	56.3	58.9	63.4	68.1	70.5	70.8	69.8	66.8	62.1	56.9	(24)	
	10%	DB	59.6	60.9	64.4	70.0	78.6	86.1	89.5	88.3	82.8	75.6	69.1	62.6	(25)	
		MCWB	53.2	53.7	55.5	58.3	62.7	67.6	70.1	70.7	69.1	65.8	61.1	56.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	59.4	61.6	66.6	70.0	76.3	78.7	77.4	76.0	71.6	67.3	61.8	(27)	
		MCDB	64.1	66.7	69.8	77.3	81.7	89.9	92.0	88.0	86.6	78.9	74.1	67.9	(28)	
	2%	WB	56.1	57.0	59.3	63.4	67.4	72.8	75.8	75.7	73.8	69.6	65.0	59.6	(29)	
		MCDB	61.7	64.3	66.6	73.4	77.8	84.8	86.7	85.2	83.3	76.8	70.9	65.3	(30)	
	5%	WB	54.9	55.5	57.7	61.2	66.0	71.1	74.0	74.5	72.1	68.3	63.3	58.0	(31)	
		MCDB	60.2	61.9	64.7	69.4	76.0	82.1	84.6	83.8	80.7	75.3	69.0	63.4	(32)	
	10%	WB	53.7	54.1	56.2	59.5	64.7	69.7	72.6	73.4	70.8	67.1	61.7	56.6	(33)	
		MCDB	58.9	60.0	62.7	66.7	74.2	81.1	83.2	83.0	79.2	73.8	67.5	61.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.7	12.9	14.5	16.1	16.8	16.5	15.7	14.6	12.9	11.9	10.6	(35)	
		MCDBR	14.1	16.0	18.2	20.0	20.7	20.4	20.4	19.5	18.8	16.2	15.5	13.8	(36)	
	5% WB	MCWBR	8.6	9.5	10.2	10.4	9.4	9.5	9.2	8.6	8.9	7.8	8.5	8.6	(37)	
		MCWBR	13.1	14.4	15.7	17.2	17.9	17.9	17.8	16.3	16.3	14.7	14.0	12.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.365	0.393	0.439	0.471	0.456	0.415	0.415	0.421	0.428	0.413	0.391	0.377	(40)	
		taud	2.383	2.279	2.131	2.064	2.163	2.330	2.338	2.320	2.301	2.308	2.332	2.344	(41)	
	Ebn at Noon		261	266	262	260	265	275	274	271	263	256	248	247	(42)	
		Edh at Noon	30	37	46	52	48	40	40	40	39	35	31	29	(43)	
(44) All-Sky Solar Radiation	RadAvg		721	967	1419	1867	2185	2479	2475	2218	1780	1249	853	632	(44)	
	RadStd		62	95	96	123	84	76	36	46	75	71	67	50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.85	+0.90	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.54	N/A	+2.16	N/A	+1.26	+1.35	N/A	-115	+193	N/A

Nomenclature: See separate page