

CHANIA SOUDA, Greece

WMO: 167460

Lat: 35.532N

Lon: 24.150E

Elev: 149

StdP: 99.54

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.8	6.0	-1.2	3.5	8.9	0.2	3.9	8.9	13.7	12.5	12.1	12.3	3.8	0	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	35.0	21.6	33.2	21.2	32.0	21.0	24.4	30.1	23.6	29.1	22.9	28.4	4.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.8	17.8	27.6	21.9	16.9	26.7	21.1	16.0	26.0	74.4	30.1	71.1	29.1	68.4	28.2	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.6	8.5	2.3	39.0	1.7	2.0	1.0	40.4	0.0	41.6	-0.9	42.7	-2.2	44.1		
			1.2	25.7	1.7	1.7	0.0	26.9	-1.0	27.9	-1.9	28.9	-3.1	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	11.3	11.6	13.3	16.1	20.3	24.5	26.9	26.8	24.0	20.0	16.2	12.8
	DBStd	6.17	2.58	2.81	2.83	2.86	2.74	2.62	2.04	1.75	2.25	2.72	2.73	2.71
	HDD10.0	42	16	14	5	0	0	0	0	0	0	0	1	7
	HDD18.3	912	217	189	158	78	11	0	0	0	0	14	73	171
	CDD10.0	3218	57	59	107	184	321	437	523	519	418	309	188	95
	CDD18.3	1046	0	1	3	12	73	187	264	261	169	65	11	1
	CDH23.3	9017	1	2	16	82	462	1667	2786	2583	1128	254	33	3
	CDH26.7	3436	0	0	4	21	116	630	1223	1060	332	47	3	1
Wind	WSAvg	3.5	3.7	3.9	4.1	3.9	3.7	3.6	3.5	3.3	3.3	3.0	3.0	3.4
Precipitation	PrecAvg	594	117	99	69	27	10	2	1	2	15	55	88	119
	PrecMax	1012	239	275	220	97	64	15	10	21	96	157	192	269
	PrecMin	284	27	5	1	0	0	0	0	0	0	0	14	27
	PrecStd	186	59	63	52	23	15	3	2	5	21	45	50	69
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	22.2	25.1	29.8	32.1	37.3	38.2	36.2	34.9	30.4	26.8	22.6
		MCWB	13.1	14.0	15.3	16.9	18.6	20.4	21.1	20.9	22.1	19.1	16.6	15.2
	2%	DB	18.0	19.2	21.8	25.2	29.6	33.5	35.2	34.1	31.8	27.9	23.9	19.8
		MCWB	12.6	13.0	13.8	15.4	17.9	20.8	21.8	21.4	20.9	19.7	17.1	14.5
	5%	DB	16.7	17.8	19.9	23.1	27.8	31.6	33.2	32.9	29.9	26.0	22.1	18.2
		MCWB	12.3	12.5	13.5	15.0	17.5	20.1	21.4	21.6	21.0	19.3	16.7	13.8
	10%	DB	15.3	16.1	18.0	21.1	25.9	30.1	32.0	31.3	28.2	24.2	20.6	17.0
		MCWB	11.8	12.1	13.1	14.6	17.0	19.8	21.1	21.5	20.6	18.8	16.2	13.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	15.2	16.4	19.2	21.1	24.6	25.9	25.2	24.4	22.0	19.6	16.6
		MCDB	17.8	19.3	21.0	25.2	27.6	32.2	33.3	31.1	30.3	26.0	23.4	20.0
	2%	WB	13.4	13.9	15.2	17.5	19.7	22.7	24.3	24.3	23.2	20.9	18.3	15.3
		MCDB	16.5	18.0	19.2	23.0	25.5	29.3	30.4	29.5	28.5	24.9	21.6	18.5
	5%	WB	12.7	13.0	14.3	16.2	18.9	21.7	23.3	23.6	22.3	20.2	17.4	14.5
		MCDB	15.7	16.6	18.2	20.8	24.4	27.8	29.2	28.8	27.1	24.1	20.5	17.5
	10%	WB	12.1	12.3	13.4	15.3	18.2	20.9	22.6	23.0	21.6	19.5	16.5	13.7
		MCDB	15.0	15.6	17.0	19.3	23.4	27.3	28.4	28.3	26.2	23.2	19.7	16.5
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.5	7.2	8.1	9.0	9.3	9.2	8.7	8.1	7.2	6.6	5.9
		MCDBR	7.8	8.9	10.1	11.1	11.5	11.3	11.3	10.8	10.4	9.0	8.6	7.6
		MCWBR	4.8	5.3	5.6	5.8	5.2	5.3	5.1	4.8	4.9	4.4	4.7	4.8
	5% WB	MCDBR	7.3	8.0	8.7	9.6	9.9	9.9	9.9	9.0	8.2	7.8	7.1	7.1
		MCWBR	4.9	5.3	5.5	5.7	5.2	5.2	5.2	4.5	4.8	4.4	4.8	4.8
Clear-Sky Solar Irradiance	taub	0.365	0.393	0.439	0.471	0.456	0.415	0.415	0.421	0.428	0.413	0.391	0.377	
	taud	2.383	2.279	2.131	2.064	2.163	2.330	2.338	2.320	2.301	2.308	2.332	2.344	
	Ebn at Noon	822	837	827	819	836	868	865	855	829	806	782	778	
	Edh at Noon	94	116	146	164	151	127	126	125	122	111	98	92	
All-Sky Solar Radiation	RadAvg	2.27	3.05	4.47	5.88	6.89	7.82	7.80	6.99	5.61	3.94	2.69	1.99	
	RadStd	0.20	0.30	0.30	0.39	0.27	0.24	0.11	0.14	0.24	0.22	0.21	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+0.47	+0.50	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.30	N/A	+1.20	N/A	+0.70	+0.75	N/A	-64	+107	N/A

Nomenclature: See separate page