

RHODES DIAGORAS, Greece

WMO: 167490

Lat: 36.405N

Lon: 28.086E

Elev: 6

StdP: 101.26

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.1	7.8	-4.7	2.5	8.1	-2.2	3.2	9.1	11.7	11.6	10.4	11.2	5.6	310	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	32.5	22.8	31.4	22.9	30.6	22.9	25.5	29.3	24.9	28.8	24.4	28.3	6.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.1	27.8	23.8	18.7	27.5	23.1	17.8	27.2	78.3	29.1	76.1	28.8	74.0	28.3	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.2	8.4	4.1	35.3	2.1	1.8	2.6	36.5	1.3	37.6	0.1	38.6	-1.4	39.8		
(5)			0.8	26.8	1.8	0.9	-0.5	27.5	-1.6	28.0	-2.6	28.6	-3.9	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	12.8	13.0	14.6	17.1	20.9	24.9	27.1	27.6	25.4	21.7	17.7	14.4	(6)
(7)		DBStd	5.71	2.40	2.37	2.17	2.11	2.03	2.04	1.53	1.31	1.65	2.17	2.46	2.43	(7)
(8)		HDD10.0	16	7	5	1	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	650	172	148	116	47	3	0	0	0	0	3	38	123	(9)
(10)		CDD10.0	3595	94	90	144	214	337	446	532	546	461	363	231	138	(10)
(11)		CDD18.3	1187	0	0	1	11	82	196	273	288	211	107	19	1	(11)
(12)		CDH23.3	9355	0	0	1	23	237	1413	2786	3066	1513	304	13	0	(12)
(13)	CDH26.7	2593	0	0	0	1	27	344	903	1007	291	20	0	0	(13)	
(14)	Wind	WSAvg	4.1	3.4	3.5	3.8	3.9	4.2	5.1	5.6	5.5	4.7	3.4	2.7	3.1	(14)
(15)	Precipitation	PrecAvg	672	137	100	66	39	21	1	1	8	51	92	147	(15)	
(16)		PrecMax	1002	293	204	139	172	148	7	4	5	59	212	275	335	(16)
(17)		PrecMin	327	0	23	3	4	0	0	0	0	4	4	0	(17)	
(18)		PrecStd	154	69	52	44	34	30	2	1	1	14	48	61	75	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.6	19.2	21.9	26.0	29.1	33.0	34.1	34.5	32.1	28.8	25.0	20.7	(19)
(20)			MCWB	14.9	14.9	16.2	16.7	19.2	21.8	22.3	23.3	22.8	21.2	19.5	17.1	(20)
(21)		2%	DB	17.8	18.1	20.0	23.3	27.1	31.1	32.3	32.4	30.1	27.0	23.2	19.8	(21)
(22)			MCWB	14.4	14.2	14.9	16.6	19.3	21.7	22.5	23.5	22.6	21.0	18.6	16.3	(22)
(23)		5%	DB	17.0	17.2	18.9	22.0	25.8	29.9	31.2	31.2	29.1	26.0	22.2	18.9	(23)
(24)			MCWB	13.9	13.9	14.7	16.3	19.2	21.5	22.5	23.8	22.5	20.5	18.1	15.6	(24)
(25)		10%	DB	16.2	16.7	18.0	20.8	24.5	28.8	30.2	30.3	28.2	25.0	21.2	18.0	(25)
(26)			MCWB	13.2	13.6	14.3	16.0	19.2	21.3	22.5	23.7	22.2	20.2	17.6	14.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.1	17.4	19.6	22.8	24.7	25.9	26.4	25.2	23.3	20.9	17.9	(27)
(28)			MADB	17.6	17.9	20.1	23.2	25.0	28.5	29.3	30.0	28.8	26.0	22.9	19.9	(28)
(29)		2%	WB	15.1	15.1	16.1	18.0	21.2	23.7	25.1	25.8	24.4	22.4	19.7	16.9	(29)
(30)			MADB	16.9	17.2	18.6	21.3	24.5	27.4	28.9	29.6	28.0	25.2	22.1	18.9	(30)
(31)		5%	WB	14.4	14.5	15.4	17.2	20.5	23.0	24.4	25.2	23.7	21.6	18.9	16.0	(31)
(32)			MADB	16.3	16.7	17.9	20.3	23.9	26.9	28.4	29.1	27.4	24.5	21.5	18.0	(32)
(33)		10%	WB	13.7	13.8	14.8	16.5	19.7	22.4	23.8	24.7	23.1	20.9	18.1	15.2	(33)
(34)			MADB	15.8	16.2	17.4	19.6	23.2	26.7	28.0	28.7	26.9	23.9	20.8	17.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.0	5.4	5.9	6.0	6.1	6.0	5.7	5.4	5.4	5.5	4.9	(35)
(36)			MADB	5.2	5.5	6.4	7.9	7.7	7.6	7.2	6.6	6.1	6.0	6.1	5.4	(36)
(37)			MCWBR	3.7	4.0	4.1	4.7	4.7	4.0	3.7	3.7	3.8	3.5	3.7	3.6	(37)
(38)		5% WB	MADB	4.7	5.1	5.8	6.6	6.3	6.3	6.1	5.7	5.5	5.6	5.5	4.9	(38)
(39)			MCWBR	3.9	4.1	4.2	4.6	4.6	4.1	4.1	3.7	4.1	3.9	4.0	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.359	0.389	0.424	0.457	0.444	0.407	0.406	0.421	0.400	0.400	0.376	0.360	(40)	
(41)		taud	2.426	2.321	2.205	2.141	2.238	2.388	2.389	2.343	2.404	2.383	2.410	2.443	(41)	
(42)		Ebn at Noon	825	838	839	830	846	875	873	853	854	817	796	797	(42)	
(43)		Edh at Noon	89	110	135	151	139	120	119	122	109	102	90	83	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.37	3.22	4.70	6.04	7.15	8.01	7.99	7.15	5.89	4.25	2.92	2.18	(44)	
(45)		RadStd	0.24	0.26	0.27	0.40	0.32	0.21	0.12	0.10	0.21	0.21	0.19	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.30	N/A	N/A	+0.39	N/A	N/A	N/A	-41	+116	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-58	N/A	N/A

Nomenclature: See separate page