

KARPATOS, Greece

WMO: 167650

Lat: 35.428N

Lon: 27.147E

Elev: 20

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.2	46.1	26.5	20.4	46.5	30.2	24.4	47.9	40.7	52.1	36.8	51.6	19.0	340	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	87.7	73.5	85.9	73.7	84.3	73.3	76.5	83.0	75.6	82.0	74.9	81.2	18.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.8	130.4	80.0	73.5	124.9	79.6	72.9	122.3	79.4	40.0	83.1	39.1	82.2	38.4	81.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.5	33.7	31.3	DB	38.6	94.4	4.2	2.8	35.6	96.4	33.2	98.1	30.8	99.7	27.8	101.8	(4)
(5)			WB	34.2	78.7	2.7	1.5	32.3	79.8	30.7	80.7	29.2	81.5	27.2	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	55.5	56.3	58.4	62.7	68.5	75.4	79.2	80.1	76.6	71.1	64.6	58.4	(6)	
	DBStd	9.45	4.88	4.30	3.88	3.23	3.29	2.98	2.20	1.77	2.78	3.20	4.23	4.34	(7)	
	HDD50	29	16	7	3	0	0	0	0	0	0	0	0	3	(8)	
	HDD65	1098	296	243	207	84	5	0	0	0	0	3	55	205	(9)	
	CDD50	6343	185	184	262	381	575	763	906	933	798	653	438	265	(10)	
	CDD65	1937	0	0	1	15	115	313	441	468	348	191	43	2	(11)	
	CDH74	11950	0	0	0	16	224	1692	3506	3996	2078	428	10	0	(12)	
	CDH80	2354	0	0	0	0	29	268	816	926	304	11	0	0	(13)	
(14) Wind	WSAvg	16.4	15.1	14.9	14.3	13.7	15.6	18.9	23.1	22.8	17.3	14.8	12.2	14.4	(14)	
(15) Precipitation	PrecAvg	21.1	3.9	3.3	2.0	1.2	0.8	0.3	0.2	0.2	0.6	1.8	2.8	4.1	(15)	
	PrecMax	28.7	8.7	6.4	4.8	2.6	1.7	0.5	0.6	0.4	2.2	5.6	5.0	6.9	(16)	
	PrecMin	12.4	1.3	1.0	0.4	0.2	0.3	0.1	0.1	0.1	0.2	0.3	1.1	0.6	(17)	
	PrecStd	4.4	1.7	1.4	1.1	0.6	0.4	0.1	0.1	0.1	0.5	1.3	1.2	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	66.4	70.0	75.6	83.4	88.1	91.4	89.8	88.0	81.0	75.3	68.7	(19)	
		MCWB	60.9	60.9	59.8	61.8	65.4	71.0	71.7	74.3	72.8	70.0	67.5	62.1	(20)	
	2%	DB	64.4	64.6	66.6	73.2	78.9	84.6	87.6	87.4	84.6	79.0	73.5	67.7	(21)	
		MCWB	58.2	58.3	59.2	62.1	66.3	71.6	73.3	74.7	72.8	69.7	65.6	61.2	(22)	
	5%	DB	62.9	63.0	65.7	70.1	76.6	82.7	85.7	85.8	82.8	77.4	71.9	66.2	(23)	
		MCWB	57.2	57.3	58.8	61.7	66.2	71.2	73.2	74.9	72.2	69.1	64.7	59.9	(24)	
	10%	DB	62.3	62.5	64.3	68.1	73.8	80.9	84.1	84.3	81.6	76.7	70.4	64.7	(25)	
		MCWB	56.8	57.0	57.8	60.5	65.2	70.4	72.9	74.2	71.7	68.6	63.9	58.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.9	62.8	62.1	65.6	69.8	75.3	77.3	78.2	77.1	74.4	69.0	64.6	(27)	
		MCDB	64.9	65.5	66.3	71.9	76.4	83.0	84.1	83.9	82.8	77.4	73.2	67.7	(28)	
	2%	WB	59.7	60.2	60.9	63.9	68.5	73.9	76.1	76.9	75.3	72.6	67.5	62.3	(29)	
		MCDB	63.2	62.8	64.9	69.6	74.9	80.6	82.7	83.4	81.1	76.5	71.5	66.3	(30)	
	5%	WB	58.1	59.0	59.9	62.8	67.4	72.8	75.1	76.0	74.3	71.1	66.6	60.6	(31)	
		MCDB	62.1	62.1	64.0	67.6	73.6	79.2	81.6	82.5	80.2	75.7	70.7	65.0	(32)	
	10%	WB	56.8	57.6	58.9	61.6	66.5	71.9	74.3	75.3	73.2	69.6	65.2	59.2	(33)	
		MCDB	61.3	61.6	63.1	66.4	72.5	78.8	81.0	81.7	79.2	75.0	69.9	64.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.3	8.9	9.8	10.1	10.5	9.8	9.0	9.1	9.2	9.1	8.1	(35)	
		MCDBR	8.7	8.5	9.9	12.5	13.0	12.5	11.8	10.6	10.4	10.1	9.5	8.7	(36)	
	5% WB	MCWBR	6.5	6.4	6.8	7.5	6.1	6.2	5.3	4.7	5.9	6.4	6.2	6.1	(37)	
		MCWBR	8.1	7.3	9.0	10.9	11.3	11.5	10.3	9.8	10.0	9.6	8.9	8.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.364	0.395	0.430	0.465	0.454	0.412	0.409	0.419	0.413	0.407	0.385	0.367	(40)	
		taud	2.413	2.300	2.184	2.109	2.200	2.372	2.381	2.350	2.370	2.361	2.383	2.420	(41)	
	Ebn at Noon		262	265	265	262	266	276	276	272	268	258	252	253	(42)	
		Edh at Noon	29	36	44	50	46	39	38	39	36	34	30	27	(43)	
(44) All-Sky Solar Radiation	RadAvg		790	1045	1517	1927	2250	2505	2482	2225	1840	1348	935	715	(44)	
	RadStd		61	80	87	105	92	57	29	28	59	60	63	54	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.58	N/A	N/A	N/A	+0.72	+0.61	N/A	-108	+198	N/A

Nomenclature: See separate page