

INEBOLU, Turkey

WMO: 170240

Lat: 41.9789N

Lon: 33.7629E

Elev: 210

StdP: 14.58

Time Zone: 3.00 (E03)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.9	31.0	20.7	15.7	34.2	23.3	17.7	35.3	32.5	48.3	28.9	44.7	11.4	160	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.9	84.6	75.0	82.7	73.4	81.1	72.4	76.7	83.1	75.0	81.4	73.4	79.9	5.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.5	130.0	82.3	72.7	122.1	80.5	71.0	115.2	78.9	40.3	83.2	38.7	81.4	37.2	80.0	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	20.4	17.7	23.9	88.0	3.0	3.7	21.8	90.7	20.0	92.9	18.3	95.0	16.2	97.7		
(5)			22.2	77.5	2.7	1.5	20.2	78.5	18.6	79.4	17.1	80.2	15.2	81.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.8	43.8	42.9	45.8	51.2	59.8	67.2	72.3	73.4	66.9	59.6	52.3	45.7		
	DBStd	12.22	6.97	7.18	7.06	6.25	5.55	3.89	3.11	3.12	4.16	5.62	6.12	7.29		
	HDD50	886	220	221	174	50	1	0	0	0	0	4	42	174		
	HDD65	3683	659	619	595	418	181	19	0	0	28	183	383	598		
	CDD50	3375	26	22	44	87	304	517	690	725	506	301	111	42		
	CDD65	698	0	0	1	5	18	86	225	260	84	16	2	1		
	CDH74	3918	0	0	3	22	86	337	1400	1725	296	41	5	3		
	CDH80	614	0	0	0	4	17	33	194	346	13	7	0	0		
(14) Wind	WSAvg	8.0	8.4	8.3	7.9	6.5	6.6	7.6	8.1	8.0	8.7	8.0	8.9	9.3		
(15) Precipitation	PrecAvg	39.6	4.7	3.4	2.8	2.0	2.0	1.8	1.7	2.6	3.3	4.9	5.0	5.5		
	PrecMax	53.2	10.2	12.4	6.0	4.5	4.5	3.8	8.1	8.6	7.9	11.6	9.9	11.3		
	PrecMin	24.6	0.7	0.4	0.4	0.1	0.4	0.4	0.0	0.2	0.0	1.0	1.7	2.5		
	PrecStd	7.4	2.3	2.2	1.5	1.1	1.1	0.9	1.9	2.2	2.2	2.8	2.2	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.4	66.6	70.8	77.3	82.3	82.7	86.1	87.8	81.9	78.8	73.6	69.3		
		MCWB	51.6	51.8	54.5	59.0	65.2	70.0	76.4	78.3	72.3	63.8	57.6	55.6		
	2%	DB	61.8	61.3	63.9	70.1	75.5	79.8	83.7	85.3	79.2	73.8	68.2	64.6		
		MCWB	49.9	49.1	51.2	57.5	63.5	70.4	74.8	76.3	70.0	64.7	56.4	53.3		
	5%	DB	58.3	57.6	60.1	64.2	71.8	77.6	82.1	83.5	77.3	71.1	64.2	60.7		
		MCWB	48.3	47.8	50.2	54.7	62.7	68.9	73.6	74.7	69.2	63.5	55.7	50.8		
	10%	DB	53.6	53.5	56.6	59.9	68.6	75.6	80.6	81.8	75.3	68.4	61.1	56.9		
		MCWB	46.5	46.6	48.9	53.1	61.4	67.9	72.8	73.2	68.0	62.1	55.0	48.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	53.7	55.6	60.7	67.7	74.3	78.2	80.1	74.1	68.8	61.1	56.6		
		MCDB	63.3	64.9	67.6	73.3	77.0	80.0	84.4	86.5	79.8	74.1	66.6	65.3		
	2%	WB	50.6	50.3	52.7	57.7	65.2	71.9	76.4	77.6	71.9	66.4	58.9	54.1		
		MCDB	59.0	58.6	62.1	68.4	72.5	77.7	82.4	84.2	77.3	72.0	64.3	62.3		
	5%	WB	49.0	48.5	50.9	55.6	63.6	70.1	74.9	75.6	70.3	64.5	57.2	51.9		
		MCDB	55.7	55.8	58.4	62.9	70.3	76.0	81.0	82.4	75.8	70.0	62.6	58.2		
	10%	WB	47.5	46.8	49.4	53.8	62.0	68.4	73.4	73.9	68.6	62.5	55.5	50.1		
		MCDB	52.7	52.7	55.6	58.9	67.8	74.4	79.7	80.9	74.2	67.2	60.2	55.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.6	10.8	10.9	12.1	13.8	14.9	14.9	13.9	12.1	12.0	10.7		
		MCDBR	15.3	16.2	16.7	17.7	16.4	16.6	16.8	17.4	16.6	15.0	15.6	14.8		
	5% WB	MCWBR	8.3	8.4	8.4	8.7	9.9	12.0	12.8	13.8	12.3	10.5	10.2	8.7		
		MCWBR	13.2	14.6	14.6	14.7	13.9	15.0	15.3	16.3	15.3	13.6	12.8	12.8		
(40) Clear-Sky Solar Irradiance	taub		0.364	0.400	0.445	0.489	0.456	0.433	0.443	0.449	0.426	0.410	0.373	0.359		
	taud		2.282	2.175	2.069	1.996	2.169	2.293	2.283	2.255	2.294	2.281	2.329	2.317		
	Ebn at Noon		240	248	251	249	262	268	264	258	255	243	235	230		
	Edh at Noon		29	37	47	54	47	41	41	41	37	33	28	26		
(44) All-Sky Solar Radiation	RadAvg		494	736	1116	1526	1865	2149	2210	1939	1440	947	626	434		
	RadStd		52	102	88	165	181	166	118	125	127	91	69	54		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	-175	-236	N/A	+94

Nomenclature: See separate page