

EDIRNE, Turkey

WMO: 170500

Lat: 41.6766N

Lon: 26.5506E

Elev: 167

StdP: 14.61

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	22.9	10.0	9.2	21.2	14.6	11.6	25.7	16.1	44.2	13.9	40.2	4.9	340	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.2	96.7	70.2	93.9	69.9	91.3	69.2	73.6	90.1	72.1	88.5	70.8	86.8	5.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	105.6	79.6	66.9	99.5	78.0	65.5	94.9	77.1	37.2	90.4	35.8	88.7	34.7	86.7	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	10.7	9.4	DB	15.6	100.8	4.2	4.0	12.6	103.7	10.1	106.0	7.7	108.2	4.7	111.1	(4)
(5)			WB	14.8	75.8	4.0	2.3	11.8	77.5	9.5	78.9	7.2	80.2	4.3	81.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.1	38.1	42.1	47.8	56.3	66.1	73.3	77.9	78.0	69.4	58.6	49.4	39.9	(6)	
	DBStd	15.65	8.31	8.25	7.41	6.44	5.77	5.35	4.11	4.58	6.15	6.83	7.61	8.88	(7)	
	HDD50	1216	380	240	133	19	0	0	0	0	12	101	331		(8)	
	HDD65	3832	835	641	534	266	58	4	0	31	217	469	777		(9)	
	CDD50	4191	10	19	64	209	498	698	864	867	582	278	83	19	(10)	
	CDD65	1331	0	0	0	5	91	253	399	402	163	17	1	0	(11)	
	CDH74	14323	0	0	3	82	933	2689	4565	4454	1467	126	4	0	(12)	
	CDH80	6501	0	0	0	14	246	1156	2280	2262	524	19	0	0	(13)	
(14) Wind	WSAvg	4.0	3.9	4.6	4.6	4.3	4.0	3.8	4.0	3.9	3.7	3.5	3.5	3.9	(14)	
(15) Precipitation	PrecAvg	23.7	2.6	2.2	2.1	1.9	2.0	1.8	1.3	0.9	1.5	2.2	2.7	2.8	(15)	
	PrecMax	34.0	7.2	7.3	5.8	4.4	6.7	6.3	4.2	4.6	5.3	6.2	8.6	6.5	(16)	
	PrecMin	15.2	0.0	0.1	0.2	0.1	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.2	(17)	
	PrecStd	4.6	1.8	1.5	1.5	1.0	1.3	1.4	1.1	0.9	1.5	1.7	1.8	1.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.0	65.8	72.4	82.6	89.3	97.4	101.1	99.9	93.6	82.6	73.4	65.7	(19)	
		MCWB	55.7	55.6	57.6	62.2	67.1	70.7	71.5	69.7	68.5	67.4	63.1	60.5	(20)	
	2%	DB	58.1	61.8	67.7	76.4	85.6	93.2	96.8	96.7	89.4	77.4	67.8	60.3	(21)	
		MCWB	53.7	53.3	55.9	59.9	65.9	69.5	70.3	70.1	67.6	64.0	60.0	56.4	(22)	
	5%	DB	54.4	58.5	64.0	72.5	82.6	90.0	93.7	94.0	86.0	73.8	64.3	56.5	(23)	
		MCWB	50.5	51.9	53.7	58.2	64.4	69.0	69.9	70.2	66.7	62.7	58.3	53.0	(24)	
	10%	DB	50.2	54.7	60.1	68.9	79.6	86.9	90.9	91.3	82.7	70.3	60.8	52.8	(25)	
		MCWB	47.6	49.7	51.8	56.4	63.4	68.0	69.2	69.3	65.7	61.1	55.6	50.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.0	57.8	59.5	63.7	70.2	73.9	75.0	76.5	71.9	69.3	65.4	60.7	(27)	
		MCDB	60.3	63.6	69.1	77.7	84.8	90.3	93.9	91.8	86.6	78.0	69.4	64.7	(28)	
	2%	WB	53.9	54.9	56.9	61.3	67.9	71.9	73.2	73.9	69.7	66.1	61.4	56.7	(29)	
		MCDB	57.5	59.6	65.0	73.8	81.3	88.0	90.1	90.2	82.5	74.0	66.8	59.9	(30)	
	5%	WB	51.0	52.5	54.8	59.3	66.1	70.3	71.9	72.0	68.3	64.0	59.0	53.5	(31)	
		MCDB	53.9	57.5	61.9	70.2	78.9	86.4	88.7	88.8	81.0	70.8	63.5	56.2	(32)	
	10%	WB	47.7	49.9	52.9	57.5	64.4	69.0	70.7	70.4	66.9	62.0	56.7	50.3	(33)	
		MCDB	50.0	54.4	59.2	67.0	76.7	84.2	87.0	86.6	79.8	68.8	60.1	52.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	15.2	17.5	19.9	22.6	23.5	24.2	24.1	21.9	17.9	15.1	11.7	(35)	
		MCDBR	17.1	21.4	23.0	25.4	27.8	27.9	28.7	28.2	27.3	23.0	19.9	14.6	(36)	
		MCWBR	12.5	13.6	12.7	12.0	11.6	10.1	9.4	9.2	10.3	11.7	12.2	11.3	(37)	
	5% WB	MCDBR	16.3	19.1	20.8	22.2	24.6	25.7	25.1	25.6	23.8	20.5	17.6	13.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.352	0.383	0.426	0.473	0.447	0.447	0.446	0.453	0.435	0.405	0.377	0.358	(40)	
		taud	2.328	2.228	2.125	2.006	2.159	2.200	2.211	2.189	2.211	2.274	2.301	2.301	(41)	
		Ebn at Noon	246	256	258	254	264	264	263	257	252	245	234	231	(42)	
	Edh at Noon		28	36	44	54	47	45	44	44	40	34	29	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		504	758	1125	1544	1940	2115	2195	1967	1458	948	593	443	(44)	
	RadStd		61	77	97	159	127	160	118	85	102	92	63	63	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.85	N/A	N/A	N/A	+1.12	+1.28	-144	-225	+178	+95

Nomenclature: See separate page