

CORLU, Turkey

WMO: 170540

Lat: 41.133N

Lon: 27.917E

Elev: 525

StdP: 14.42

Time Zone: 3.00 (E03)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	25.1	15.9	12.5	24.0	19.6	15.0	27.1	33.6	31.3	30.3	32.9	14.3	0	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.1	91.2	69.9	88.2	69.5	86.1	69.4	73.8	84.3	72.6	82.4	71.4	80.3	12.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	117.5	77.2	69.8	111.8	76.5	68.3	105.8	75.7	37.8	84.2	36.5	81.4	35.5	80.5	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.9	24.9	22.4	DB	18.0	95.6	4.9	3.2	14.5	98.0	11.7	99.9	8.9	101.7	5.4	104.0	
			WB	16.7	75.6	4.7	1.7	13.3	76.8	10.6	77.8	7.9	78.7	4.5	79.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.5	39.3	41.1	46.1	53.7	63.0	71.1	75.4	76.6	68.8	59.5	51.4	42.7
	DBStd	14.37	7.76	7.99	6.62	6.12	5.31	4.82	3.54	3.70	5.19	5.99	7.07	7.13
	HDD50	1103	338	262	155	30	0	0	0	0	0	8	66	244
	HDD65	3804	797	671	585	340	100	6	0	0	23	183	408	691
	CDD50	3842	6	12	36	143	404	634	788	823	564	304	109	19
	CDD65	1065	0	0	0	2	39	190	323	358	138	14	1	0
	CDH74	8749	0	0	0	37	301	1532	2823	3072	903	79	2	0
	CDH80	2974	0	0	0	2	43	465	1012	1206	236	10	0	0
Wind	WSAvg	10.6	10.5	11.6	10.5	9.7	9.3	9.9	11.3	12.5	11.2	10.6	9.6	10.4
Precipitation	PrecAvg	22.6	1.9	2.1	2.0	1.7	1.9	1.3	1.2	0.9	1.6	2.2	2.9	3.0
	PrecMax	27.9	7.4	4.1	3.9	4.0	5.0	3.2	3.3	4.4	4.8	7.5	8.0	7.2
	PrecMin	16.9	0.2	0.4	0.7	0.4	0.2	0.1	0.0	0.0	0.0	0.1	0.9	0.6
	PrecStd	3.1	1.7	1.0	0.9	0.9	1.3	0.9	0.9	1.1	1.3	1.9	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	64.1	68.1	78.8	84.4	91.8	94.8	94.8	89.8	80.5	73.2	64.5
		MCWB	52.7	55.4	55.8	60.8	65.7	70.8	69.8	69.9	68.9	66.0	61.7	56.6
	2%	DB	55.6	59.0	64.4	73.3	80.6	87.8	90.0	91.5	85.8	75.6	68.2	59.3
		MCWB	50.2	52.7	54.2	60.0	64.7	69.7	69.5	69.8	67.5	63.6	59.7	54.5
	5%	DB	53.3	55.6	60.9	69.5	77.2	84.6	87.8	89.3	82.4	72.0	64.6	55.8
		MCWB	48.7	50.4	52.8	58.1	63.6	68.0	69.2	69.9	66.5	61.9	57.9	52.1
	10%	DB	50.2	52.1	57.3	65.8	74.8	82.3	85.7	86.3	79.1	69.5	61.2	53.4
		MCWB	47.2	48.2	50.6	55.7	62.4	67.0	69.6	69.7	65.2	61.0	56.4	50.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	56.2	57.7	62.8	68.5	74.6	75.3	75.4	72.6	67.4	63.1	57.4
		MCDB	58.1	62.5	65.7	75.4	79.6	86.5	85.9	85.3	84.1	76.3	70.4	63.4
	2%	WB	51.2	53.0	55.2	60.3	66.5	72.0	73.7	73.9	70.3	65.2	60.5	54.9
		MCDB	55.1	58.1	62.3	70.8	77.3	82.3	83.6	84.3	79.1	73.2	66.6	58.9
	5%	WB	49.2	51.0	53.1	58.2	64.6	70.2	72.3	72.8	68.6	63.4	58.6	52.8
		MCDB	52.3	55.3	60.0	67.5	74.6	80.7	81.9	82.6	77.2	70.1	63.9	56.3
	10%	WB	47.4	48.9	51.1	56.4	63.0	68.8	71.0	71.8	67.3	61.9	56.8	50.7
		MCDB	50.1	52.2	56.5	64.5	72.5	78.8	80.5	80.2	75.7	67.7	61.5	53.2
Mean Daily Temperature Range	5% DB	MDBR	11.9	12.6	15.6	18.2	18.7	18.7	19.0	19.1	18.0	15.2	13.8	12.1
		MCDBR	14.7	17.6	21.0	23.4	22.6	22.0	22.3	22.4	22.0	20.1	17.0	14.9
		MCWBR	10.4	11.9	13.0	13.5	11.4	9.3	8.7	7.7	8.4	10.1	9.9	10.9
	5% WB	MCDBR	14.0	16.7	19.7	21.5	20.3	19.9	19.2	19.0	19.3	18.1	15.9	14.0
		MCWBR	10.4	11.6	12.7	13.1	11.0	9.1	8.4	7.0	8.1	9.8	9.5	10.5
Clear-Sky Solar Irradiance	taub	0.362	0.392	0.428	0.468	0.434	0.428	0.430	0.437	0.426	0.407	0.378	0.367	
	taud	2.326	2.219	2.134	2.039	2.215	2.273	2.279	2.258	2.270	2.289	2.315	2.304	
	Ebn at Noon	245	254	258	256	268	270	268	262	256	246	236	230	
	Edh at Noon	28	36	44	52	44	42	42	41	38	34	29	27	
All-Sky Solar Radiation	RadAvg	479	703	1106	1558	1978	2194	2269	1980	1452	940	597	431	
	RadStd	66	90	102	167	136	157	94	95	107	90	75	62	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.37	N/A	N/A	N/A	+2.09	+1.84	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+1.03	N/A	N/A	N/A	N/A	N/A	-104	-227	+229	+121

Nomenclature: See separate page