

CORLU, Turkey

WMO: 170540

Lat: 41.133N

Lon: 27.917E

Elev: 160

StdP: 99.42

Time Zone: 3.00 (E03)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-3.9	-8.9	1.8	-4.4	-6.9	2.1	-2.7	15.0	-0.4	13.5	0.5	6.4	0	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.6	32.9	21.1	31.2	20.8	30.1	20.8	23.2	29.1	22.6	28.0	21.9	26.8	5.4	30

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.8	16.8	25.1	21.0	16.0	24.7	20.1	15.1	24.3	69.9	29.0	67.0	27.5	64.6	26.9	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.5	11.1	10.0	DB	-7.8	35.4	2.7	1.8	-9.7	36.6	-11.3	37.7	-12.8	38.7	-14.8	40.0	(4)
			WB	-8.5	24.2	2.6	0.9	-10.4	24.9	-11.9	25.4	-13.4	26.0	-15.3	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	4.0	5.0	7.9	12.1	17.2	21.7	24.1	24.8	20.5	15.3	10.8	6.0	(6)
(7)		DBStd	7.98	4.31	4.44	3.68	3.40	2.95	2.68	1.97	2.05	2.89	3.33	3.93	3.96	(7)
(8)		HDD10.0	613	188	146	86	17	0	0	0	0	4	37	136	(8)	
(9)		HDD18.3	2113	443	373	325	189	56	3	0	13	102	227	384	(9)	
(10)		CDD10.0	2134	3	7	20	79	224	352	438	457	313	169	61	11	(10)
(11)		CDD18.3	592	0	0	0	1	22	106	179	199	77	8	1	0	(11)
(12)		CDH23.3	4861	0	0	0	21	167	851	1568	1707	502	44	1	0	(12)
(13)		CDH26.7	1652	0	0	0	1	24	258	562	670	131	6	0	0	(13)
(14)	Wind	WSAvg	4.7	4.7	5.2	4.7	4.3	4.2	4.4	5.0	5.6	5.0	4.7	4.3	4.6	(14)
(15)	Precipitation	PrecAvg	573	47	53	51	44	47	34	31	23	40	57	73	76	(15)
(16)		PrecMax	708	187	105	99	101	128	81	85	111	121	191	202	184	(16)
(17)		PrecMin	430	6	10	17	10	6	3	0	0	3	22	15	(17)	
(18)		PrecStd	80	42	26	24	24	34	24	22	27	34	48	42	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	17.8	20.1	26.0	29.1	33.2	34.9	34.9	32.1	27.0	22.9	18.0	(19)
(20)			MCWB	11.5	13.0	13.2	16.0	18.7	21.6	21.0	21.1	20.5	18.9	16.5	13.7	(20)
(21)		2%	DB	13.1	15.0	18.0	22.9	27.0	31.0	32.2	33.1	29.9	24.2	20.1	15.2	(21)
(22)			MCWB	10.1	11.5	12.3	15.6	18.2	20.9	20.8	21.0	19.7	17.6	15.4	12.5	(22)
(23)		5%	DB	11.8	13.1	16.1	20.8	25.1	29.2	31.0	31.8	28.0	22.2	18.1	13.2	(23)
(24)			MCWB	9.3	10.2	11.6	14.5	17.5	20.0	20.7	21.1	19.2	16.6	14.4	11.2	(24)
(25)		10%	DB	10.1	11.2	14.0	18.8	23.8	28.0	29.8	30.1	26.2	20.8	16.2	11.9	(25)
(26)			MCWB	8.4	9.0	10.3	13.2	16.9	19.4	20.9	21.0	18.4	16.1	13.6	10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	13.4	14.3	17.1	20.3	23.7	24.1	24.1	22.6	19.6	17.3	14.1	(27)
(28)			MCDWB	14.5	17.0	18.7	24.1	26.5	30.3	29.9	29.6	28.9	24.6	21.3	17.5	(28)
(29)		2%	WB	10.7	11.7	12.9	15.7	19.1	22.2	23.2	23.3	21.3	18.4	15.8	12.7	(29)
(30)			MCDWB	12.8	14.5	16.8	21.6	25.2	28.0	28.7	29.0	26.2	22.9	19.2	15.0	(30)
(31)		5%	WB	9.6	10.6	11.7	14.6	18.1	21.2	22.4	22.7	20.3	17.5	14.8	11.6	(31)
(32)			MCDWB	11.3	12.9	15.5	19.7	23.7	27.1	27.7	28.1	25.1	21.2	17.7	13.5	(32)
(33)		10%	WB	8.6	9.4	10.6	13.5	17.2	20.4	21.7	22.1	19.6	16.6	13.8	10.4	(33)
(34)			MCDWB	10.1	11.2	13.6	18.1	22.5	26.0	26.9	26.8	24.3	19.9	16.4	11.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.6	7.0	8.7	10.1	10.4	10.6	10.6	10.0	8.5	7.6	6.7	(35)	
(36)			MCDBR	8.2	9.8	11.6	13.0	12.6	12.2	12.4	12.2	11.2	9.4	8.3	(36)	
(37)			MCWBR	5.8	6.6	7.2	7.5	6.3	5.2	4.8	4.3	4.7	5.6	5.5	6.1	(37)
(38)		5% WB	MCDBR	7.8	9.3	11.0	12.0	11.3	11.1	10.7	10.6	10.7	10.0	8.8	7.8	(38)
(39)			MCWBR	5.8	6.4	7.1	7.3	6.1	5.1	4.7	3.9	4.5	5.4	5.3	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.362	0.392	0.428	0.468	0.434	0.428	0.430	0.437	0.426	0.407	0.378	0.367	(40)	
(41)		taud	2.326	2.219	2.134	2.039	2.215	2.273	2.279	2.258	2.270	2.289	2.315	2.304	(41)	
(42)		Ebn at Noon	771	800	813	807	846	850	844	826	808	775	743	726	(42)	
(43)		Edh at Noon	89	114	139	164	140	133	131	130	120	106	90	85	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.51	2.22	3.49	4.91	6.24	6.92	7.15	6.24	4.58	2.96	1.88	1.36	(44)	
(45)		RadStd	0.21	0.28	0.32	0.53	0.43	0.49	0.30	0.30	0.34	0.28	0.23	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	+0.76	N/A	N/A	N/A	+1.16	+1.02	N/A	N/A	N/A	N/A
		+0.57	N/A	N/A	N/A	N/A	N/A	-58	-126	+127	+67

Nomenclature: See separate page