

TEKIRDAG, Turkey

WMO: 170560

Lat: 40.9580N

Lon: 27.4960E

Elev: 3

StdP: 101.29

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.5	-1.8	-8.1	1.9	-2.4	-5.9	2.3	-0.8	9.7	9.6	8.5	8.6	3.1	320	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	30.9	23.6	29.7	23.1	28.7	22.9	25.6	29.0	24.7	28.2	23.9	27.5	3.9	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	19.6	28.3	23.5	18.4	27.5	22.6	17.3	26.6	79.0	29.1	75.2	28.3	71.6	27.6	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.2	-6.3	34.1	2.4	2.7	-8.0	36.1	-9.4	37.7	-10.7	39.3	-12.5	41.3		
(5)			-7.2	26.8	2.3	1.4	-8.9	27.8	-10.2	28.7	-11.5	29.5	-13.2	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	5.5	6.3	8.6	12.4	17.3	21.8	24.3	24.8	20.8	16.1	11.6	7.3	(6)
(7)		DBStd	7.51	3.87	3.89	3.64	3.28	2.85	2.43	1.83	2.04	2.55	3.13	3.60	4.17	(7)
(8)		HDD10.0	474	146	114	72	14	0	0	0	0	0	2	25	102	(8)
(9)		HDD18.3	1909	398	338	303	181	53	2	0	0	9	81	203	341	(9)
(10)		CDD10.0	2219	6	10	28	84	226	353	444	459	325	192	72	20	(10)
(11)		CDD18.3	612	0	0	1	1	21	106	186	201	83	12	1	0	(11)
(12)		CDH23.3	4226	0	0	2	3	53	597	1508	1699	338	25	1	0	(12)
(13)		CDH26.7	925	0	0	0	0	7	102	341	443	30	2	0	0	(13)
(14)	Wind	WSAvg	2.5	2.5	2.7	2.6	2.2	2.2	2.4	2.7	3.0	2.5	2.5	2.4	2.6	(14)
(15)	Precipitation	PrecAvg	566	72	49	53	43	38	38	21	16	30	48	74	87	(15)
(16)		PrecMax	779	157	125	128	114	87	114	86	78	133	136	201	184	(16)
(17)		PrecMin	405	1	9	3	7	0	1	0	0	0	0	21	1	(17)
(18)		PrecStd	110	45	32	31	26	22	28	19	18	37	34	46	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	18.0	20.9	23.2	27.3	31.7	32.7	32.7	29.4	25.7	21.5	19.2	(19)
(20)			MCWB	12.9	13.1	14.2	16.3	18.9	22.4	23.2	24.6	22.1	20.5	17.4	15.0	(20)
(21)		2%	DB	13.6	15.1	17.6	20.7	24.6	29.2	30.6	31.1	27.2	23.6	19.4	16.7	(21)
(22)			MCWB	11.5	11.9	13.0	15.5	19.4	22.8	23.5	24.2	22.0	20.1	16.7	14.1	(22)
(23)		5%	DB	11.8	13.0	15.3	18.6	23.1	27.6	29.5	30.0	26.3	22.1	18.0	14.5	(23)
(24)			MCWB	10.3	10.8	12.2	14.7	18.7	22.1	23.1	23.2	21.5	19.2	15.8	12.9	(24)
(25)		10%	DB	10.6	11.3	13.5	17.1	21.9	26.4	28.5	29.0	25.3	20.8	16.6	13.0	(25)
(26)			MCWB	9.4	9.8	11.3	14.0	18.1	21.5	22.7	23.2	20.9	18.0	14.5	11.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	13.8	15.7	17.8	22.0	26.2	26.7	27.1	24.8	22.8	19.5	15.8	(27)
(28)			MCDWB	15.5	16.9	18.5	21.3	24.1	28.2	29.9	30.6	27.1	23.9	19.9	18.1	(28)
(29)		2%	WB	11.7	12.2	13.6	16.2	20.6	24.1	25.4	25.8	23.3	21.1	17.0	14.2	(29)
(30)			MCDWB	13.2	14.4	16.5	19.1	23.0	27.2	29.0	29.3	26.0	22.3	18.7	16.2	(30)
(31)		5%	WB	10.5	11.0	12.4	15.2	19.5	22.9	24.4	25.0	22.3	19.6	15.9	13.0	(31)
(32)			MCDWB	11.7	12.6	14.9	17.9	22.2	26.4	28.2	28.6	25.2	21.5	17.7	14.4	(32)
(33)		10%	WB	9.5	9.9	11.4	14.3	18.5	22.0	23.4	24.2	21.6	18.5	14.8	11.7	(33)
(34)			MCDWB	10.5	11.2	13.4	16.8	21.4	25.7	27.5	27.9	24.6	20.5	16.3	12.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.6	6.3	6.6	7.1	7.7	7.9	7.7	7.2	6.4	6.1	5.5	(35)
(36)			MCDBR	6.8	8.0	8.9	8.9	8.6	9.1	8.8	8.5	8.2	7.6	7.1	7.0	(36)
(37)			MCWBR	5.2	5.5	5.8	5.7	5.5	5.6	5.5	5.3	5.3	5.2	5.2	5.4	(37)
(38)		5% WB	MCDBR	6.6	7.3	8.1	8.1	7.9	8.4	8.1	7.8	7.5	7.1	6.6	6.4	(38)
(39)			MCWBR	5.3	5.2	5.6	5.8	5.8	6.1	6.0	5.7	5.5	5.6	5.4	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.372	0.403	0.444	0.487	0.452	0.444	0.445	0.452	0.440	0.421	0.391	0.378	(40)	
(41)		taud	2.294	2.183	2.082	1.985	2.164	2.230	2.236	2.216	2.227	2.247	2.276	2.271	(41)	
(42)		Ebn at Noon	759	787	797	790	830	836	831	813	794	759	727	712	(42)	
(43)		Edh at Noon	92	119	147	173	148	139	137	136	126	110	94	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.57	2.29	3.55	4.99	6.31	6.98	7.26	6.36	4.69	3.03	1.92	1.41	(44)	
(45)		RadStd	0.21	0.27	0.33	0.54	0.44	0.50	0.33	0.30	0.34	0.30	0.23	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.54	N/A	N/A	N/A	N/A	N/A	-65	-130	+118	+63

Nomenclature: See separate page