

CORUM, Turkey

WMO: 170840

Lat: 40.5459N

Lon: 34.9364E

Elev: 2546

StdP: 13.39

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	16.7	6.0	8.2	13.6	10.8	10.5	19.6	15.1	45.7	12.8	41.4	1.9	180	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	29.3	93.7	64.9	90.2	64.9	86.9	64.2	68.3	85.5	67.0	83.9	65.7	82.2	5.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	94.3	74.4	61.4	89.2	73.3	59.9	84.7	72.3	34.0	85.8	33.0	83.3	31.9	82.4	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.5	12.4	10.9	DB	5.4	99.6	7.9	3.6	-0.3	102.2	-4.9	104.3	-9.3	106.3	-15.0	109.0	
			WB	5.0	70.3	7.7	2.2	-0.6	71.9	-5.1	73.2	-9.4	74.4	-15.0	76.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	32.8	36.1	42.8	51.5	59.1	65.2	70.5	71.5	64.5	55.1	43.5	35.7	(6)
	DBStd	14.94	8.33	8.11	7.15	6.93	6.05	4.80	4.84	4.85	5.98	6.80	6.86	7.16	(7)
	HDD50	1918	534	389	239	63	6	0	0	0	0	29	212	446	(8)
	HDD65	5111	998	808	687	408	198	54	7	7	80	310	645	909	(9)
	CDD50	2811	0	1	17	107	287	457	635	666	435	188	17	1	(10)
	CDD65	533	0	0	0	2	14	61	178	208	65	5	0	0	(11)
	CDH74	7795	0	0	3	73	402	1048	2466	2628	1016	159	0	0	(12)
	CDH80	3047	0	0	0	7	90	329	1067	1154	372	28	0	0	(13)
(14) Wind	WSAvg	3.6	2.6	3.0	3.9	4.1	3.6	4.2	5.2	5.0	3.8	2.9	2.2	2.4	(14)
(15) Precipitation	PrecAvg	17.4	1.6	1.2	1.6	2.0	2.5	2.1	0.7	0.6	0.9	1.1	1.4	1.9	(15)
	PrecMax	25.0	3.7	2.9	3.6	4.3	8.7	8.1	2.8	3.7	3.5	4.1	4.0	5.0	(16)
	PrecMin	9.6	0.1	0.1	0.0	0.1	0.2	0.2	0.0	0.0	0.0	0.0	0.1	0.1	(17)
	PrecStd	3.3	0.9	0.7	0.7	1.0	1.4	1.4	0.8	0.8	0.9	0.9	0.9	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	62.6	71.9	80.6	87.3	93.0	98.8	98.9	93.8	83.6	68.5	57.6	(19)
		MCWB	45.5	47.3	51.9	57.3	63.1	64.5	65.5	64.2	62.0	59.4	52.6	48.3	(20)
	2%	DB	50.4	57.1	65.9	75.6	82.2	87.2	93.8	93.6	88.7	78.7	64.3	52.6	(21)
		MCWB	43.2	46.1	49.6	55.5	60.9	63.7	65.4	65.7	62.1	58.1	50.9	45.5	(22)
	5%	DB	47.1	53.1	61.5	71.3	78.5	83.7	90.0	89.9	84.2	73.9	59.9	49.1	(23)
		MCWB	41.7	44.4	47.9	53.8	59.6	63.1	65.4	65.5	61.0	56.9	48.9	44.1	(24)
	10%	DB	43.7	49.1	57.2	66.8	74.6	80.2	86.1	86.5	79.9	69.2	55.9	46.0	(25)
		MCWB	40.0	42.4	46.3	52.1	58.6	61.8	64.4	65.0	60.5	55.5	47.5	42.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	49.5	53.7	59.6	64.9	67.7	70.4	70.2	65.9	62.0	54.5	49.5	(27)
		MCDB	52.2	58.6	68.0	76.2	82.0	83.7	88.1	87.1	84.1	77.5	65.2	55.7	(28)
	2%	WB	44.0	46.9	50.8	56.9	62.6	65.7	68.2	68.5	64.1	59.6	52.1	46.8	(29)
		MCDB	49.0	54.4	62.3	72.0	77.8	82.0	86.0	85.5	81.0	73.2	60.5	51.0	(30)
	5%	WB	42.2	45.1	48.9	55.0	60.9	64.2	66.8	67.3	62.7	58.0	50.1	44.8	(31)
		MCDB	46.5	52.2	59.1	67.8	75.6	79.8	84.2	84.1	79.2	70.5	58.2	48.5	(32)
	10%	WB	40.3	43.0	47.0	53.1	59.3	62.8	65.5	66.1	61.4	56.5	48.2	42.8	(33)
		MCDB	43.7	48.8	56.3	64.7	72.6	77.7	82.2	82.3	76.4	67.5	55.0	45.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	18.0	21.0	24.2	26.1	27.5	29.9	29.3	28.3	24.3	21.8	14.5	(35)
		MCDBR	19.5	24.8	29.8	32.8	33.9	34.4	36.2	35.0	36.2	32.8	29.1	20.1	(36)
		MCWBR	13.1	14.9	15.8	15.5	15.2	13.8	13.3	12.8	14.4	15.4	16.7	13.5	(37)
	5% WB	MCDBR	17.5	22.6	26.2	29.0	29.9	30.2	31.4	29.8	30.1	28.1	24.8	17.4	(38)
		MCWBR	12.1	13.8	14.5	14.5	13.9	12.8	12.1	11.6	12.6	13.7	14.6	12.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.308	0.337	0.377	0.416	0.393	0.370	0.372	0.375	0.352	0.353	0.319	0.307	(40)
	taud		2.373	2.315	2.233	2.150	2.292	2.382	2.381	2.356	2.420	2.398	2.452	2.429	(41)
	Ebn at Noon		269	276	276	272	281	287	285	281	282	267	264	260	(42)
	Edh at Noon		27	33	40	47	41	38	37	37	33	30	25	23	(43)
(44) All-Sky Solar Radiation	RadAvg		579	896	1231	1603	1922	2195	2291	2056	1605	1074	733	496	(44)
	RadStd		67	151	130	166	164	167	100	103	108	89	77	64	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-247	+182	+112	

Nomenclature: See separate page