

ERZINCAN, Turkey

WMO: 170920

Lat: 39.716N

Lon: 39.525E

Elev: 3786

StdP: 12.79

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	8.3	-2.4	5.6	3.7	3.0	7.4	11.8	25.1	40.4	21.7	40.0	0.6	250	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	30.6	95.2	63.5	92.8	63.6	89.7	63.4	68.9	87.3	67.0	85.4	65.5	83.7	5.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	98.1	78.6	60.6	91.1	75.6	58.8	85.3	74.5	35.5	87.4	33.9	85.7	32.5	84.1	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	16.8	14.3	DB	-2.0	99.5	10.2	2.2	-9.4	101.1	-15.4	102.4	-21.1	103.6	-28.5	105.2	(4)
(5)			WB	-2.7	70.8	10.0	3.7	-9.9	73.4	-15.7	75.6	-21.3	77.6	-28.6	80.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	28.0	31.9	41.9	51.6	59.9	67.7	74.3	74.7	65.7	55.1	42.2	32.3		
	DBStd	17.39	9.61	9.12	7.02	6.57	5.41	4.79	4.23	3.86	5.36	6.09	6.49	8.99		
	HDD50	2328	684	506	266	55	2	0	0	0	0	23	242	550		
	HDD65	5462	1149	926	717	405	175	28	1	0	54	308	684	1015		
	CDD50	3136	0	0	13	103	308	530	753	766	473	182	8	0		
	CDD65	794	0	0	0	2	16	107	289	301	76	3	0	0		
	CDH74	10871	0	0	0	30	316	1469	3693	3873	1375	115	0	0		
	CDH80	4750	0	0	0	2	49	486	1789	1922	491	11	0	0		
(14) Wind	WSAvg	4.4	3.3	4.1	5.9	5.7	4.9	5.3	5.4	4.8	4.0	3.1	3.0	3.4		
(15) Precipitation	PrecAvg	15.3	1.1	1.2	1.7	2.1	2.2	1.2	0.4	0.3	0.6	1.7	1.5	1.1		
	PrecMax	24.6	3.3	2.5	3.9	3.8	5.4	2.8	2.4	2.2	1.8	5.2	4.9	3.5		
	PrecMin	9.8	0.0	0.2	0.0	0.4	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.1		
	PrecStd	3.1	0.8	0.7	0.8	0.9	1.1	0.6	0.5	0.4	0.4	1.1	1.1	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	56.3	67.2	77.4	84.6	91.8	98.7	98.8	92.9	81.6	64.7	54.9		
		MCWB	40.8	43.2	48.3	53.5	58.7	63.1	64.7	64.4	60.0	57.3	49.2	43.5		
	2%	DB	45.5	51.5	62.6	73.3	80.8	88.1	95.4	95.7	89.0	77.3	61.0	50.0		
		MCWB	38.8	40.9	46.6	52.4	57.7	62.7	64.1	63.4	59.7	56.0	47.6	41.7		
	5%	DB	42.9	47.5	59.0	69.3	77.4	85.6	92.9	93.2	85.7	73.4	57.5	47.0		
		MCWB	37.1	39.3	45.3	51.2	56.4	61.5	64.1	63.5	59.4	54.6	46.0	40.4		
	10%	DB	40.7	44.4	55.1	65.5	74.0	82.5	89.6	90.0	82.4	69.4	54.3	44.5		
		MCWB	35.7	37.9	43.8	49.8	55.6	60.8	64.0	64.0	58.7	53.3	44.8	39.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.9	44.0	50.3	56.5	62.5	68.3	72.4	71.9	66.2	60.2	51.6	45.5		
		MCDB	47.1	53.5	62.3	71.2	79.2	85.1	90.3	90.8	82.9	75.3	60.8	52.9		
	2%	WB	39.5	41.7	47.9	54.1	59.7	65.6	69.2	69.1	63.1	57.7	49.3	43.0		
		MCDB	44.2	49.1	59.9	68.5	75.2	82.4	87.7	87.6	81.4	71.7	57.5	47.9		
	5%	WB	38.0	40.0	46.2	52.5	58.1	63.8	67.3	67.1	61.2	56.1	47.5	41.4		
		MCDB	42.0	46.1	56.9	65.8	73.1	80.9	86.3	85.4	79.4	68.7	55.0	45.7		
	10%	WB	36.2	38.4	44.3	50.9	56.7	62.1	65.7	65.5	59.6	54.3	45.8	39.7		
		MCDB	39.9	43.6	53.4	62.7	70.8	78.7	84.2	83.8	77.4	66.1	53.1	43.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.4	17.1	19.1	21.0	23.9	26.9	29.4	30.6	30.2	24.9	21.5	16.6		
		MCDBR	17.2	21.5	25.9	28.5	30.2	31.9	34.6	35.5	36.3	32.8	27.8	19.2		
		MCWBR	11.1	12.5	12.6	12.2	11.4	10.9	10.9	10.9	12.8	13.9	15.2	11.9		
	5% WB	MCDBR	14.8	18.8	21.8	24.0	26.4	28.8	29.6	30.2	30.9	27.1	22.2	16.0		
		MCWBR	9.8	11.4	11.1	10.8	10.9	11.4	11.7	11.5	12.4	12.2	12.5	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.312	0.353	0.413	0.467	0.436	0.386	0.383	0.395	0.351	0.387	0.333	0.307		
	taud		2.165	2.025	1.966	1.934	2.094	2.296	2.326	2.277	2.381	2.201	2.313	2.267		
	Ebn at Noon		265	267	263	257	268	282	282	275	283	254	257	259		
	Edh at Noon		33	44	53	58	50	41	40	41	34	37	29	28		
(44) All-Sky Solar Radiation	RadAvg		723	1049	1335	1494	1831	2263	2344	2078	1700	1102	754	597		
	RadStd		84	143	128	176	136	134	115	93	104	96	102	107		

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+1.82	-1.62	-1.85	N/A	N/A	N/A	N/A	(46)
(47)	Regional (7 neighbors)	N/A	N/A	N/A	+0.97	-0.81	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page