

ERZINCAN, Turkey

WMO: 170920

Lat: 39.716N

Lon: 39.525E

Elev: 1154

StdP: 88.21

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-13.2	-19.1	0.8	-15.7	-16.1	1.1	-11.2	11.2	4.7	9.7	4.5	0.2	250	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	35.1	17.5	33.8	17.5	32.0	17.4	20.5	30.7	19.5	29.7	18.6	28.7	2.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	14.0	25.9	15.9	13.0	24.2	14.9	12.2	23.6	64.8	30.8	60.9	29.8	57.8	28.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.5	6.4	-18.9	37.5	5.7	1.2	-23.0	38.4	-26.3	39.1	-29.5	39.8	-33.6	40.7		
(5)			-19.3	21.5	5.6	2.1	-23.3	23.0	-26.5	24.2	-29.6	25.4	-33.7	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-2.2	0.0	5.5	10.9	15.5	19.8	23.5	23.7	18.7	12.9	5.7	0.1	(6)
(7)		DBStd	9.66	5.34	5.07	3.90	3.65	3.01	2.66	2.35	2.14	2.98	3.38	3.61	4.99	(7)
(8)		HDD10.0	1293	380	281	148	31	1	0	0	0	0	13	134	306	(8)
(9)		HDD18.3	3034	638	514	398	225	97	16	1	0	30	171	380	564	(9)
(10)		CDD10.0	1742	0	0	7	57	171	294	418	426	263	101	4	0	(10)
(11)		CDD18.3	441	0	0	0	1	9	59	161	167	42	2	0	0	(11)
(12)		CDH23.3	6039	0	0	0	17	176	816	2052	2152	764	64	0	0	(12)
(13)		CDH26.7	2639	0	0	0	1	27	270	994	1068	273	6	0	0	(13)
(14)	Wind	WSAvg	2.0	1.5	1.8	2.6	2.5	2.2	2.4	2.4	2.1	1.8	1.4	1.3	1.5	(14)
(15)	Precipitation	PrecAvg	389	29	30	42	53	57	30	11	8	14	43	38	29	(15)
(16)		PrecMax	626	84	63	100	96	138	70	61	55	46	131	124	90	(16)
(17)		PrecMin	248	1	4	1	9	12	2	0	0	0	0	0	3	(17)
(18)		PrecStd	79	21	17	21	22	28	16	13	10	11	29	27	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	13.5	19.6	25.2	29.2	33.2	37.0	37.1	33.8	27.5	18.2	12.7	(19)
(20)			MCWB	4.9	6.2	9.0	12.0	14.9	17.3	18.1	18.0	15.6	14.1	9.6	6.4	(20)
(21)		2%	DB	7.5	10.8	17.0	22.9	27.1	31.2	35.2	35.4	31.7	25.1	16.1	10.0	(21)
(22)			MCWB	3.8	4.9	8.1	11.4	14.3	17.0	17.8	17.4	15.4	13.3	8.6	5.4	(22)
(23)		5%	DB	6.1	8.6	15.0	20.7	25.2	29.8	33.8	34.0	29.8	23.0	14.2	8.3	(23)
(24)			MCWB	2.8	4.1	7.4	10.7	13.5	16.4	17.8	17.5	15.2	12.5	7.8	4.7	(24)
(25)		10%	DB	4.8	6.9	12.8	18.6	23.3	28.0	32.0	32.2	28.0	20.8	12.4	7.0	(25)
(26)			MCWB	2.0	3.3	6.5	9.9	13.1	16.0	17.8	17.8	14.8	11.8	7.1	4.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	6.7	10.2	13.6	16.9	20.2	22.4	22.2	19.0	15.7	10.9	7.5	(27)
(28)			MCDWB	8.4	11.9	16.9	21.8	26.2	29.5	32.4	32.7	28.3	24.1	16.0	11.6	(28)
(29)		2%	WB	4.2	5.4	8.8	12.3	15.4	18.7	20.7	20.6	17.3	14.3	9.6	6.1	(29)
(30)			MCDWB	6.8	9.5	15.5	20.3	24.0	28.0	31.0	30.9	27.5	22.0	14.1	8.8	(30)
(31)		5%	WB	3.3	4.4	7.9	11.4	14.5	17.6	19.6	19.5	16.2	13.4	8.6	5.2	(31)
(32)			MCDWB	5.6	7.9	13.8	18.8	22.9	27.1	30.1	29.7	26.3	20.4	12.8	7.6	(32)
(33)		10%	WB	2.4	3.5	6.8	10.5	13.7	16.7	18.7	18.6	15.3	12.4	7.7	4.3	(33)
(34)			MCDWB	4.4	6.4	11.9	17.1	21.6	25.9	29.0	28.8	25.2	19.0	11.7	6.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	9.5	10.6	11.7	13.3	14.9	16.3	17.0	16.8	13.8	11.9	9.2	(35)
(36)			MCDBR	9.5	11.9	14.4	15.9	16.8	17.7	19.2	19.7	20.1	18.2	15.5	10.7	(36)
(37)			MCWBR	6.2	6.9	7.0	6.8	6.3	6.1	6.0	6.0	7.1	7.7	8.5	6.6	(37)
(38)		5% WB	MCDBR	8.2	10.5	12.1	13.3	14.7	16.0	16.5	16.8	17.1	15.0	12.3	8.9	(38)
(39)			MCWBR	5.5	6.4	6.2	6.0	6.1	6.3	6.5	6.4	6.9	6.8	6.9	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.353	0.413	0.467	0.436	0.386	0.383	0.395	0.351	0.387	0.333	0.307	(40)	
(41)		taud	2.165	2.025	1.966	1.934	2.094	2.296	2.326	2.277	2.381	2.201	2.313	2.267	(41)	
(42)		Ebn at Noon	834	842	829	810	846	889	889	868	891	800	810	815	(42)	
(43)		Edh at Noon	104	139	166	183	159	130	125	128	108	116	90	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.28	3.31	4.21	4.71	5.77	7.13	7.39	6.55	5.36	3.48	2.38	1.88	(44)	
(45)		RadStd	0.26	0.45	0.40	0.56	0.43	0.42	0.36	0.29	0.33	0.30	0.32	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.01	-0.90	-1.03	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	+0.54	-0.45	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page