

YENISEHIR, Turkey

WMO: 171180

Lat: 40.255N

Lon: 29.563E

Elev: 233

StdP: 98.56

Time Zone: 3.00 (E03)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-4.9	-8.8	1.8	-6.3	-6.8	2.2	-2.6	10.9	10.7	9.7	9.6	1.0	20	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.5	34.2	20.6	32.9	20.5	31.4	20.2	22.9	30.6	22.1	29.5	21.4	28.6	4.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.5	26.6	19.8	14.9	26.1	19.0	14.1	25.2	69.1	30.4	65.9	29.4	63.3	28.9	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.8	6.9	DB	-11.4	37.9	4.1	1.8	-14.3	39.2	-16.7	40.2	-19.0	41.2	-22.0	42.4	(4)
			WB	-11.7	24.1	4.0	1.0	-14.6	24.9	-17.0	25.5	-19.3	26.1	-22.2	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	3.6	5.8	8.5	12.0	16.8	20.8	23.0	23.5	19.7	14.8	9.7	5.2
	DBStd	7.67	4.49	4.38	3.70	3.69	3.16	2.54	2.05	2.13	2.74	3.25	4.08	4.23
	HDD10.0	641	204	127	73	21	1	0	0	0	0	4	53	159
	HDD18.3	2174	458	350	306	190	67	6	0	0	17	115	259	406
	CDD10.0	1981	4	11	27	82	212	323	403	419	291	153	45	11
	CDD18.3	471	0	0	0	1	20	80	144	161	58	6	1	0
	CDH23.3	6170	0	1	4	80	369	1079	1853	1916	744	112	11	1
	CDH26.7	2517	0	0	1	12	99	423	823	872	268	21	0	0
Wind	WSAvg	2.3	2.5	2.6	2.5	2.3	2.2	2.4	2.8	2.7	2.3	1.8	1.9	2.3
Precipitation	PrecAvg	589	58	54	57	62	49	44	22	24	34	59	58	73
	PrecMax	782	108	110	104	172	143	119	68	95	83	144	121	204
	PrecMin	439	11	10	17	10	9	1	1	3	1	5	12	19
	PrecStd	99	29	26	21	35	31	28	19	23	25	34	29	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.9	21.0	23.2	28.1	31.9	35.8	36.8	36.2	35.0	29.2	25.0	20.5
		MCWB	10.6	12.5	13.1	16.8	18.9	21.0	21.3	20.4	20.0	16.8	14.7	12.7
	2%	DB	15.1	17.9	20.9	25.8	29.2	32.9	34.0	34.1	31.9	26.1	22.0	16.8
		MCWB	9.2	11.1	12.0	15.9	18.6	20.4	21.1	20.6	19.2	16.3	13.7	11.3
	5%	DB	13.1	15.8	18.9	23.2	27.2	30.9	32.2	32.8	29.8	24.0	19.5	14.1
		MCWB	8.4	10.1	11.4	14.7	17.7	19.6	20.6	20.9	18.8	15.9	13.0	10.1
	10%	DB	10.9	13.1	16.8	20.9	25.1	29.1	31.0	31.2	27.8	21.9	17.0	11.9
		MCWB	7.6	8.7	10.6	13.5	16.8	19.2	20.3	20.7	18.1	15.5	12.1	8.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	13.7	14.6	18.4	20.9	22.9	24.1	24.1	21.9	18.9	16.2	13.5
		MCDB	17.0	19.1	21.9	25.9	29.4	31.5	32.6	31.6	29.3	24.6	21.5	18.5
	2%	WB	9.8	11.7	12.8	16.6	19.4	21.7	22.8	23.1	20.9	17.8	14.5	11.8
		MCDB	14.4	16.6	18.7	24.5	26.8	29.2	30.8	30.5	28.1	23.5	20.5	15.7
	5%	WB	8.8	10.3	11.8	15.2	18.4	20.8	21.8	22.4	19.9	16.9	13.4	10.4
		MCDB	12.6	14.4	17.6	22.2	25.3	27.9	29.4	29.5	26.8	21.7	18.7	13.5
	10%	WB	7.7	9.3	10.8	13.9	17.6	19.9	21.2	21.7	19.1	16.1	12.3	9.3
		MCDB	10.5	12.8	15.6	19.9	23.9	27.3	28.7	28.5	25.4	20.4	16.8	11.8
Mean Daily Temperature Range	5% DB	MDBR	9.1	10.3	12.5	14.7	14.5	15.0	15.7	15.5	15.0	12.9	12.2	9.5
		MCDBR	12.5	14.8	17.5	19.5	18.5	18.5	18.2	17.7	19.5	17.6	15.6	11.7
		MCWBR	7.7	8.8	9.8	10.5	8.8	7.5	7.1	6.7	8.2	8.6	8.9	7.2
	5% WB	MCDBR	11.5	13.7	15.6	18.1	16.2	16.0	15.6	14.7	15.4	13.5	14.1	10.4
		MCWBR	7.4	8.3	9.0	10.1	8.3	7.1	6.7	6.1	6.9	7.1	8.5	6.6
Clear-Sky Solar Irradiance	taub	0.341	0.369	0.411	0.452	0.427	0.411	0.411	0.417	0.403	0.386	0.353	0.342	
	taud	2.380	2.293	2.187	2.093	2.237	2.322	2.332	2.314	2.341	2.370	2.414	2.406	
	Ebn at Noon	809	834	835	824	854	867	862	848	835	807	789	777	
	Edh at Noon	86	107	133	156	138	127	125	123	113	99	83	78	
All-Sky Solar Radiation	RadAvg	1.68	2.43	3.60	4.87	6.05	6.91	7.25	6.37	4.80	3.22	2.21	1.56	
	RadStd	0.24	0.36	0.35	0.55	0.53	0.64	0.29	0.40	0.39	0.28	0.28	0.23	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (15 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	-97	N/A	+46

Nomenclature: See separate page