

KIRSEHIR, Turkey

WMO: 171600

Lat: 39.1644N

Lon: 34.1558E

Elev: 1007

StdP: 89.80

Time Zone: 3.00 (E03)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-9.2	-15.4	1.1	-10.6	-12.6	1.4	-8.2	10.2	-0.1	8.6	-0.8	2.1	350	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	34.7	17.2	33.1	17.0	31.3	16.7	19.0	29.6	18.2	29.0	17.6	28.4	3.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.4	12.4	23.1	14.5	11.6	22.6	13.6	11.0	22.0	58.3	29.4	55.8	28.9	53.5	28.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.5	6.5	DB	-15.0	37.2	5.6	1.5	-19.0	38.3	-22.3	39.2	-25.4	40.0	-29.4	41.1	(4)
(5)			WB	-15.4	20.5	5.4	1.8	-19.3	21.8	-22.5	22.8	-25.5	23.9	-29.4	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	0.3	2.7	6.4	11.6	16.0	20.2	24.1	24.3	19.6	13.9	7.4	2.1	(6)
(7)		DBStd	9.11	5.13	4.94	4.24	3.70	3.21	2.98	2.86	2.75	3.20	3.94	4.01	4.74	(7)
(8)		HDD10.0	1009	301	207	124	25	1	0	0	0	0	12	94	245	(8)
(9)		HDD18.3	2672	558	438	371	204	87	15	1	1	23	144	328	502	(9)
(10)		CDD10.0	1896	0	2	12	72	186	304	438	443	287	133	17	2	(10)
(11)		CDD18.3	516	0	0	0	1	13	69	181	186	60	7	0	0	(11)
(12)		CDH23.3	5538	0	0	0	29	194	733	1923	1942	644	73	0	0	(12)
(13)		CDH26.7	2212	0	0	0	1	37	238	857	871	199	9	0	0	(13)
(14)	Wind	WSAvg	2.5	2.0	2.4	2.5	2.6	2.4	2.9	3.7	3.5	2.6	2.3	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	395	46	39	37	45	44	36	7	4	14	29	40	51	(15)
(16)		PrecMax	506	146	93	79	93	96	94	40	39	49	114	114	88	(16)
(17)		PrecMin	301	4	7	5	8	7	0	0	0	0	0	1	6	(17)
(18)		PrecStd	60	30	23	19	22	21	27	10	8	12	27	32	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	17.5	21.6	26.0	30.2	33.6	36.7	36.9	33.3	28.0	20.9	15.7	(19)
(20)			MCWB	6.8	8.5	10.3	12.5	15.1	16.6	17.3	17.4	16.4	13.9	11.1	8.7	(20)
(21)		2%	DB	10.6	14.5	18.5	23.9	27.3	31.2	35.0	35.0	30.9	25.2	18.4	12.4	(21)
(22)			MCWB	5.8	7.4	9.1	12.0	14.6	16.4	17.4	17.2	15.5	13.4	10.4	7.8	(22)
(23)		5%	DB	8.7	12.2	16.2	21.3	25.5	29.4	33.3	33.2	29.0	23.4	16.5	10.4	(23)
(24)			MCWB	5.1	6.6	8.2	11.1	14.1	16.0	17.2	17.1	15.0	13.0	9.3	6.6	(24)
(25)		10%	DB	7.1	9.9	14.1	19.0	23.4	27.5	31.3	31.3	27.1	21.1	14.2	8.6	(25)
(26)			MCWB	4.2	5.5	7.4	10.3	13.5	15.4	16.9	17.0	14.7	12.3	8.4	5.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	9.5	11.2	13.6	16.6	18.5	20.2	19.9	17.9	15.1	12.4	9.9	(27)
(28)			MCD B	11.3	15.0	18.4	22.8	26.3	29.2	31.4	30.7	28.5	24.2	18.5	13.2	(28)
(29)		2%	WB	6.3	7.7	9.9	12.5	15.5	17.6	19.2	18.9	16.7	14.2	11.0	8.3	(29)
(30)			MCD B	9.6	12.8	16.4	21.4	24.6	27.8	29.8	29.6	27.2	22.9	16.8	11.6	(30)
(31)		5%	WB	5.3	6.8	8.8	11.7	14.7	16.7	18.4	18.3	16.0	13.5	9.9	7.1	(31)
(32)			MCD B	8.5	11.5	15.0	19.8	23.5	26.2	29.1	29.1	26.4	21.7	15.1	9.8	(32)
(33)		10%	WB	4.3	5.7	7.8	10.9	14.0	16.1	17.7	17.6	15.3	12.8	8.9	5.9	(33)
(34)			MCD B	6.9	9.7	13.1	18.1	22.0	25.6	28.5	28.5	25.1	20.0	13.3	8.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.4	10.7	11.9	12.3	12.6	13.0	12.9	13.4	11.9	11.1	8.2	(35)
(36)			MCDBR	10.4	13.2	14.8	15.7	15.6	15.1	15.4	15.2	15.9	14.9	14.5	10.7	(36)
(37)			MCWBR	6.5	7.3	7.6	7.0	6.1	5.1	4.8	5.0	6.0	6.4	7.8	6.6	(37)
(38)		5% WB	MCD BR	9.6	12.1	13.1	13.7	14.1	13.4	13.2	13.0	13.8	13.0	12.8	9.1	(38)
(39)			MCWBR	6.1	6.9	7.0	6.4	5.8	4.8	4.5	4.4	5.4	5.8	7.1	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.335	0.375	0.417	0.393	0.365	0.364	0.364	0.341	0.349	0.316	0.303	(40)	
(41)		taud	2.375	2.303	2.204	2.111	2.251	2.348	2.345	2.318	2.386	2.354	2.418	2.427	(41)	
(42)		Ebn at Noon	863	880	876	859	887	910	907	899	904	853	844	839	(42)	
(43)		Edh at Noon	86	107	131	154	136	124	123	123	108	100	82	77	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.99	3.02	4.15	5.31	6.33	7.27	7.59	6.83	5.42	3.73	2.56	1.80	(44)	
(45)		RadStd	0.23	0.41	0.33	0.45	0.39	0.49	0.29	0.20	0.32	0.23	0.24	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (11 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page